

State of Oregon Drinking Water Section
Monthly UV Disinfection Report for Ground Water Systems Requiring 4-log Viral Inactivation

System Name Salmon Run Golf Course

PWS ID# 4 1 95127

Month/Year 04/2021

Entry Point: A

Required Minimum Dose 186 mJ/cm²

Date	Time	Source(s) in use	Any UV Alarms? (Y/N)	Notes
1		Well, SRC-AA		
2		Well, SRC-AA		
3		Well, SRC-AA		
4		Well, SRC-AA		
5		Well, SRC-AA		
6		Well, SRC-AA		
7	14:04	Well, SRC-AA	N	
8		Well, SRC-AA		
9		Well, SRC-AA		
10		Well, SRC-AA		
11		Well, SRC-AA		
12		Well, SRC-AA		
13		Well, SRC-AA		
14	11:25	Well, SRC-AA	N	
15		Well, SRC-AA		
16		Well, SRC-AA		
17		Well, SRC-AA		
18		Well, SRC-AA		
19		Well, SRC-AA		
20		Well, SRC-AA		
21		Well, SRC-AA		
22	10:15	Well, SRC-AA	N	
23		Well, SRC-AA		
24		Well, SRC-AA		
25		Well, SRC-AA		
26		Well, SRC-AA		
27		Well, SRC-AA		
28		Well, SRC-AA		
29	09:58	Well, SRC-AA	N	
30		Well, SRC-AA		
31		Well, SRC-AA		

Was the minimum UV dose ever less than the required dose of 186 mJ/cm²? Or was the alarm ever triggered? Yes No

This form is for groundwater systems where no residual disinfection has been required to prevent regrowth of pathogens in the pipes.

Date & time UV reactor failed:

____/____/____ :____ am/pm

Date & time it was returned to service:

____/____/____ :____ am/pm

Printed Name: Mark Haglund

Title: Operations Supervisor

Operator Certification #: T-6161 FE

Signature: 

Phone #: (541) 412-0424

OR

Date: 5/4/2021

Small Groundwater System