


State of Oregon Drinking Water Section  
**Monthly UV Disinfection Report for Ground Water Systems Requiring 4-log Viral Inactivation**

System Name Salmon Run Golf Course

PWS ID# 41 95127

Month/Year 08/2021 Entry Point: A

Required Minimum Dose 186 mJ/cm<sup>2</sup>

Date	Time	Source(s) in use	Any UV Alarms? (Y/N)	Notes
1		Well, SRC-AA		
2		Well, SRC-AA		
3		Well, SRC-AA		
4		Well, SRC-AA		
5	13:30	Well, SRC-AA	N	
6		Well, SRC-AA		
7		Well, SRC-AA		
8		Well, SRC-AA		
9		Well, SRC-AA		
10		Well, SRC-AA		
11		Well, SRC-AA		
12	14:00	Well, SRC-AA	N	
13		Well, SRC-AA		
14		Well, SRC-AA		
15		Well, SRC-AA		
16		Well, SRC-AA		
17		Well, SRC-AA		
18		Well, SRC-AA		
19	14:13	Well, SRC-AA	Y	Golf Course Staff assisted resetting it.
20		Well, SRC-AA	Y 	Comp. Boards failed, loss of system Pressure, boil water notice issued.
21		Well, SRC-AA		Boil water notice in-place
22		Well, SRC-AA		Boil water notice in-place
23		Well, SRC-AA		Boil water notice in-place
24		Well, SRC-AA		Boil water notice in-place
25		Well, SRC-AA		Boil water notice in-place
26		Well, SRC-AA		Boil water notice in-place
27		Well, SRC-AA		Boil water notice in-place
28		Well, SRC-AA		Boil water notice in-place
29		Well, SRC-AA		Boil water notice in-place
30		Well, SRC-AA		Boil water notice in-place
31		Well, SRC-AA		Boil water notice in-place

Was the minimum UV dose ever less than the required dose of 186 mJ/cm<sup>2</sup>? Or was the alarm ever triggered?  Yes  No  
 If yes, was a boil notice issued, and DWS contacted? If not, please explain: 8/19 system was reset. 8/20, system could not be reset due to failed comp. boards and DWS was contacted.

**This form is for groundwater systems where no residual disinfection has been required to prevent regrowth of pathogens in the pipes.**

Date & time UV reactor failed:  
08/20/2021 12:01 am/pm  
 Date & time it was returned to service:  
Not returned to normal service yet, awaiting parts.

Printed Name: Mark Haglund

Title: Operations Supervisor

Operator Certification #: T-6161 FE

Signature: 

Phone #: (541) 412-0424

OR

Date: 9/08/2021

Small Groundwater System