

State of Oregon Drinking Water Section
Monthly UV Disinfection Report for Ground Water Systems Requiring 4-log Viral Inactivation

System Name <u>Salmon Run Golf Course</u>	PWS ID# 41 <u>95127</u>
Month/Year <u>01/2022</u> Entry Point: <u>A</u>	Required Minimum Dose <u>186</u> mJ/cm ²

Date	Time	Source(s) in use	Any UV Alarms? (Y/N)	Notes
1		Well, SRC-AA		
2		Well, SRC-AA		
3		Well, SRC-AA		
4		Well, SRC-AA		
5		Well, SRC-AA		
6	11:40	Well, SRC-AA	N	
7		Well, SRC-AA		
8		Well, SRC-AA		
9		Well, SRC-AA		
10		Well, SRC-AA		
11		Well, SRC-AA		
12		Well, SRC-AA		
13	13:12	Well, SRC-AA	N	
14		Well, SRC-AA		
15		Well, SRC-AA		
16		Well, SRC-AA		
17		Well, SRC-AA		
18		Well, SRC-AA		
19		Well, SRC-AA		
20	10:44	Well, SRC-AA	N	
21		Well, SRC-AA		
22		Well, SRC-AA		
23		Well, SRC-AA		
24		Well, SRC-AA		
25		Well, SRC-AA		
26		Well, SRC-AA		
27	09:13	Well, SRC-AA	N	
28		Well, SRC-AA		
29		Well, SRC-AA		
30		Well, SRC-AA		
31		Well, SRC-AA		

Was the minimum UV dose ever less than the required dose of 186 mJ/cm²? Or was the alarm ever triggered? Yes No
 If yes, was a boil notice issued, and DWS contacted? If not, please explain:

<p style="text-align: center;">This form is for groundwater systems where no residual disinfection has been required to prevent regrowth of pathogens in the pipes.</p>	Date & time UV reactor failed: // am/pm Date & time it was returned to service: // am/pm
--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	---------------------------------------------------------------------------------------------------------------------------------------------

Printed Name: <u>Mark Haglund</u> Signature: <u><i>Mark Haglund</i></u> Date: <u>02/03/22</u>	Title: <u>Operations Supervisor</u> Phone #: <u>(541) 412-0424</u>	Operator Certification #: <u>T-6161 FE</u> OR Small Groundwater System <input type="checkbox"/>
-----------------------------------------------------------------------------------------------------	-----------------------------------------------------------------------	-------------------------------------------------------------------------------------------------------