

Received Time Mar. 1, 2021 5:37 PM No. 6877

System Name **Rice Hill RV Park 541-513-6883** PWS ID# **4 1 95210**
 Month/Year **02 / 21** Entry Point: **EP 1** Required Minimum Residual **0.5 mg/L**

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	10:00	well #1	1.2	DLW
2	10:00		1.1	DLW
3	10:00		1.2	DLW
4	10:00		1.2	DLW
5	10:00		1.2	DLW
6	10:00		1.2	JR
7	10:00		1.3	DLW
8	10:00		1.2	DLW
9	10:00		1.2	JR
10	10:00		1.2	DLW
11	9:50		1.2	JR
12	10:00		1.2	JR
13	10:00		1.2	JR
14	10:00		1.2	JR
15	10:30		1.2	JR
16	10:00		1.2	JR
17	11:00		1.2	JR
18	10:00		1.1	JR
19	10:00		1.2	JR
20	10:00		1.2	JR
21	10:00		1.6	DLW
22	10:00		1.7	DLW
23	10:00		1.1	DLW
24	10:00		1.1	DLW
25	10:00		1.2	DLW
26	10:00		1.1	DLW
27	10:30		1.1	JR
28	10:00		1.2	DLW
29				
30				
31				

Was the chlorine residual ever less than the required minimum residual of _____ mg/L? Yes No
 If yes, what was the longest time period until the required level was restored? _____ hours - If > 4 hours, Drinking Water Program to be notified by end of next business day.

<p>GWS Serving 3,300 or Fewer</p> <p>If yes, did you monitor every four hours until the residual returned to _____ mg/L as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>Attach those results and submit them with this form.</p>	<p>GWS Serving More Than 3,300</p> <p>Did continuous monitoring equipment fail at any time this reporting month? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>Attach grab sample results and submit them with this form.</p>	<p>Date continuous monitoring equipment failed: / /</p> <p>Date it was returned to service: / /</p>
----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	-----------------------------------------------------------------------------------------------------

Printed Name: Steve Scott (or Tarni Allen)	Title: _____	Operator Certification #: n/a
Signature: _____	Phone #: (541) 337-9635	OR
Date: / /		Small Groundwater System <input checked="" type="checkbox"/>