

State of Oregon Drinking Water Program
 Monthly Disinfection Report for Group

PWS ID# 41 95210

System Name Rice Hill RV Park 541-513-6883

Month/Year 02 / 22 Entry Point: EP 1

Required Minimum Residual 0.5 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	10:00	well #1	1.1	DLW
2	10:00		1.1	DLW
3	10:00		1.0	DLW
4	10:00		1.0	DLW
5	10:00		1.0	DLW
6	10:00		1.1	DLW
7	10:00		1.1	DLW
8	10:00		1.1	DLW
9	10:00		1.1	DLW
10	10:00		1.2	DLW
11	10:00		1.2	DLW
12	10:00		1.1	DLW
13	10:00		1.0	DLW
14	10:00		1.1	DLW
15	10:00		1.1	DLW
16	10:00		1.0	DLW
17	10:00		1.1	DLW
18	10:00		1.1	DLW
19	10:00		1.1	DLW
20	10:00		1.1	DLW
21	10:00		1.0	DLW
22	10:00		1.0	DLW
23	10:00		1.1	DLW
24	10:00		1.1	DLW
25	10:00		1.1	DLW
26	10:00		1.1	DLW
27	10:00		1.0	DLW
28	10:00		1.0	DLW
29				
30				
31				

Was the chlorine residual ever less than the required minimum residual of _____ mg/L? Yes No

If yes, what was the longest time period until the required level was restored? _____ hours - If > 4 hours, Drinking Water Program to be notified by end of next business day.

GWS Serving 3,300 or Fewer

If yes, did you monitor every four hours until the residual returned to _____ mg/L as required? Yes No

Attach those results and submit them with this form.

GWS Serving More Than 3,300

Did continuous monitoring equipment fail at any time this reporting month? Yes No

If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? Yes No

Attach grab sample results and submit them with this form.

Date continuous monitoring equipment failed: / /

Date it was returned to service: / /

Printed Name: Steve Scott (or Tami Allen)

Title:

Operator Certification #: n/a

Signature: _____

Phone #: (541) 337-9635

OR

Date: / /

Small Groundwater System

Received Time Mar. 1, 2022 11:06 AM No. 8343