

State of Oregon Drinking Water Program
Monthly Disinfection Report for Groundwater

PWS ID# 41 95210

System Name Rice Hill RV Park 541-513-6883

Month/Year 08/22 Entry Point: EP 1

Required Minimum Residual 0.5 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	7:30	well #1	1.1	DLW
2	10:00		1.2	DLW
3	10:00		1.1	DLW
4	10:30		1.1	DLW
5	9:30		1.3	DLW
6	10:00		1.2	DLW
7	8:39		1.3	DLW
8	9:00		1.2	DLW
9	2:07		1.3	DLW
10	9:30		1.1	DLW
11	7:00		1.1	DLW
12	7:00		1.1	DLW
13	7:00		1.1	DLW
14	7:00		1.2	DLW
15	11:00		1.1	DLW
16	10:00		1.1	DLW
17	10:00		1.1	DLW
18	10:00		1.1	DLW
19	10:00		1.0	DLW
20	10:00		1.0	DLW
21	10:00		1.0	DLW
22	10:00		1.1	DLW
23	10:00		1.1	DLW
24	10:00		1.1	DLW
25	10:00		1.1	DLW
26	10:00		1.0	DLW
27	10:00		1.1	DLW
28	10:00		1.2	DLW
29	10:00		1.2	DLW
30	10:00		1.1	DLW
31	9:00		1.1	DLW

Was the chlorine residual ever less than the required minimum residual of _____ mg/L? Yes No
 If yes, what was the longest time period until the required level was restored? _____ hours - If > 4 hours, Drinking Water Program to be notified by end of next business day.

<p>GWS Serving 3,300 or Fewer</p> <p>If yes, did you monitor every four hours until the residual returned to _____ mg/L as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>Attach those results and submit them with this form.</p>	<p>GWS Serving More Than 3,300</p> <p>Did continuous monitoring equipment fail at any time this reporting month? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>Attach grab sample results and submit them with this form.</p>
<p>Date continuous monitoring equipment failed: / /</p> <p>Date it was returned to service: / /</p>	

Printed Name: Steve Scott (or Tami Allen)	Title:	Operator Certification #: n/a
Signature: _____	Phone #: (541) 337-9635	OR
Date: / /		Small Groundwater System <input checked="" type="checkbox"/>

Received Time Aug. 31, 2022 8:52AM No. 8884