

System Name Rice Hill RV Park 541-513-6883

PWS ID# 4 1 95210

Month/Year 08 / 23 Entry Point: EP 1

Required Minimum Residual 0.5 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	9:45	well #1	1.5	NS
2	10:00		1.5	JR
3	9:50		1.5	J.B
4	10:00		1.5	J.B
5	10:00		1.5	J.B
6	9:30		1.5	NS
7	10:00		1.5	NS
8	10:00		1.5	NS
9	9:35		1.5	JB
10	9:45		1.5	JB
11	9:45		1.5	JB
12	9:45		1.5	JB
13	10:15		1.5	NS
14	9:45		1.5	NS
15	10:00		1.5	NS
16	10:00		1.5	NS
17	9:30		1.5	JB
18	9:30		1.5	JR
19	9:20		1.5	JB
20	7:00		1.5	JB
21	9:30		1.5	NS
22	10:00		1.5	NS
23	9:30		1.5	NS
24	9:30		1.5	JB
25	9:40		1.5	JB
26	9:45		1.5	JB
27	11:00		1.5	NS
28	10:00		1.5	NS
29	9:30		1.5	NS
30	9:45		1.5	NS
31	9:20		1.5	JB

Was the chlorine residual ever less than the required minimum residual of \_\_\_\_\_ mg/L?  Yes  No  
 If yes, what was the longest time period until the required level was restored? \_\_\_\_\_ hours - If > 4 hours, Drinking Water Program to be notified by end of next business day.

<p><b>GWS Serving 3,300 or Fewer</b></p> <p>If yes, did you monitor every four hours until the residual returned to _____ mg/L as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>Attach those results and submit them with this form.</p>	<p><b>GWS Serving More Than 3,300</b></p> <p>Did continuous monitoring equipment fail at any time this reporting month? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>Attach grab sample results and submit them with this form.</p>
<p>Date continuous monitoring equipment failed:     /     /</p> <p>Date it was returned to service:     /     /</p>	

Printed Name: Steve Scott (or Tami Allen)	Title:	Operator Certification #: n/a
Signature: _____	Phone #: (541) 337-9635	OR
Date: / /		Small Groundwater System <input checked="" type="checkbox"/>

