

System Name **Rice Hill RV Park 541-513-6883** PWS ID# **41 95210**  
 Month/Year **09/23** Entry Point: **EP 1** Required Minimum Residual **0.5 mg/L**

Sept. 2023

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	9:45	well #1	1.5	4B
2	9:30		1.5	4B
3	7:45		1.5	7B
4	9:30		1.5	7B
5	10:35		1.5	7B
6	9:30		1.5	7B
7	9:20		1.5	4B
8	9:40		1.5	4B
9	9:35		1.5	4B
10	9:30		1.5	4B
11	9:30		1.5	7B
12	9:45		1.5	7B
13	9:30		1.5	7B
14	9:30		1.5	4B
15	9:30		1.5	4B
16	9:40		1.5	4B
17	7:00		1.5	4B
18	9:50		1.5	4B
19	9:45		1.5	7B
20	10:00		1.5	7B
21	9:40		1.5	4B
22	9:30		1.5	4B
23	9:35		1.5	7B
24	8:00 A		1.5	7B
25	9:54		1.5	7B
26	10:00		1.5	7B
27	10:00		1.5	7B
28	9:30		1.5	4B
29	9:40		1.5	4B
30	9:35		1.5	4B
31	10:15		1.5	4B

Was the chlorine residual ever less than the required minimum residual of \_\_\_\_\_ mg/L?  Yes  No  
 If yes, what was the longest time period until the required level was restored? \_\_\_\_\_ hours - If > 4 hours, Drinking Water Program to be notified by end of next business day.

<p><b>GWS Serving 3,300 or Fewer</b></p> <p>If yes, did you monitor every four hours until the residual returned to _____ mg/L as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>Attach those results and submit them with this form.</p>	<p><b>GWS Serving More Than 3,300</b></p> <p>Did continuous monitoring equipment fail at any time this reporting month? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>Attach grab sample results and submit them with this form.</p>
<p>Date continuous monitoring equipment failed: / /</p> <p>Date it was returned to service: / /</p>	

Printed Name: Steve Scott (or Tami Allen)	Title:	Operator Certification #: n/a
Signature: _____	Phone #: (541) 337-9635	OR
Date: / /		Small Groundwater System <input checked="" type="checkbox"/>