



State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems

System Name Rice Hill RV Park 541-513-6883 PWS ID# 41 95210
 Month/Year 1/24 Entry Point: EP 1 Required Minimum Residual 0.5 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	9:00	well #1	1.5	GM
2	10:00 AM		2.5	RB
3	10:00 AM		1.5	RB
4	9:00		1.5	GM
5	9:00		1.5	GM
6	9:00		1.5	GM
7	10:00		1.5	GM
8	9:45		1.5	GM
9	9:45		1.5	RB
10	9:00		1.5	RB
11	9:00		1.5	RB
12	9:15		1.5	GM
13	9:20		1.5	GM
14	10:30		1.5	GM
15	9:45A		1.5	RB
16	10 AM		1.5	RB
17	9:30		1.2	RB
18	9:00		1.5	GM
19	9:00		1.5	GM
20	9:00		1.5	GM
21	10:00		1.5	GM
22	10:30		1.5	GM
23	9:30		1.5	GM
24	9:30		1.5	GM
25	9:10		1.5	GM
26	9:00		1.5	GM
27	9:00		1.5	GM
28	10:00		1.5	GM
29	9:40		1.5	GM
30	9:35		1.5	GM
31	10:05		1.5	GM

Was the chlorine residual ever less than the required minimum residual of _____ mg/L? Yes No
 If yes, what was the longest time period until the required level was restored? _____ hours - If > 4 hours, Drinking Water Program to be notified by end of next business day.

GWS Serving 3,300 or Fewer
 If yes, did you monitor every four hours until the residual returned to _____ mg/L as required? Yes No
 Attach those results and submit them with this form.

GWS Serving More Than 3,300
 Did continuous monitoring equipment fail at any time this reporting month? Yes No
 Date continuous monitoring equipment failed: / /
 If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? Yes No
 Date it was returned to service: / /
 Attach grab sample results and submit them with this form.

Printed Name: Tami Allen Title: _____
 Signature: TAMI ALLEN Phone #: (541) 337-9635
 Date: / /

Operator Certification # n/a
 OR
 Small Groundwater System