

STATE OF MARYLAND DRINKING WATER PROGRAM
 Monthly Disinfection Report for Ground Water Systems

System Name Rice Hill RV Park 541-513-6883

PWS ID# 41 95210

Month/Year / Entry Point EP 1

Required Minimum Residual 0.5 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	9:15	well #1	1.3	OK
2	9:35		1.5	OK
3	9:05		1.5	OK
4	9:00		1.2	OK
5	9:10		1.6	OK
6	9:00		1.5	OK
7	9:10		1.5	OK
8	9:35		1.4	OK
9	9:25		1.5	OK
10	9:00		1.5	OK
11	9:15		1.5	OK
12	9:45		1.5	OK
13	9:30		1.6	OK
14	10:00		1.4	OK
15	9:50		1.5	OK
16	9:00		1.0	OK
17	9:00		1.2	OK
18	9:00		1.5	OK
19	9:00		1.25	OK
20	8:45		1.5	OK
21	10:15		1.5	OK
22	9:20		1.5	OK
23	9:00		1.5	OK
24	9:30		1.5	OK
25	9:10		1.3	OK
26	9:00		1.25	OK
27	9:00		1.5	OK
28	9:35		1.5	OK
29	9:30		1.5	OK
30	10:05		1.5	OK
31	9:30		1.5	OK

Was the chlorine residual ever less than the required minimum residual of mg/L? Yes No
 If yes, what was the longest time period until the required level was restored? hours - (if > 4 hours, Drinking Water Program 301 notified by end of next business day)

<p>GWS Serving 3,300 or Fewer</p> <p>If yes, did you monitor every four hours until the residual returned to mg/L as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>Attach those results and submit them with this form.</p>	<p>GWS Serving More Than 3,300</p> <p>Did continuous monitoring equipment fail at any time this reporting month? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>Attach grab sample results and submit them with this form.</p>
	<p>Date continuous monitoring equipment failed: / /</p> <p>Date it was returned to service: / /</p>

Printed Name: Tami Allen Title: _____ Operator Certification #. n/a

Signature: *Tami Allen* Phone #: (541) 337-8636 OR

Date: / / Small Groundwater System