

**State of Oregon Drinking Water Program  
Monthly Disinfection Report for Ground Water Systems**

System Name Rice Hill RV Park 541-513-6883

PWS ID# 41 95210

Month/Year 6-1 / 25 Entry Point: EP 1

Required Minimum Residual 0.5 mg/L

	Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
<u>Sun</u>	1	7:05	well #1 1.75		W.W.
	2	11:15	1.75		M-F
	3	11:05	1.5		M-F
	4	10:45	1.3		M-F
	5	9:39	1.7		W.W.
	6	9:39	1.67		W.W.
	7	9:48	1.80		W.W.
	8	9:15	1.6		W.W.
	9	10:25	1.6		M-F
	10	9:50	1.5		M-F
	11	9:45	1.5		M-F
	12	9:45	1.5		M-F
	13	9:40	1.35		W.W.
	14	9:46	1.30		W.W.
<u>Sun</u>	15	7:00	1.40		W.W.
	16	10:50	1.4		W.W.
	17	9:45	1.4		M-F
	18	9:10	1.6		M-F
	19	9:41	1.6		W.W.
	20	9:42	1.5		W.W.
	21	9:45	1.4		W.W.
<u>Sun</u>	22	10:15	1.4		W.W.
	23	10:35	1.4		M-F
	24	9:20	1.4		M-F
	25	10:15	1.4		M-F
	26	9:40	1.5		W.W.
	27	9:50	1.6		W.W.
	28	9:45	1.5		W.W.
<u>Sun</u>	29	7:10 AM	1.7		W.W.
	30	9:50	1.6		W.W.
	31				M-F

Was the chlorine residual ever less than the required minimum residual of \_\_\_\_\_ mg/L? ☐ Yes ☒ No  
 If yes, what was the longest time period until the required level was restored? \_\_\_\_\_ hours - If > 4 hours, Drinking Water Program to be notified by end of next business day.

**GWS Serving 3,300 or Fewer**

If yes, did you monitor every four hours until the residual returned to \_\_\_\_\_ mg/L as required? ☐ Yes ☒ No

Attach those results and submit them with this form.

**GWS Serving More Than 3,300**

Did continuous monitoring equipment fail at any time this reporting month? ☐ Yes ☒ No

If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? ☐ Yes ☐ No

Attach grab sample results and submit them with this form.

Date continuous monitoring equipment failed: \_\_\_\_\_ / \_\_\_\_\_ / \_\_\_\_\_

Date it was returned to service: \_\_\_\_\_ / \_\_\_\_\_ / \_\_\_\_\_

Printed Name: Steve Scott (or Tami Allen)

Title: Owner

Operator Certification #: n/a

Signature: TAM

Phone #: (541) 337-9635

OR

Date: 6 / 30 / 25

Small Groundwater System ☒