

**State of Oregon Drinking Water Program  
Monthly Disinfection Report for Ground Water Systems**

System Name **Lobster Creek / Campground**

PWS ID# **4195331**

Month/Year **11 / 21**

Entry Point:

Required Minimum Residual **0.50** mg/L

| Date | Time   | Source(s) in use | Lowest free chlorine residual at entry point to distribution system (mg/L) | Notes |
|------|--------|------------------|----------------------------------------------------------------------------|-------|
| 1    | 7am    | HOST Site        | 1.84                                                                       |       |
| 2    | 9am    | 1                | 1.97                                                                       |       |
| 3    | 7am    | 1                | 1.94                                                                       |       |
| 4    | 1030am | Day use          | 1.77                                                                       |       |
| 5    | 7am    | Host Site        | 1.92                                                                       |       |
| 6    | 7am    | 1                | 1.89                                                                       |       |
| 7    | 7am    | 1                | 1.86                                                                       |       |
| 8    | 7am    | 1                | 1.87                                                                       |       |
| 9    | 7am    | 1                | 1.90                                                                       |       |
| 10   | 8am    | Site #2          | 1.82                                                                       |       |
| 11   | 7am    | Host Site        | 1.91                                                                       |       |
| 12   | 730am  | 1                | 1.84                                                                       |       |
| 13   | 7am    | 1                | 1.87                                                                       |       |
| 14   | 7am    | 1                | 1.85                                                                       |       |
| 15   | 7am    | 1                | 1.85                                                                       |       |
| 16   | 9am    | Day use          | 1.80                                                                       |       |
| 17   | 7am    | Host Site        | 1.92                                                                       |       |
| 18   | 830am  | 1                | 1.87                                                                       |       |
| 19   | 8am    | 1                | 1.91                                                                       |       |
| 20   | 7am    | 1                | 1.96                                                                       |       |
| 21   | 730am  | 1                | 1.93                                                                       |       |
| 22   | 8am    | Site #2          | 1.88                                                                       |       |
| 23   | 7am    | Host Site        | 1.96                                                                       |       |
| 24   | 7am    | 1                | 1.99                                                                       |       |
| 25   | 730am  | 1                | 1.96                                                                       |       |
| 26   | 7am    | 1                | 1.92                                                                       |       |
| 27   | 930am  | Day use          | 1.74                                                                       |       |
| 28   | 7am    | Host Site        | 1.81                                                                       |       |
| 29   | 7am    | 1                | 1.79                                                                       |       |
| 30   | 7am    | 1                | 1.72                                                                       |       |
| 31   |        |                  |                                                                            |       |

Was the chlorine residual ever less than the required minimum residual of 0.50 mg/L? ☐ Yes ☒ No

If yes, what was the longest time period until the required level was restored?  
If yes, what was the longest time period until the required level was restored?

hours - If > 4 hours, Drinking Water Program to be notified by end of next business day.

**GWS Serving 3,300 or Fewer**

If yes, did you monitor every four hours until the residual returned to 0.50 mg/L as required? ☐ Yes ☐ No

Attach those results and submit them with this form.

**GWS Serving More Than 3,300**

Did continuous monitoring equipment fail at any time this reporting month? ☐ Yes ☐ No

If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? ☐ Yes ☐ No

Attach grab sample results and submit them with this form.

Date continuous monitoring equipment failed:

/ /

Date it was returned to service:

/ /

Printed Name: **Willis Sage**

Title: **REL T/C**

Signature: 

Phone #: **(541) 242-3603**

Date: **12/01/2021**

Operator Certification #:

OR

Small Groundwater System ☒