

State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems

System Name Lobster Creek / Campground

PWS ID# 4195331

Month/Year 6 122 Entry Point:

Required Minimum Residual 0.50 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	7~	Host Site	2.8	
2	7~	1	2.77	
3	730	1	2.84	
4	8~	Day use	3.11	
5	7~	Host Site	2.74	
6	7~	1	2.77	
7	730	1	2.94	
8	730/	Site #2	2.92	
9	7AM	Host Site	2.98	
10	730	1	3.0	
11	7~	1	2.8	
12	730	1	2.77	
13	8~	Day use	3.18	
14	7~	Host Site	2.74	
15	7~	1	2.86	
16	830	1	3.14	
17	7~	1	2.94	
18	830	Day use	3.14	
19	8~	Site #2	3.24	
20	7AM	Host Site	2.8	
21	730	1	2.88	
22	7~	1	2.81	
23	730	1	2.81	
24	9AM	Site #2	3.3	
25	7~	Host Site	2.72	
26	730	1	2.77	
27	7~	1	2.82	
28	800h	Day use	3.0	
29	7~	Host Site	2.83	
30	7~	1	2.95	
31				

Was the chlorine residual ever less than the required minimum residual of 0.50 mg/L? ☐ Yes ☒ No

If yes, what was the longest time period until the required level was restored?

hours - If > 4 hours, Drinking Water Program to be

notified by end of next business day.

GWS Serving 3,300 or Fewer

If yes, did you monitor every four hours until the residual returned to 0.50 mg/L as required? ☐ Yes ☐ No

Attach those results and submit them with this form.

GWS Serving More Than 3,300

Did continuous monitoring equipment fail at any time this reporting month? ☐ Yes ☐ No

If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? ☐ Yes ☐ No

Attach grab sample results and submit them with this form.

Date continuous monitoring equipment failed:

/ /
Date it was returned to service:

/ /

Printed Name: Will Sayre

Title: Rec to C

Operator Certification #:

Signature: 

Phone #: (503) 247-3603

OR

Date: 0910 1202

Small Groundwater System ☒

December 19, 2012