

**State of Oregon Drinking Water Program  
Monthly Disinfection Report for Ground Water Systems**

System Name **Lobster Creek / Campground**

PWS ID# **4195331**

Month/Year **1/23** Entry Point:

Required Minimum Residual **0.50** mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	7AM	Host Site	2.31	
2	7AM	1	2.27	
3	7AM	1	2.34	
4	8AM	Site # 2	2.41	
5	7AM	Host Site	2.26	
6	7AM	1	2.35	
7	7AM	1	2.28	
8	7AM	Host Site	2.32	
9	7AM	1	2.34	
10	7AM	Day use	2.42	
11	8AM	Host Site	2.26	
12	7AM	1	2.29	
13	7AM	1	2.31	
14	7AM	1	2.38	
15	7AM	Site # 2	2.36	
16	7AM	Host Site	2.33	
17	7AM	1	2.24	
18	7AM	1	2.26	
19	7AM	1	2.22	
20	7:30AM	Site # 2	2.28	
21	7AM	Host Site	2.31	
22	7AM	1	2.33	
23	7AM	1	2.31	
24	7:30AM	1	2.27	
25	7AM	Day Use Area	2.33	
26	7:30AM	Host Site	2.27	
27	7:30AM	1	.55 / 1.07	Chlorine Pump Stopped.
28	7AM	1	1.06	Pump repaired. Re-test -
29	8:30AM	Site # 2	1.19	1.07, Re
30	7AM	Host Site	1.21	
31	7AM	1	1.24	

Was the chlorine residual ever less than the required minimum residual of 0.50 mg/L? ☐ Yes ☒ No

If yes, what was the longest time period until the required level was restored? \_\_\_\_\_ hours - If > 4 hours, Drinking Water Program to be notified by end of next business day.

**GWS Serving 3,300 or Fewer**

If yes, did you monitor every four hours until the residual returned to 0.50 mg/L as required? ☐ Yes ☐ No

Attach those results and submit them with this form.

**GWS Serving More Than 3,300**

Did continuous monitoring equipment fail at any time this reporting month? ☐ Yes ☐ No

If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? ☐ Yes ☐ No

Attach grab sample results and submit them with this form.

Date continuous monitoring equipment failed:

/ /  
Date it was returned to service:

/ /

Printed Name: **Will B Sage**

Signature: *[Signature]*

Date: **2/1/2223**

Title: **Rec'tec**

Phone #: **(541) 244-3600**

Operator Certification #:

OR

Small Groundwater System ☒