

System Name 

PWS ID# 41 95377

Month/Year July 24 Entry Point: \*

Required Minimum Residual .2 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	1145		.6	
2	330	kitchen	.6	
3	6pm		.6	ADD 96 g.
4	1115		.6	
5	1130		.6	chlorine to
6	1130		.6	
7	1130		.6	System
8	1130		.6	
9	330		.6	
10	6pm		.6	
11	1115		.6	
12	1100		.6	
13	1130		.6	
14	1130		.6	
15	1130		.6	
16	330		.6	
17	6pm		.6	
18	1130		.6	
19	1130		.6	
20	1130		.6	
21	1145		.6	
22	1130		.6	
23	330		.6	
24	6pm		.6	
25	1130		.6	
26	1145		.6	
27	1130		.6	
28	1130		.6	
29	1130		.6	
30	330		.6	
31	6pm		.6	

Was the chlorine residual ever less than the required minimum residual of .2 mg/L?  Yes  No

If yes, what was the longest time period until the required level was restored? \_\_\_\_\_ hours - If &gt; 4 hours, Drinking Water Program to be notified by end of next business day.

**GWS Serving 3,300 or Fewer**If yes, did you monitor every four hours until the residual returned to \_\_\_\_\_ mg/L as required?  Yes  No

Attach those results and submit them with this form.

**GWS Serving More Than 3,300**Did continuous monitoring equipment fail at any time this reporting month?  Yes  NoIf yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required?  Yes  No

Attach grab sample results and submit them with this form.

Date continuous monitoring equipment failed: / /

Date it was returned to service: / /

Printed Name: EDWARD BORTA

Title: owner

Operator Certification #: /

Signature: Edward M. Borta

Phone #: (541) 787-5988

OR N/A

Date: Aug 1 24

Small Groundwater System Return by 10<sup>th</sup> of following month by either email [dwp.dmce@state.or.us](mailto:dwp.dmce@state.or.us); fax 971-673-0694; or mail to Drinking Water Services, PO Box 14350, Portland, OR 97293-0350.

August 22, 2019