State of Oregon Drinking Water Program Monthly Disinfection Report for Ground Water Systems

Systen	n Name	ASCA IS TSA	responil	PV	PWS ID# 41 95377		
Month/	Year Ave	1/24 Entry Po	oint:	Required Minimum Residual , 2 mg/L			
Date	Time	Source(s)	n use	Lowest free chlorine residual at entry point to distribution system (mg/L)		Notes	
1	1130	λ		, 6		40 00 11 -	
2	1115	404		<u>(</u>	AND	70 Schloowe	
3	330	7.11	room	المار الم			
4	Copm	DAT		<i>-</i> (<i>a</i>			
5	//30			. 6			
6	1/30			.6		. , , , , , , , , , , , , , , , , , , ,	
7 8	1130			,6			
9				.4			
10	16/5			ى:			
11	300			ile.			
12	6 pm			.6			
13	1130		<u>,</u>	, (e			
14	1170			, lo			
15	1130			م)،			
16	1130			. (0			
17	330			.6			
18	6 pm			. 6		,,	
19	1130			.6			
20	11:45		· · · · · · · · · · · · · · · · · · ·	, 6			
21	11 45			.6			
22	1115			,6			
23	11.30			,6			
24	330			,6			
25	6pm			. (.			
26	1130			,0			
27	1130			, 5			
28	1145						
29	1115			-5			
30	77.30			, 5			
31	330			2 ء			
Was the chlorine residual ever less than the required minimum residual of , Z mg/L? Yes No							
If yes, what was the longest time period until the required level was restored? hours – If > 4 hours, Drinking Water Program to be notified by end of next business day.							
GWS Serving 3,300 or Fewer				GWS Serving N	GWS Serving More Than 3,300		
If yes, did you monitor every four hours until the residual returned to mg/L			Did continuous monitoring equipment fail at any reporting month? ☐ Yes ☐ No		ny time this	Date continuous monitoring equipment failed:	
as required? Yes No			,	<u> </u>	r house until the	1 1	
Attach those results and submit them with this form.			If yes, were grab samples collected every four hot continuous monitoring equipment was returned to required?			Date it was returned to service:	
			Attach grab sample results and submit them		with this form.	1 1	
Printed Name: COWARD BORTA Title: OWNER					Operator Certification #:		
Signature:					OR NA		
Date: 50TI 1 124 5998					Small Groundwater System 🗌		