

**State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems**

System Name Rascals Bar & Grill PWS ID# 41 95377
 Month/Year Aug / 25 Entry Point: A Required Minimum Residual .2 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	1130		.6	
2	1130		.6	
3	1130	Small Bathroom	.6	Add 96 oz chlorine to vessel
4	1130		.6	
5	330		.6	
6	6pm		.6	
7	1115		.6	
8	1130		.5	
9	1130		.5	
10	1130		.5	
11	1130		.5	
12	330		.5	
13	6pm		.5	
14	1115		.5	
15	1130		.5	
16	1130		.5	
17	1145		.5	
18	1130		.5	
19	330		.5	
20	6pm		.5	
21	1115		.5	
22	1130		.5	
23	1130		.5	
24	1130		.5	
25	1145		.5	
26	330		.5	
27	6pm		.5	
28	1115		.5	
29	1130		.5	
30	1145		.5	
31				

Was the chlorine residual ever less than the required minimum residual of .2 mg/L? ☐ Yes ☒ No
 If yes, what was the longest time period until the required level was restored? _____ hours – If > 4 hours, Drinking Water Program to be notified by end of next business day.

GWS Serving 3,300 or Fewer If yes, did you monitor every four hours until the residual returned to _____ mg/L as required? ☐ Yes ☐ No Attach those results and submit them with this form.	GWS Serving More Than 3,300 Did continuous monitoring equipment fail at any time this reporting month? ☐ Yes ☐ No If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? ☐ Yes ☐ No Attach grab sample results and submit them with this form.	Date continuous monitoring equipment failed: _____ / _____ / _____ Date it was returned to service: _____ / _____ / _____
---	---	--

Printed Name: EDWARD BORTA Title: owner Operator Certification #: _____
 Signature: Edward M. Borta Phone #: (541) 787-5998 OR N/A
 Date: Sept / 9 / 25 Small Groundwater System ☐

Return by 10th of following month by either email dwp.dmce@state.or.us; fax 971-673-0694; or mail to Drinking Water Services, PO Box 14350, Portland, OR 97293-0350.