

**State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems**

System Name MR RASCALS PWS ID# 41 95377
 Month/Year MAR 23 Entry Point: A Required Minimum Residual 0.2 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	6 pm		.4	
2	1130		.4	
3	1130	MENS	.4	
4	1130		.4	
5	1130	BATHROOM	.4	
6	1130		.4	
7	330		.4	
8	6 pm		.5	
9	1145		.5	
10	1130		.5	
11	1130		.5	
12	1130		.5	
13	1130		.5	
14	330		.5	
15	6 pm		.5	
16	1130		.5	
17	1130		.5	
18	1130		.5	
19	1130		.5	
20	1130		.5	
21	330		.5	
22	6 pm		.5	
23	1130		.5	
24	1130		.5	
25	1130		.6	
26	1130		.6	
27	1100w		.6	
28	330		.6	
29	6 pm		.6	
30	1145		.9	
31	1145		1.0	

Was the chlorine residual ever less than the required minimum residual of 0.2 mg/L? Yes No
 If yes, what was the longest time-period until the required level was restored? hours

<p>GWS Serving 3,300 or Fewer</p> <p>If yes, did you monitor every four hours until the residual returned to <u> </u> mg/L? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>Attach those results and submit them with this form.</p>	<p>GWS Serving More Than 3,300</p> <p>Did continuous monitoring equipment fail at any time this reporting month? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>Attach grab sample results and submit them with this form.</p>	<p>Date continuous monitoring equipment failed: <u> </u>/<u> </u>/<u> </u></p> <p>Date it was returned to service: <u> </u>/<u> </u>/<u> </u></p>
---	---	---

Printed Name: EDWARD BORTA Title: OWNER Operator Certification #:
 Signature: Phone #: (541) 846-7303 OR N/A
 Date: / / Small Groundwater System