State of Oregon Drinking Water Program Monthly Disinfection Report for Ground Water Systems

System Name OSU Rowing Center PWS ID# 4 1 41-95390								
Month/	Year 07	7/2022 Entry Po	int: Chart at Mixing Tank Requi		quired Minimum	ired Minimum Residual 2.00 mg/L		
Date	Time	Source(s) i	n use	Lowest free chlorine residual at entry point to distribution system (mg/L		Notes		
1	12p	Chart Recorder at m	nixing tank	2.94				
2	12p	"		2.82				
3	12p	"		2.58				
4	12p	"		2.55				
5	12p	"		2.52				
6	12p	"		2.25				
7	12p	11		2.52				
8	12p	11		2.43				
9	12p	11		2.55				
10	12p	"		2.43				
11	12p	11		2.58				
12	12p	"		2.43				
13	12p	"		2.49				
					treatment d	ak, system ran nonstop, rained,below compliance		
14	12p	"		0.00	3pm			
15	12p	11		0.00	discovered compliant 6	in am, system fixed and spm		
16	12p	"		2.58				
17	12p	"		2.76				
18	12p	11		2.49				
19	12p	11		2.55				
20	12p	11		2.67				
21	12p	"		1.74		g tank and pressure 4hrs non-compliant		
22	12p	11		2.43	, , J,			
23	12p	11		2.28				
24	12p	11		2.55				
25	12p	"		2.37				
26	12p	"		2.25				
27	12p	"		2.55				
28	12p	11		2.49				
29	12p	11		2.64				
30	12p	11		2.19				
31	12p	"		2.31				
Was the chlorine residual ever less than the required minimum residual of 2.00 mg/L? Yes No If yes, what was the longest time period until the required level was restored? 27 hours – If > 4 hours, Drinking Water Program to be								
	notified by end of next business day.							
GWS Serving 3,300 or Fewer GWS Serving More Than 3,300						300		
until the	e residual re		Did continuous monitoring equipment fail at any time this reporting month? Yes No Date continuous monitoring equipment failed:					
as required?			If yes, were grab samples collected every four hours until the					
Attach those results and submit them with this form.			continuous monitoring equipment was returned to service as required? Yes No Date it was returned to service:					
Attach grab sample results and submit them with this form.								
Printed Name: John Schneider			ıTitl	e: boatman	Operato	or Certification #:		

State of Oregon Drinking Water Program Monthly Disinfection Report for Ground Water Systems

Signature:	Phone #: (541) 231-4291	OR
Date: 08 / 09 / 2022		Small Groundwater System

December 19, 2012