

**State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems**

System Name Hanley Farm Living History Museum

PWS ID# 41 99571



Month/Year MAR /2022

Entry Point: contact tank hose bib

Required Minimum Residual 1.0 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	1330	New well	2.8	TG
2	0957	New well	1.9	TM
3	0918	New well	1.2	TM
4	1038	new well	2.0	TM
5	1146	new well	1.4	TM
6	1746	new well	2.0	TM
7	2030	new well	3.2	TG
8	0910	new well	3.0	TG
9	1150	new well	2.4	TM
10	1510	new well	1.6	TM
11	0855	new well	1.6	TM
12	1042	new well	1.85	TM
13	1645	new well	1.8	TG
14	1320	new well	2.0	TG
15	1725	new well	4.0 1.4	TG
16	1355	new well	1.0	TG
17	1108	new well	2.7	TM
18	8:45	new well	2.2	TM
19	2:19 PM	new well	2.0	TM
20	1700	new well	2.4	TG
21	0930	new well	2.4	TG
22	1400	new well	1.8	TG
23	0947	new well	1.2	TM
24	1151	new well	1.2	TM
25	9:07	new well	2.6	TM
26	1237	new well	3.4	TM
27	1500	new well	1.2	TG
28	1300	new well	1.4	TG
29	0845	new well	2.4	TG
30	1022	new well	1.0	TM
31	1022	new well	1.0	TM

Was the chlorine residual ever less than the required minimum residual of 1.0 mg/L? Yes No
 If yes, what was the longest time period until the required level was restored? _____ hours

GWS Serving 3,300 or Fewer

If yes, did you monitor every four hours until the residual returned to _____ mg/L?
 Attach those results and submit them with this form.

GWS Serving More Than 3,300

Did continuous monitoring equipment fail at any time this reporting month? Yes No
 If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service?
 Yes No
 Attach grab sample results and submit them with this form.

Date continuous monitoring equipment failed: / /
 Date it was returned to service: / /

Printed Name: Thom Gilsdorf

Title: project coordinator

Operator Certification #:

Signature: *Thom Gilsdorf*

Phone #: (541 601) 6203

OR

Date: 04/10/2022

Small Groundwater System

Email to *dwp.dmc@state.or.us*
bakerse@tadocounty.org