

**State of Oregon Drinking Water Program  
Monthly Disinfection Report for Ground Water Systems**

System Name Hanley Farm Living History Museum

PWS ID# 41 99571



Month/Year JUNE 2022

Entry Point: contact tank hose bib

Required Minimum Residual 1.0 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes	
1	1614	New well	2.0	TM	
2	1204	New well	1.2	TM	
3		New well	.		
4		new well	.		MISSSED
5	3:14	new well	1.6		TM
6	11:49	new well	2.2		TM
7	0835	new well	1.4	TG	
8	1120	new well	1.2	TM	
9	0402	new well	1.4	TM	
10	0947	new well	1.7	TM	
11	0248	new well	3.2	TM	
12	1210	new well	3.4	TG	
13	1545	new well	3.4	TG	
14	1045	new well	3.4	TG	
15	1013	new well	1.7	TM	
16	1637	new well	1.2	TM	
17	0920	new well	2.0	TM	
18	0940	new well	1.0	TM	
19	1110	new well	2.4	TM	
20	1550	new well	2.2	TG	
21	0843	new well	2.0	TM	
22	0945	new well	3.2	TG	
23	1143	new well	3.5	TM	
24	8:50	new well	<del>3.5</del> 3.2	TM	
25	1358	new well	3.0	TM	
26	1658	new well	2.8	TM	
27	1945	new well	2.6	TG	
28	1043	new well	3.0 <del>3.0</del>	TM	
29	934	new well	3.0	TM	
30	912	new well	2.5	TM	
31		new well			

Was the chlorine residual ever less than the required minimum residual of \_\_\_\_\_ mg/L?  Yes  No  
 If yes, what was the longest time period until the required level was restored? \_\_\_\_\_ hours

**GWS Serving 3,300 or Fewer**

If yes, did you monitor every four hours until the residual returned to \_\_\_\_\_ mg/L?  
 Attach those results and submit them with this form.

**GWS Serving More Than 3,300**

Did continuous monitoring equipment fail at any time this reporting month?  Yes  No  
 If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service?  
 Yes  No  
 Attach grab sample results and submit them with this form.

Date continuous monitoring equipment failed: \_\_\_\_\_  
 Date it was returned to service: \_\_\_\_\_

Printed Name: Thom Gilchrist TAM WOODRE

Title: project coordinator

Operator Certification #: \_\_\_\_\_

Signature: [Signature]

Phone #: (541 601) 6203

OR

Date: 7/11/2022

Small Groundwater System