

**State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems**

System Name Hanley Farm Living History Museum

PWS ID# 41 99571



Month/Year **SEPT** /2022

Entry Point: contact tank hose bib

Required Minimum Residual 1.0 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	1259	New well	2.4	TM
2	1138	New well	2.0	TM
3	11:00	New well	1	(TM)
4	12:26	new well	3	(TM)
5	0851	new well	2.5	TM
6	14"	new well	2.2	DL
7	442	new well	2.0	TM
8	1205	new well	1.0	TM
9	1016	new well	3.2	TM
10	1327	new well	1.2	TM
11	0852	new well	3.2	TM
12	11 ⁰⁰	new well	3.5	DL
13	15"	new well	3.0	DL
14	1011	new well	3.4	TM
15	1118	new well	2.8	TM
16	1116	new well	2.2	TM
17	1038	new well	1.4	TM
18	0907	new well	3.0	TM
19	17 ⁰⁰	new well	2.6	DL
20	1705	new well	2.5	TM
21	1108	new well	2.3	TM
22	1156	new well	2.3	TM
23	1037	new well	1.6	TM
24	1246	new well	2.4	(TM)
25	10:40	new well	2.6	(TM)
26	18 ⁰⁰	new well	2.4	DL
27	15 ⁰⁰	new well	2.8	DL
28	1222	new well	2.8	TM
29	1144	new well	2.0	TM
30	1120	new well	1.0	TM
31		new well		

Was the chlorine residual ever less than the required minimum residual of 1.0 mg/L? Yes No

If yes, what was the longest time period until the required level was restored? _____ hours

GWS Serving 3,300 or Fewer	GWS Serving More Than 3,300	
If yes, did you monitor every four hours until the residual returned to _____ mg/L? Attach those results and submit them with this form.	Did continuous monitoring equipment fail at any time this reporting month? <input type="checkbox"/> Yes <input type="checkbox"/> No If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service? <input type="checkbox"/> Yes <input type="checkbox"/> No Attach grab sample results and submit them with this form.	Date continuous monitoring equipment failed: / / Date it was returned to service: - / /

Printed Name: Thom Glendon TAM MOORE Title: project coordinator

Signature: TAM MOORE Phone #: (541 601) 6203

Date: 09/30/2022

Operator Certification #:

OR

Small Groundwater System