

**State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems**

System Name **Hanley Farm Living History Museum**

PWS ID# **95571**

Month/Year **Feb 1 2024** Entry Point: **Contact Tank hose bib**

Required Minimum Residual **1.0 mg/L**

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	0940		1.5	PL
2	1036		2.0	TM
3	1000		1.5	TM
4	1040		2.3	(PL)
5	MISSED			
6	0940		1.7	PL
7	0930		1.7	PL
8	1000		1.8	PL
9	1024		2.4	TM
10	1119		3.4	TM
11	1100		2.8	(PL)
12	1410		3.2	PL
13	0930		1.5	PL
14	1000		1.5	PL
15	1005		2.0	PL
16	0931		1.0	TM
17	1433		1.0	TM
18	1030		1.8	(PL)
19	1300		3.0	PL
20	0925		2.3	PL
21	0910		2.8	PL
22	1205		3.2	TM
23	1107		2.9	TM
24	1123		1.0	TM
25	1140		2.8	(PL)
26	MISSED			
27	1040		2.6	PL
28	1630		3.4	PL
29	1040		3.4	PL
30				
31				

Was the chlorine residual ever less than the required minimum residual of _____ mg/L? Yes No
 If yes, what was the longest time period until the required level was restored? _____ hours – If > 4 hours, Drinking Water Program to be notified by end of next business day.

<p>GWS Serving 3,300 or Fewer</p> <p>If yes, did you monitor every four hours until the residual returned to _____ mg/L as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>Attach those results and submit them with this form.</p>	<p>GWS Serving More Than 3,300</p> <p>Did continuous monitoring equipment fail at any time this reporting month? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>Attach grab sample results and submit them with this form.</p>	<p>Date continuous monitoring equipment failed: / /</p> <p>Date it was returned to service: / /</p>
--	--	---

Printed Name: Craig Akins Ted Moore Title: System Coordinator Operator Certification #: _____
 Signature: [Signature] Phone #: (541)951 2202 OR
 Date: 31/01/2024 Small Groundwater System

Return by 10th of following month by either email dwp_dmce@state.or.us; fax 971-673-0694; or mail to Drinking Water Services, PO Box 14350, Portland, OR 97293-0350.