

State of Oregon Drinking Water Program  
**Monthly Disinfection Report for Ground Water Systems**

System Name **Hanley Farm Living History Museum**

PWS ID# **95571**

Month/Year **Sept 1 2024** Entry Point: **Contact Tank hose bib**

Required Minimum Residual **1.0 mg/L**

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	1045		2.8	(Fu)
2	0818		3.2	TW
3	0900		3.4	P.W.
4	1030		3.4	P.W.
5	0930		3.4	P.W.
6	0912		3.4	FM
7	1145		1.0	(Fu)
8	1106		1.4	(Fu)
9	1110		1.6	FM
10	1005		3.4	P.W.
11	1215		3.4	P.W.
12	1200		3.4	P.W.
13	0959		3.4	FM
14	1017		1.0	FM
15	1040		1.3	(Fu)
16	1232		2.8	FM
17	1225		2.8	P.W.
18	1010		2.3	P.W.
19	0720		1.4	P.W.
20	1053		1.4	FM
21	0846		1.0	FM
22	0545 PM		2.0	(Fu)
23	1526		2.0	FM
24	1120		1.6	P.W.
25	1010		1.4	P.W.
26	1620		3.4	P.W.
27	1104		2.6	FM
28	1425		1.6	(Fu)
29	1527		1.0	FM
30	0947		1.0	FM
31				

Was the chlorine residual ever less than the required minimum residual of \_\_\_\_\_ mg/L?  Yes  No  
 If yes, what was the longest time period until the required level was restored? \_\_\_\_\_ hours - If > 4 hours, Drinking Water Program to be notified by end of next business day.

GWS Serving 3,300 or Fewer	GWS Serving More Than 3,300	
If yes, did you monitor every four hours until the residual returned to _____ mg/L as required? <input type="checkbox"/> Yes <input type="checkbox"/> No Attach those results and submit them with this form.	Did continuous monitoring equipment fail at any time this reporting month? <input type="checkbox"/> Yes <input type="checkbox"/> No If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? <input type="checkbox"/> Yes <input type="checkbox"/> No Attach grab sample results and submit them with this form.	Date continuous monitoring equipment failed: _____ / _____ / _____ Date it was returned to service: _____ / _____ / _____

Printed Name: **Greg Askins** *TAMMUNE*

Title: **farm manager** *Lowder*

Operator Certification #: \_\_\_\_\_

Signature: *Greg Askins*

Phone #: (541)951 2202

OR

Date: **9/30/2024**

Small Groundwater System

Return by 10<sup>th</sup> of following month by either email [dwp.dmce@state.or.us](mailto:dwp.dmce@state.or.us); fax 971-673-0694; or mail to Drinking Water Services, PO Box 14350, Portland, OR 97293-0350.