

**State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems**

System Name **Hanley Farm Living History Museum**

PWS ID# **4 1 99571**

Month/Year **JAN 2021**
~~Oct 2020~~

Entry Point: **contact tank hose bib**

Required Minimum Residual **1.0 mg/L**

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	1327	New well	3.0	iw
2	1546	New well	2.8	iw
3	1218	New well	2.6	iw
4	1338	new well	2.2	iw
5	1040	new well	1.4	TM
6	1040	new well	1.9	TM
7	1649	new well	2.2	iw
8	1257	new well	2.2	iw
9	1209	new well	2.0	iw
10	1327	new well	2.0	iw
11	1308	new well	2.0	iw
12	1133	new well	1.4	TM
13	1058	new well	2.0	TM
14	1422	new well	2.6	iw
15	1054	new well	3.0	iw
16	1548	new well	3.0	iw
17	1131	new well	3.4	iw
18	1403	new well	3.2	iw
19	1206	new well	2.6	TM
20	1224	new well	1.8	TM
21	1125	new well	2.8	iw
22	1043	new well	3.0	iw
23	1511	new well	3.0	iw
24	1156	new well	3.0	iw
25	1341	new well	3.0	iw
26	1424	new well	1.8	TM
27	1448	new well	1.4	TM
28	1024	new well	3.2	iw
29	1053	new well	3.2	iw
30	1224	new well	3.4	iw
31	1147	new well	3.4	iw

Was the chlorine residual ever less than the required minimum residual of _____ mg/L? Yes No
If yes, what was the longest time period until the required level was restored? _____ hours

GWS Serving 3,300 or Fewer

If yes, did you monitor every four hours until the residual returned to _____ mg/L?
Attach those results and submit them with this form.

GWS Serving More Than 3,300

Did continuous monitoring equipment fail at any time this reporting month? Yes No
If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service?
 Yes No
Attach grab sample results and submit them with this form.

Date continuous monitoring equipment failed: / /
Date it was returned to service: / /

Printed Name: **Tam Moore**

Title: **project coordinator**

Operator Certification #:

Signature: *Tam Moore*

Phone #: **(541 890 0992)**

OR

Date: **21 21 2021**

Small Groundwater System