## State of Oregon Drinking Water Program Monthly Disinfection Report for Ground Water Systems

System Name Hanley Farm Living History Museum PWS ID# 95571						
Month/Year / 20 LEntry Point: Contact Tank hose bib Required Minimum Residual 1.0 mg/L						
Date	Time	Source(s) ir		Lowest free chlorine residual at entry point to distribution system (mg/L)		Notes
1	1149	,		1.1	TM	
2	1142	·		1.2	TM	
3	1446			1.0	an	· ·
4	1253			1.4	CHO	
5	1500	1. 2.		2.4	DL	
6	1500			3.0	DL	
7	1115	0		2.9	TH	
8	11 10			2.9	The	
9	1035			1.0	Tiles	
10	1150		A 4	1.6	(fee)	
11	430			2,0	(EU)	)
12	1400			18	De	
13	1530			2.0	PL	
14	1517	Market .		1. 0	TIL	
15	1047	4		1,0	-na	
16	15-30			1.3	tw	1
17	1052		4.5	0	1	M
18	1529			1.7/	-/1	VI.
19	1100			7 . C.	a	
20	1700			1.8	70	
21	1142			1.4	Tu	1
22	100			2/2	+4	4
23	0937	1		7.2	TU	
24	1453			2,2	Red	
25	1030			1.4	Sol	
26	1540	,		7.2	And	7
27	14:00			30	19	al)
28	1224			1.4	Till	1
29	1042		1	2.2	TH	
30	1139	/		1.7	The	
31	1050	1, 1, 2, 1, 1, 1, 1, 1, 1, 1, 1, 1, 1, 1, 1, 1,		1,4	(A)	
Was the chlorine residual ever less than the required minimum residual of mg/L? Yes No						
If yes, what was the longest time period until the required level was restored? hours – If > 4 hours, Drinking Water Program to be notified by end of next business day.						
GWS Serving 3,300 or Fewer GWS Serving More Than 3,300						
If yes, did you monitor every four hours   Until the residual returned to   In yes, did you monitor every four hours   Until the residual returned to   In yes, did you monitor every four hours   In						
as req		Yes No				
		and cubmit them with	If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as			
Attach those results and submit them with this form.			required? Yes No service:			
	inge.		Attach grab sample results and submit them with this form.			
Printed Name: Tam Moore Title: project coordinator Operator Certification #:						
Signature: Phone #: (541)890-0992 OR						
Date: 1/3/222						

Return by 10<sup>th</sup> of following month by either email <u>dwp.dmce@state.or.us</u>; fax 971-673-0694; or mail to Drinking Water Services, PO Box 14350, Portland, OR 97293-0350.