

OHA - Drinking Water Services -Turbidity Monitoring Report Form
Conventional or Direct Filtration

County: **Benton**
 Month/Year: **Dec-22**

System Name:	Adair Village		1-00003				WTP : TP -
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1							
2			0.07	0.06	0.06		0.07
3							
4							
5			0.07	0.06	0.07		0.07
6							
7			0.07	0.07	0.07		0.07
8							
9			0.07	0.06	0.06		0.07
10							
11							
12			0.07	0.07	0.07		0.07
13							
14			0.07	0.06	0.06		0.07
15							
16			0.07	0.07	0.06		0.07
17							
18							
19			0.06	0.06	0.06		0.06
20							
21			0.07	0.07	0.07		0.07
22							
23			0.07	0.06	0.06		0.07
24							
25							
26			0.06	0.06	0.06		0.06
27							
28			0.06	0.07	0.07		0.07
29							
30			0.06	0.06	0.06		0.06
31							

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of 4-hour turbidity readings ≤ 0.3 NTU? <input checked="" type="radio"/> Yes <input type="radio"/> No	CT's met everyday? (see back) <input checked="" type="radio"/> Yes <input type="radio"/> No	All Cl2 residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes <input type="radio"/> No
All 4-hour turbidity readings ≤ 1 NTU? <input checked="" type="radio"/> Yes <input type="radio"/> No		
All turbidity readings < IFE ² triggers <input checked="" type="radio"/> Yes <input type="radio"/> No		

Notes:	PRINTED NAME: Matt Lydon	
	SIGNATURE: <i>Matt Lydon</i>	DATE: 1/9/23
	503-302-4317	CERT #: 8763

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may not correspond to continuous readings' maximum. ² IFE = Individ. Filter Effl. (333-061-0040(1)(d)(B&C))

OHA - Drinking Water Program - Surface Water Quality Data Form

WTP - :

System Name:	Adair Village	ID#: 41 00003	Month/Year:	Disinfection <i>Giardia</i> Log Inactive:	1
--------------	---------------	---------------	-------------	---	---

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1								
2	1.09	47	51.2	12.4	7.34	37.5	YES	665
3								
4								
5	1.11	47	52.2	12.2	7.32	37.8	YES	665
6								
7	1.14	47	53.6	11.8	7.39	39.9	YES	663
8								
9	1.07	47	50.3	11.8	7.44	40.3	YES	657
10								
11								
12	1.04	47	48.9	11.4	7.40	40.7	YES	660
13								
14	1.1	47	51.7	10.8	7.37	42.1	YES	668
15								
16	1.14	47	53.6	10.4	7.39	43.8	YES	653
17								
18								
19	1.08	47	50.8	10.4	7.27	41.7	YES	666
20								
21	1.11	47	52.2	9.8	7.33	44.4	YES	663
22								
23	1.15	47	54.1	9.4	7.35	46.1	YES	654
24								
25								
26	1.05	47	49.4	9.8	7.45	46.0	YES	648
27								
28	1.07	47	50.3	9.4	7.37	46.1	YES	665
29								
30	1.03	47	48.4	9.8	7.35	44.3	YES	654
31								

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:
dwp_dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350