

OHA - Drinking Water Program - Turbidity Monitoring Report Form

Conventional or Direct Filtration

System Name: ALBANY, CITY OF ID#: OR4100012 WTP-:WTP-A (Vine Street)	County: Linn & Benton	Month/Year: 1 / 2026
---	----------------------------------	-----------------------------

Day	Max IFE , 1st 4 hours, NTU	Time	Max IFE , 2nd 4 hours, NTU	Time	Max IFE , 3rd 4 hours, NTU	Time	Max IFE , 4th 4 hours, NTU	Time	Max IFE , 5th 4 hours, NTU	Time	Max IFE , 6th 4 hours, NTU	Time	Highest IFE reading of the day, NTU
01	0.07	1:38 PM	0.05	2:29 PM	Plant Offline		Plant Offline		Plant Offline		Plant Offline		0.07
02	0.05	12:19 PM	0.05	2:19 PM	Plant Offline		Plant Offline		Plant Offline		Plant Offline		0.05
03	0.08	12:47 PM	0.06	2:32 PM	Plant Offline		Plant Offline		Plant Offline		Plant Offline		0.08
04	0.07	12:31 PM	Plant Offline		Plant Offline		Plant Offline		Plant Offline		Plant Offline		0.07
05	0.07	10:52 AM	Plant Offline		Plant Offline		Plant Offline		Plant Offline		Plant Offline		0.07
06	0.06	11:28 AM	Plant Offline		Plant Offline		Plant Offline		Plant Offline		Plant Offline		0.06
07	0.05	10:18 AM	0.05	11:48 AM	Plant Offline		Plant Offline		Plant Offline		Plant Offline		0.05
08	0.05	11:06 AM	0.05	1:51 PM	Plant Offline		Plant Offline		Plant Offline		Plant Offline		0.05
09	0.09	2:24 PM	Plant Offline		Plant Offline		Plant Offline		Plant Offline		Plant Offline		0.09
10	0.08	12:14 PM	0.05	2:15 PM	Plant Offline		Plant Offline		Plant Offline		Plant Offline		0.08
11	0.08	12:40 PM	Plant Offline		Plant Offline		Plant Offline		Plant Offline		Plant Offline		0.08
12	0.05	12:07 PM	Plant Offline		Plant Offline		Plant Offline		Plant Offline		Plant Offline		0.05
13	0.05	11:38 AM	Plant Offline		Plant Offline		Plant Offline		Plant Offline		Plant Offline		0.05
14	0.06	10:03 AM	0.06	12:58 PM	0.07	6:33 PM	0.06	7:03 PM	Plant Offline		Plant Offline		0.07
15	0.05	9:54 AM	0.07	12:25 PM	Plant Offline		Plant Offline		Plant Offline		Plant Offline		0.07
16	0.07	12:19 PM	0.06	12:49 PM	Plant Offline		Plant Offline		Plant Offline		Plant Offline		0.07
17	0.07	10:26 AM	Plant Offline		Plant Offline		Plant Offline		Plant Offline		Plant Offline		0.07
18	Plant Offline		Plant Offline		Plant Offline		Plant Offline		Plant Offline		Plant Offline		
19	Plant Offline		Plant Offline		Plant Offline		Plant Offline		Plant Offline		Plant Offline		
20	Plant Offline		Plant Offline		Plant Offline		Plant Offline		Plant Offline		Plant Offline		
21	0.10	10:03 AM	0.05	1:48 PM	Plant Offline		Plant Offline		Plant Offline		Plant Offline		0.10
22	0.06	10:37 AM	0.05	2:22 PM	Plant Offline		Plant Offline		Plant Offline		Plant Offline		0.06
23	0.08	12:19 PM	0.05	2:01 PM	Plant Offline		Plant Offline		Plant Offline		Plant Offline		0.08
24	0.08	12:54 PM	0.05	3:05 PM	Plant Offline		Plant Offline		Plant Offline		Plant Offline		0.08
25	Plant Offline		Plant Offline		Plant Offline		Plant Offline		Plant Offline		Plant Offline		
26	0.07	11:14 AM	Plant Offline		Plant Offline		Plant Offline		Plant Offline		Plant Offline		0.07
27	0.05	11:29 AM	Plant Offline		Plant Offline		Plant Offline		Plant Offline		Plant Offline		0.05
28	0.06	10:31 AM	Plant Offline		Plant Offline		Plant Offline		Plant Offline		Plant Offline		0.06
29	0.06	12:17 PM	0.05	1:41 PM	Plant Offline		Plant Offline		Plant Offline		Plant Offline		0.06
30	0.07	1:37 PM	0.06	2:07 PM	Plant Offline		Plant Offline		Plant Offline		Plant Offline		0.07
31	0.05	12:30 PM	Plant Offline		Plant Offline		Plant Offline		Plant Offline		Plant Offline		0.05

<p align="center">Conventional Filtration - Using LT2 Toolbox CFE/IFE Option for Additional 1.0-log Credit</p> <p>95% of the 15-minute increment IFE turbidity readings <= 0.15? No IFE turbidity exceeded 0.3 NTU in two consecutive measurements? 95% of maximum IFE readings <= 0.15? All turbidity readings < IFE triggers?(1)</p> <p>Notes:</p>	<p align="center">Monthly Summary (Answer Yes or No)</p> <table border="1" style="width:100%; border-collapse: collapse;"> <tr> <td style="width:50%; text-align: center;"> CT's met everyday? <input checked="" type="radio"/> Yes / <input type="radio"/> No </td> <td style="width:50%; text-align: center;"> All CL2 residuals at entry point >= 0.2 mg/?l <input checked="" type="radio"/> Yes / <input type="radio"/> No </td> </tr> </table> <p>PRINTED NAME: <i>Chris Germond</i> SIGNATURE: <i>Chris Germond</i> PHONE #: <i>541-764-2309</i></p>	CT's met everyday? <input checked="" type="radio"/> Yes / <input type="radio"/> No	All CL2 residuals at entry point >= 0.2 mg/?l <input checked="" type="radio"/> Yes / <input type="radio"/> No
CT's met everyday? <input checked="" type="radio"/> Yes / <input type="radio"/> No	All CL2 residuals at entry point >= 0.2 mg/?l <input checked="" type="radio"/> Yes / <input type="radio"/> No		

(1) IFE = Individual Filter Effluent (OAR 333-061-0040(1)(d))

OHA - Drinking Water Program - Surface Water Quality Data Form

System Name: ALBANY, CITY OF ID #: OR4100012 WTP:-WTP-A	Month/Year: 1/2026	Required Log Inactivation: 0.5
---	--------------------	--------------------------------

Date / Time	Minimum CL2 Residual @ 1st User (C) (1)	Contact Time (T)	Actual CT	Temp.	pH	Reqd. CT	CT Met? (1)	Peak Hourly Demand Flow (2)
	[ppm or mg/L]	[minutes]	C x T	[°C]		Use tables	Yes / No	[GPM]
01/01/26	1.14	114	130	7.3	8.28	37	YES	2755
01/02/26	1.22	146	178	7.6	8.20	36	YES	1713
01/03/26	1.24	174	216	8.2	8.19	34	YES	2659
01/04/26	Plant Off							
01/05/26	Plant Off							
01/06/26	1.01	267	270	9.1	8.03	30	YES	1652
01/07/26	1.15	66	76	8.4	8.07	32	YES	3802
01/08/26	1.11	221	245	8.0	8.08	33	YES	1630
01/09/26	1.03	102	105	7.5	8.08	34	YES	2592
01/10/26	1.14	143	163	7.6	8.12	34	YES	2762
01/11/26	Plant Off							
01/12/26	1.02	135	138	7.9	8.20	34	YES	2037
01/13/26	1.15	80	92	7.7	8.24	36	YES	2591
01/14/26	1.30	81	105	6.9	8.27	39	YES	7407
01/15/26	1.27	122	155	7.0	8.24	38	YES	4690
01/16/26	1.18	185	218	6.8	8.26	38	YES	2838
01/17/26	1.04	135	140	6.6	8.24	38	YES	2675
01/18/26	Plant Off							
01/19/26	0.84	62	52	8.5	8.23	32	YES	2329
01/20/26	0.84	108	91	8.6	8.23	32	YES	2808
01/21/26	0.78	55	43	7.1	8.25	36	YES	2121
01/22/26	1.03	142	146	5.7	8.34	42	YES	2725
01/23/26	1.15	250	288	5.6	8.35	43	YES	1589
01/24/26	1.10	220	242	5.7	8.31	42	YES	1563
01/25/26	Plant Off							
01/26/26	1.02	130	133	5.6	8.25	41	YES	2801
01/27/26	Plant Off							
01/28/26	Plant Off							
01/29/26	1.12	156	175	6.2	8.31	41	YES	2730
01/30/26	1.08	254	274	7.1	8.22	37	YES	1564
01/31/26	1.08	131	141	7.7	8.22	35	YES	1891

Signature: <u>Chris Germond</u>	Date: <u>2/7/26</u>
Print Name: <u>Chris Germond</u>	Cert #: <u>T-08682</u>

(1) If Cl2 at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.
 (2) Prior to 12/2014 Peak Instantaneous Demand Flow is used.



Vine St. IFE Turbidity Compliance

January 2026

Combined IFE Measurement Results

- 95% of the 15-minute increment IFE turbidity readings ≤ 0.15 NTU?..... **Yes**
- No IFE turbidity exceeded 0.3 NTU in two consecutive measurements?..... **Yes**
- 95% of Maximum IFE readings ≤ 0.15 NTU?..... **Yes**

Individual Filter Measurement Results

Filter Number	Percent of Readings ≤ 0.15 NTU	Two Consecutive Readings > 0.3 NTU?
1	100.0	No
2	100.0	No
3	100.0	No
4	100.0	No
5	100.0	No
6	100.0	No
7	100.0	No
8	100.0	No
9	100.0	No
10	100.0	No

IFE Measurements > 0.15 NTU

Time	Filter Number	Turbidity (NTU)	Four Hour Time Block	Second Consecutive Measurement > 0.3 NTU?