

**OHA - Drinking Water Program - Turbidity Monitoring Report Form**

**Conventional or Direct Filtration**

<b>System Name: ALBANY, CITY OF ID#: OR4100012 WTP:-WTP-A (Vine Street)</b>	<b>County: Linn &amp; Benton</b>	<b>Month/Year: 2 / 2026</b>
---	----------------------------------	-----------------------------

Day	Max IFE , 1st 4 hours, NTU	Time	Max IFE , 2nd 4 hours, NTU	Time	Max IFE , 3rd 4 hours, NTU	Time	Max IFE , 4th 4 hours, NTU	Time	Max IFE , 5th 4 hours, NTU	Time	Max IFE , 6th 4 hours, NTU	Time	Highest IFE reading of the day, NTU
01	Plant Offline		Plant Offline		Plant Offline		Plant Offline		Plant Offline		Plant Offline		
02	0.06	10:51 AM	Plant Offline		Plant Offline		Plant Offline		Plant Offline		Plant Offline		0.06
03	0.06	10:17 AM	Plant Offline		Plant Offline		Plant Offline		Plant Offline		Plant Offline		0.06
04	0.08	12:11 PM	0.05	2:15 PM	Plant Offline		Plant Offline		Plant Offline		Plant Offline		0.08
05	0.06	10:48 AM	0.05	2:33 PM	Plant Offline		Plant Offline		Plant Offline		Plant Offline		0.06
06	0.07	2:03 PM	Plant Offline		Plant Offline		Plant Offline		Plant Offline		Plant Offline		0.07
07	Plant Offline		Plant Offline		Plant Offline		Plant Offline		Plant Offline		Plant Offline		
08	Plant Offline		Plant Offline		Plant Offline		Plant Offline		Plant Offline		Plant Offline		
09	0.08	12:45 PM	Plant Offline		Plant Offline		Plant Offline		Plant Offline		Plant Offline		0.08
10	0.06	9:00 AM	Plant Offline		Plant Offline		Plant Offline		Plant Offline		Plant Offline		0.06
11	0.08	2:04 PM	Plant Offline		Plant Offline		Plant Offline		Plant Offline		Plant Offline		0.08
12	0.07	10:32 AM	0.06	1:02 PM	Plant Offline		Plant Offline		Plant Offline		Plant Offline		0.07
13	0.08	1:57 PM	Plant Offline		Plant Offline		Plant Offline		Plant Offline		Plant Offline		0.08
14	0.06	11:05 AM	0.06	2:05 PM	Plant Offline		Plant Offline		Plant Offline		Plant Offline		0.06
15	Plant Offline		Plant Offline		Plant Offline		Plant Offline		Plant Offline		Plant Offline		
16	0.07	11:19 AM	Plant Offline		Plant Offline		Plant Offline		Plant Offline		Plant Offline		0.07
17	0.08	1:32 PM	Plant Offline		Plant Offline		Plant Offline		Plant Offline		Plant Offline		0.08
18	0.07	12:23 PM	Plant Offline		Plant Offline		Plant Offline		Plant Offline		Plant Offline		0.07
19	0.07	1:04 PM	0.06	3:00 PM	Plant Offline		Plant Offline		Plant Offline		Plant Offline		0.07
20	0.07	2:19 PM	0.06	2:49 PM	Plant Offline		Plant Offline		Plant Offline		Plant Offline		0.07
21	0.06	11:07 AM	Plant Offline		Plant Offline		Plant Offline		Plant Offline		Plant Offline		0.06
22	Plant Offline		Plant Offline		Plant Offline		Plant Offline		Plant Offline		Plant Offline		
23	0.07	11:28 AM	Plant Offline		Plant Offline		Plant Offline		Plant Offline		Plant Offline		0.07
24	0.07	10:18 AM	Plant Offline		Plant Offline		Plant Offline		Plant Offline		Plant Offline		0.07
25	0.07	9:43 AM	0.06	1:13 PM	Plant Offline		Plant Offline		Plant Offline		Plant Offline		0.07
26	0.07	10:27 AM	0.06	2:12 PM	Plant Offline		Plant Offline		Plant Offline		Plant Offline		0.07
27	0.07	9:00 AM	Plant Offline		Plant Offline		Plant Offline		Plant Offline		Plant Offline		0.07
28	0.06	10:42 AM	Plant Offline		Plant Offline		Plant Offline		Plant Offline		Plant Offline		0.06

<p><b>Conventional Filtration - Using LT2 Toolbox CFE/IFE Option for Additional 1.0-log Credit</b></p> <p>95% of the 15-minute increment IFE turbidity readings &lt;= 0.15? <span style="float:right;">Yes / No</span></p> <p>No IFE turbidity exceeded 0.3 NTU in two consecutive measurements? <span style="float:right;">Yes / No</span></p> <p>95% of maximum IFE readings &lt;= 0.15? <span style="float:right;">Yes / No</span></p> <p>All turbidity readings &lt; IFE triggers?(1) <span style="float:right;">Yes / No</span></p> <p><b>Notes:</b></p>	<p align="center"><b>Monthly Summary (Answer Yes or No)</b></p> <table border="1" style="width:100%; border-collapse: collapse;"> <tr> <td style="width:50%;">CT's met everyday? <span style="float:right;">Yes / No</span></td> <td style="width:50%;">All CL2 residuals at entry point &gt;= 0.2 mg/?l <span style="float:right;">Yes / No</span></td> </tr> </table> <p><b>PRINTED NAME:</b> <i>Chris Germond</i></p> <p><b>SIGNATURE:</b> <i>Chris Germond</i></p> <p><b>PHONE #:</b> <i>541-204-2309</i></p>	CT's met everyday? <span style="float:right;">Yes / No</span>	All CL2 residuals at entry point >= 0.2 mg/?l <span style="float:right;">Yes / No</span>
CT's met everyday? <span style="float:right;">Yes / No</span>	All CL2 residuals at entry point >= 0.2 mg/?l <span style="float:right;">Yes / No</span>		

(1) IFE = Individual Filter Effluent (OAR 333-061-0040(1)(d))

## OHA - Drinking Water Program - Surface Water Quality Data Form

System Name: ALBANY, CITY OF ID #: OR4100012 WTP:-WTP-A	Month/Year: 2/2026	Required Log Inactivation: 0.5
---	--------------------	--------------------------------

Date / Time	Minimum CL2 Residual @ 1st User (C) (1)	Contact Time (T)	Actual CT	Temp.	pH	Reqd. CT	CT Met? (1)	Peak Hourly Demand Flow (2)
	[ppm or mg/L]	[minutes]	C x T	[°C]		Use tables	Yes / No	[GPM]
02/01/26	Plant Off							
02/02/26	0.96	121	116	8.2	8.21	33	YES	2674
02/03/26	Plant Off							
02/04/26	1.11	244	271	8.1	8.25	35	YES	1593
02/05/26	1.07	105	112	8.1	8.18	34	YES	2598
02/06/26	1.16	155	180	7.8	8.20	35	YES	2653
02/07/26	1.00	83	83	8.5	8.22	33	YES	2587
02/08/26	0.90	89	80	9.0	8.20	31	YES	2364
02/09/26	0.96	204	196	8.5	8.19	32	YES	1621
02/10/26	Plant Off							
02/11/26	0.99	100	99	8.6	8.37	34	YES	2639
02/12/26	1.06	144	153	7.8	8.03	33	YES	2680
02/13/26	1.17	148	173	7.6	8.11	34	YES	2614
02/14/26	1.11	112	124	7.9	8.16	34	YES	2639
02/15/26	Plant Off							
02/16/26	Plant Off							
02/17/26	0.89	66	59	8.3	8.10	32	YES	2628
02/18/26	1.05	107	112	7.6	8.05	33	YES	2650
02/19/26	1.23	119	146	7.3	8.11	35	YES	2626
02/20/26	1.17	125	146	7.2	8.11	35	YES	2506
02/21/26	1.16	140	162	7.1	8.11	35	YES	2742
02/22/26	Plant Off							
02/23/26	1.05	113	119	8.2	8.08	32	YES	2705
02/24/26	0.96	113	108	8.6	7.97	30	YES	2684
02/25/26	1.05	74	78	8.7	7.92	29	YES	5799
02/26/26	1.09	144	157	9.1	7.98	29	YES	2690
02/27/26	0.95	199	189	8.6	8.08	31	YES	1050
02/28/26	1.23	171	210	8.2	8.25	35	YES	2740

---

<b>Signature:</b> <u>Chris Germond</u>	<b>Date:</b> <u>3/4/26</u>
<b>Print Name:</b> <u>Chris Germond</u>	<b>Cert #:</b> <u>T-08682</u>

---

(1) If Cl2 at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.  
 (2) Prior to 12/2014 Peak Instantaneous Demand Flow is used.



# Vine St. IFE Turbidity Compliance

February 2026

## Combined IFE Measurement Results

- 95% of the 15-minute increment IFE turbidity readings  $\leq$  0.15 NTU?..... **Yes**
- No IFE turbidity exceeded 0.3 NTU in two consecutive measurements?..... **Yes**
- 95% of Maximum IFE readings  $\leq$  0.15 NTU?..... **Yes**

## Individual Filter Measurement Results

Filter Number	Percent of Readings $\leq$ 0.15 NTU	Two Consecutive Readings $>$ 0.3 NTU?
1	100.0	No
2	100.0	No
3	100.0	No
4	100.0	No
5	100.0	No
6	100.0	No
7	100.0	No
8	100.0	No
9	100.0	No
10	100.0	No

## IFE Measurements $>$ 0.15 NTU

Time	Filter Number	Turbidity (NTU)	Four Hour Time Block	Second Consecutive Measurement $>$ 0.3 NTU?
------	---------------	-----------------	----------------------	---