

**OHA - Drinking Water Program - Turbidity Monitoring Report Form    County: Linn**  
**Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems**

**System Name: ALBANY, CITY OF    ID #: OR4100012    WTP:-WTP-B**

**Month/Year: 3/2021**

DAY	12 AM	4 AM	8 AM	NOON	4 PM	8 PM	Highest Reading of the Day (1)
	[NTU]	[NTU]	[NTU]	[NTU]	[NTU]	[NTU]	[NTU]
1	0.01	0.01	0.01	0.01	0.01	0.01	0.01
2	0.01	0.01	0.01	0.01	0.01	0.01	0.01
3	0.01	0.01	0.01	0.01	0.02	0.01	0.02
4	0.01	0.01	0.01	0.01	0.01	0.01	0.01
5	0.01	0.01	0.01	0.01	0.01	0.01	0.01
6	0.01	0.01	0.01	0.01	0.01	0.01	0.01
7	0.01	0.01	0.01	0.01	0.01	0.01	0.01
8	0.01	0.01	0.01	0.01	0.01	0.01	0.01
9	0.01	0.01	0.01	0.01	0.01	0.01	0.01
10	0.01	0.01	0.01	0.01	0.01	0.01	0.01
11	0.01	0.01	0.01	0.01	0.01	0.01	0.01
12	0.01	0.01	0.01	0.01	0.01	0.01	0.01
13	0.01	0.01	0.01	0.01	0.00	0.01	0.01
14	0.01	0.01	0.01	0.01	0.01	0.01	0.01
15	0.01	0.01	0.01	0.01	0.01	0.01	0.01
16	0.01	0.01	0.01	0.01	0.01	0.01	0.01
17	0.01	0.01	0.01	0.01	0.01	0.01	0.01
18	0.01	0.01	0.01	0.01	0.01	0.01	0.01
19	0.01	0.01	0.01	0.01	0.01	0.01	0.01
20	0.01	0.01	0.01	0.01	0.01	0.01	0.01
21	0.01	0.01	0.01	0.01	0.01	0.01	0.01
22	0.01	0.01	0.01	0.01	0.01	0.01	0.01
23	0.01	0.01	0.01	0.01	0.01	0.01	0.01
24	0.01	0.01	0.01	0.01	0.01	0.01	0.01
25	0.01	0.01	0.01	0.01	0.01	0.01	0.01
26	0.01	0.01	0.01	0.01	0.01	0.01	0.01
27	0.01	0.01	0.01	0.01	0.01	0.01	0.01
28	0.01	0.01	0.01	0.01	0.01	0.01	0.01
29	0.01	0.01	0.01	0.01	0.01	0.01	0.01
30	0.01	0.01	0.01	0.01	0.01	0.01	0.01
31	0.01	0.01	0.01	0.01	0.01	0.01	0.01


Membrane Filtration	Monthly Summary (Answer Yes or No)	
95% of turbidity readings <= 1 NTU? (2) <input checked="" type="radio"/> Yes / No	CT's met everyday? <input checked="" type="radio"/> Yes / No	All CL2 residuals at entry point >= 0.2 mg/l? <input checked="" type="radio"/> Yes / No
All daily turbidity readings <= 5 NTU? <input checked="" type="radio"/> Yes / No		
<b>Notes:</b>	PRINTED NAME: <i>Chuck Leffler</i>	
	SIGNATURE: <i>[Signature]</i>	DATE: <i>4-2-21</i>
	PHONE #: <i>541-990-1907</i>	CERT #: <i>T-7158 FE</i>

(1) Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. (2) Filtered systems only.

## OHA - Drinking Water Program - Surface Water Quality Data Form

**System Name: ALBANY, CITY OF ID #: OR4100012 WTP:-WTP-B**      **Month/Year: 3/2021**

Date / Time	Minimum CL2 Residual @ 1st User (C) (1)	Contact Time (T)	Actual CT	Temp.	pH	Reqd. CT	CT Met? (1)	Peak Hourly Demand Flow (2)
	[ppm or mg/L]	[minutes]	C x T	[°C]		Use tables	Yes / No	[GPM]
1	1.09	259.8	283.2	5.3	8.33	43.2	Y	5,820
2	1.14	302.1	344.4	5.9	8.17	39.4	Y	4,771
3	1.06	265.8	281.7	5.6	8.12	39.0	Y	5,433
4	1.08	277.4	299.6	5.5	8.20	40.7	Y	4,573
5	1.05	338.1	355.0	5.2	8.19	41.0	Y	4,455
6	1.00	250.2	250.2	5.2	8.29	42.4	Y	4,937
7	0.95	268.6	255.2	6.0	8.27	39.5	Y	5,581
8	1.11	287.9	319.6	5.4	8.27	42.0	Y	4,716
9	1.11	266.4	295.7	5.3	8.26	42.2	Y	5,602
10	1.07	249.4	266.9	5.6	8.24	40.8	Y	5,503
11	1.03	281.4	289.8	5.1	8.33	43.4	Y	5,195
12	1.04	288.7	300.2	5.4	8.42	44.1	Y	4,619
13	1.04	272.4	283.3	5.5	8.40	43.4	Y	5,289
14	1.04	291.3	303.0	6.3	8.38	40.8	Y	4,569
15	1.08	245.9	265.6	5.2	8.28	42.7	Y	6,107
16	1.02	284.3	290.0	5.2	8.45	45.2	Y	4,691
17	1.00	257.4	257.4	5.5	8.48	44.7	Y	5,824
18	1.06	263.6	279.4	6.2	8.46	42.3	Y	4,707
19	1.12	283.3	317.3	6.0	8.27	40.5	Y	5,242
20	1.11	279.9	310.7	6.0	10.17	82.1	Y	4,609
21	1.11	276.3	306.7	6.1	8.43	42.5	Y	5,209
22	0.94	288.8	271.5	6.0	8.47	42.6	Y	4,636
23	0.93	246.2	229.0	5.6	8.43	43.0	Y	5,816
24	0.95	244.0	231.8	5.5	8.46	44.0	Y	5,241
25	1.09	260.1	283.5	5.5	8.34	42.8	Y	4,676
26	1.06	240.7	255.1	5.5	8.38	43.1	Y	5,634
27	1.06	279.4	296.2	6.3	8.48	42.3	Y	5,020
28	1.07	268.3	287.1	6.8	8.45	40.7	Y	4,645
29	1.10	242.7	267.0	6.2	8.27	39.8	Y	6,143
30	1.05	294.9	309.6	5.4	8.40	43.8	Y	4,688
31	1.03	225.8	232.6	6.1	8.50	43.0	Y	4,743

Signature:   
 Print Name: Chuck Leffler

Date: 4-2-21  
 Cert #: T-7158 FE

(1) If Cl2 at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.  
 (2) Prior to 11/2014, Peak Instantaneous Demand Flow is used.



# Department of Human Services - Drinking Water Section

## Membrane Integrity Report Form

Public Water System Name: Albany

PWS ID#: 41 00012 B

Month/Year:

3/ 2021

Albany/Millersburg Water Plant

Date	Membrane 1	Membrane 2	Membrane 3	Membrane 4
03/01/21	Pass	Pass	Pass	Pass
03/02/21	Pass	Pass	Pass	Pass
03/03/21	Pass	Pass	Pass	Pass
03/04/21	Pass	Pass	Pass	Pass
03/05/21	Pass	Pass	Pass	Pass
03/06/21	Pass	Pass	Pass	Pass
03/07/21	Pass	Pass	Pass	Pass
03/08/21	Pass	Pass	Pass	Pass
03/09/21	Pass	Pass	Pass	Pass
03/10/21	Pass	Pass	Pass	Pass
03/11/21	Pass	Pass	Pass	Pass
03/12/21	Pass	Pass	Pass	Pass
03/13/21	Pass	Pass	Pass	Pass
03/14/21	Pass	Pass	Pass	Pass
03/15/21	Pass	Pass	Pass	Pass
03/16/21	Pass	Pass	Pass	Pass
03/17/21	Pass	Pass	Pass	Pass
03/18/21	Pass	Pass	Pass	Pass
03/19/21	Pass	Pass	Pass	Pass
03/20/21	Pass	Pass	Pass	Pass
03/21/21	Pass	Pass	Pass	Pass
03/22/21	Pass	Pass	Pass	Pass
03/23/21	Pass	Pass	Pass	Pass
03/24/21	Pass	Pass	Pass	Pass
03/25/21	Pass	Pass	Pass	Pass
03/26/21	Pass	Pass	Pass	Pass
03/27/21	Pass	Pass	Pass	Pass
03/28/21	Pass	Pass	Pass	Pass
03/29/21	Pass	Pass	Pass	Pass
03/30/21	Pass	Pass	Pass	Pass
03/31/21	Pass	Pass	Pass	Pass

Signature: \_\_\_\_\_



Date: \_\_\_\_\_

4-2-21

Print Name: \_\_\_\_\_

Chuck Leffler

Cert. #: \_\_\_\_\_

T-7158 FE