

**OHA - Drinking Water Program - Turbidity Monitoring Report Form    County: Linn**  
**Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems**

**System Name: ALBANY, CITY OF    ID #: OR4100012    WTP:-WTP-B**

**Month/Year: 4/2021**

DAY	12 AM	4 AM	8 AM	NOON	4 PM	8 PM	Highest Reading of the Day (1)
	[NTU]	[NTU]	[NTU]	[NTU]	[NTU]	[NTU]	[NTU]
1	0.01	0.01	0.01	0.01	0.01	0.01	0.01
2	0.01	0.01	0.01	0.01	0.01	0.01	0.01
3	0.01	0.01	0.01	0.01	0.01	0.01	0.01
4	0.01	0.01	0.01	0.01	0.01	0.01	0.01
5	0.01	0.01	0.01	0.01	0.01	0.01	0.01
6	0.01	0.01	0.01	0.01	0.01	0.01	0.01
7	0.01	0.01	0.01	0.01	0.01	0.01	0.01
8	0.01	0.01	0.01	0.01	0.01	0.01	0.01
9	0.01	0.01	0.01	0.01	0.01	0.01	0.01
10	0.01	0.01	0.01	0.01	0.01	0.01	0.01
11	0.01	0.01	0.01	0.01	0.01	0.01	0.01
12	0.01	0.01	0.01	0.01	0.01	0.01	0.01
13	0.01	0.01	0.01	0.01	0.01	0.01	0.01
14	0.01	0.01	0.01	0.01	0.01	0.01	0.01
15	0.01	0.01	0.01	0.01	0.01	0.01	0.01
16	0.01	0.01	0.01	0.01	0.01	0.01	0.01
17	0.01	0.01	0.01	0.01	0.02	0.01	0.02
18	0.01	0.01	0.01	0.01	0.01	0.01	0.01
19	0.01	0.01	0.01	0.01	0.01	0.01	0.01
20	0.01	0.01	0.01	0.01	0.01	0.01	0.01
21	0.01	0.03	0.01	0.01	0.01	0.01	0.03
22	0.01	0.01	0.01	0.01	0.01	0.01	0.01
23	0.01	0.01	0.01	0.01	0.01	0.01	0.01
24	0.01	0.01	0.01	0.01	0.01	0.01	0.01
25	0.01	0.01	0.02	0.01	0.01	0.01	0.02
26	0.01	0.01	0.01	0.01	0.01	0.01	0.01
27	0.01	0.01	0.01	0.01	0.01	0.01	0.01
28	0.01	0.01	0.01	0.01	0.01	0.01	0.01
29	0.01	0.01	0.01	0.01	0.01	0.01	0.01
30	0.01	0.01	0.01	0.01	0.01	0.01	0.01

<b>Membrane Filtration</b>		<b>Monthly Summary (Answer Yes or No)</b>	
95% of turbidity readings <= 1 NTU? (2)	Yes / No	CT's met everyday?	All CL2 residuals at entry point >= 0.2 mg/l?
All daily turbidity readings <= 5 NTU?	Yes / No	Yes / No	Yes / No
<b>Notes:</b>	PRINTED NAME: <i>Chuck Leffler</i>		DATE: <i>5-10-21</i>
	SIGNATURE: <i>[Signature]</i>		CERT #: <i>T-7158 FE</i>
	PHONE #: <i>541-990-1907</i>		

(1) Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. (2) Filtered systems only.

# OHA - Drinking Water Program - Surface Water Quality Data Form

System Name: ALBANY, CITY OF ID #: OR4100012 WTP:-WTP-B Month/Year: 4/2021

Date / Time	Minimum CL2 Residual @ 1st User (C) (1)	Contact Time (T)	Actual CT	Temp.	pH	Reqd. CT	CT Met? (1)	Peak Hourly Demand Flow (2)
	[ppm or mg/L]	[minutes]	C x T	[°C]		Use tables	Yes / No	[GPM]
1	1.06	216.6	229.6	7.1	8.51	40.5	Y	5,501
2	1.10	275.3	302.8	8.1	8.35	35.9	Y	5,108
3	1.08	292.5	315.9	7.7	8.24	35.4	Y	5,069
4	1.06	224.6	238.1	7.7	8.44	38.0	Y	6,269
5	1.07	267.8	286.5	6.8	8.50	41.3	Y	4,842
6	1.06	231.8	245.7	7.1	8.54	41.0	Y	5,295
7	1.06	105.1	111.4	7.0	8.49	40.5	Y	6,843
8	1.13	245.2	277.1	6.9	8.38	39.6	Y	5,515
9	1.04	262.2	272.7	6.8	8.42	40.0	Y	5,297
10	1.04	291.7	303.4	7.3	8.49	39.7	Y	5,011
11	1.05	262.0	275.1	6.2	8.37	41.0	Y	5,325
12	1.07	214.4	229.4	7.2	8.45	39.4	Y	6,608
13	1.07	232.1	248.3	7.4	8.41	38.3	Y	5,179
14	1.03	209.7	216.0	8.1	8.41	36.5	Y	6,661
15	1.00	213.8	213.8	8.2	8.43	36.2	Y	6,313
16	1.05	201.9	212.0	9.4	8.46	34.0	Y	6,832
17	1.01	185.6	187.5	9.6	8.41	32.7	Y	6,193
18	1.00	147.4	147.4	10.6	8.56	32.3	Y	5,919
19	1.09	148.6	162.0	10.5	8.61	33.5	Y	5,894
20	1.06	148.5	157.4	10.5	8.65	34.0	Y	6,094
21	1.07	175.7	188.0	10.0	8.65	34.9	Y	6,069
22	1.07	181.7	194.4	10.2	8.64	34.4	Y	5,935
23	1.06	175.7	186.2	9.4	8.60	35.7	Y	6,142
24	1.06	212.2	224.9	9.0	8.63	37.2	Y	6,507
25	1.09	186.4	203.2	8.6	8.52	36.9	Y	7,841
26	1.01	199.7	201.7	9.0	8.49	35.2	Y	7,974
27	0.97	199.9	193.9	9.7	8.40	32.3	Y	7,781
28	0.94	186.4	175.2	9.9	8.41	31.9	Y	7,977
29	1.06	231.5	245.4	10.7	8.44	31.0	Y	5,770
30	1.07	232.9	249.2	11.0	8.46	30.4	Y	6,071

Signature:   
 Print Name: Chuck Leffler

Date: 5-10-21  
 Cert #: T-7158 FE

(1) If Cl2 at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.  
 (2) Prior to 11/2014, Peak Instantaneous Demand Flow is used.

# Department of Human Services - Drinking Water Section

## Membrane Integrity Report Form

Public Water System Name: Albany

PWS ID#: 41 00012 B

Month/Year:

4/ 2021

Albany/Millersburg Water Plant

Date	Membrane 1	Membrane 2	Membrane 3	Membrane 4
04/01/21	Pass	Pass	Pass	Pass
04/02/21	Pass	Pass	Pass	Pass
04/03/21	Pass	Pass	Pass	Pass
04/04/21	Pass	Pass	Pass	Pass
04/05/21	Pass	Pass	Pass	Pass
04/06/21	Pass	Pass	Pass	Pass
04/07/21	Pass	Pass	Pass	Pass
04/08/21	Pass	Pass	Pass	Pass
04/09/21	Pass	Pass	Pass	Pass
04/10/21	Pass	Pass	Pass	Pass
04/11/21	Pass	Pass	Pass	Pass
04/12/21	Pass	Pass	Pass	Pass
04/13/21	Pass	Pass	Pass	Pass
04/14/21	Pass	Pass	Pass	Pass
04/15/21	Pass	Pass	Pass	Pass
04/16/21	Pass	Pass	Pass	Pass
04/17/21	Pass	Pass	Pass	Pass
04/18/21	Pass	Pass	Pass	Pass
04/19/21	Pass	Pass	Pass	Pass
04/20/21	Pass	Pass	Pass	Pass
04/21/21	Pass	Pass	Pass	Pass
04/22/21	Pass	Pass	Pass	Pass
04/23/21	Pass	Pass	Pass	Pass
04/24/21	Pass	Pass	Pass	Pass
04/25/21	Pass	Pass	Pass	Pass
04/26/21	Pass	Pass	Pass	Pass
04/27/21	Pass	Pass	Pass	Pass
04/28/21	Pass	Pass	Pass	Pass
04/29/21	Pass	Pass	Pass	Pass
04/30/21	Pass	Pass	Pass	Pass

Signature: \_\_\_\_\_



Date: \_\_\_\_\_

S-10-21

Print Name: \_\_\_\_\_

Chuck Lettles

Cert. #: \_\_\_\_\_

T-71SP FE