


OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Linn
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

System Name: ALBANY, CITY OF ID #: OR4100012 WTP--WTP-B

Month/Year: 5/2021

DAY	12 AM	4 AM	8 AM	NOON	4 PM	8 PM	Highest Reading of the Day (1)
	[NTU]	[NTU]	[NTU]	[NTU]	[NTU]	[NTU]	[NTU]
1	0.01	0.01	0.01	0.01	0.01	0.01	0.01
2	0.01	0.01	0.01	0.01	0.01	0.01	0.01
3	0.01	0.01	0.01	0.01	0.01	0.01	0.01
4	0.01	0.01	0.01	0.01	0.01	0.01	0.01
5	0.01	0.01	0.01	0.01	0.01	0.01	0.01
6	0.01	0.01	0.01	0.02	0.01	0.01	0.02
7	0.01	0.01	0.01	0.01	0.01	0.01	0.01
8	0.01	0.01	0.01	0.01	0.01	0.01	0.01
9	0.01	0.01	0.01	0.01	0.01	0.01	0.01
10	0.01	0.01	0.01	0.01	0.01	0.01	0.01
11	0.01	0.01	0.01	0.01	0.01	0.01	0.01
12	0.01	0.01	0.01	0.01	0.01	0.01	0.01
13	0.01	0.01	0.01	0.01	0.01	0.01	0.01
14	0.01	0.01	0.01	0.01	0.01	0.01	0.01
15	0.01	0.01	0.01	0.01	0.01	0.01	0.01
16	0.01	0.01	0.01	0.01	0.01	0.01	0.01
17	0.01	0.01	0.01	0.01	0.01	0.01	0.01
18	0.01	0.01	0.01	0.01	0.01	0.01	0.01
19	0.01	0.01	0.01	0.01	0.01	0.01	0.01
20	0.01	0.01	0.01	0.01	0.01	0.01	0.01
21	0.01	0.02	0.01	0.01	0.01	0.01	0.02
22	0.02	0.01	0.01	0.01	0.01	0.01	0.02
23	0.01	0.02	0.02	0.01	0.01	0.01	0.02
24	0.01	0.01	0.02	0.01	0.01	0.01	0.02
25	0.01	0.01	0.01	0.01	0.01	0.01	0.01
26	0.01	0.01	0.01	0.01	0.01	0.01	0.01
27	0.01	0.01	0.01	0.01	0.01	0.01	0.01
28	0.01	0.01	0.01	0.01	0.01	0.01	0.01
29	0.01	0.01	0.01	0.01	0.01	0.01	0.01
30	0.01	0.01	0.02	0.01	0.01	0.01	0.02
31	0.01	0.01	0.01	0.01	0.01	0.01	0.01

Membrane Filtration		Monthly Summary (Answer Yes or No)	
95% of turbidity readings <= 1 NTU? (2)	<input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday?	All CL2 residuals at entry point >= 0.2 mg/l?
All daily turbidity readings <= 5 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No
Notes:		PRINTED NAME: Scott LaRaque	
		SIGNATURE: 	DATE: 6/10/21
		PHONE #: 541 791 0175	CERT #: N/A

(1) Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. (2) Filtered systems only.

OHA - Drinking Water Program - Surface Water Quality Data Form

System Name: ALBANY, CITY OF ID #: OR4100012 WTP--WTP-B	Month/Year: 5/2021
---	--------------------

Date / Time	Minimum CL2 Residual @ 1st User (C) (1)	Contact Time (T)	Actual CT	Temp.	pH	Reqd. CT	CT Met? (1)	Peak Hourly Demand Flow (2)
	[ppm or mg/L]	[minutes]	C x T	[°C]		Use tables	Yes / No	[GPM]
1	1.10	227.9	250.7	11.0	8.46	30.6	Y	5,924
2	1.04	191.9	199.6	10.6	8.33	29.9	Y	7,661
3	1.00	210.9	210.9	10.7	8.34	29.6	Y	6,783
4	1.00	193.1	193.1	11.5	8.29	27.6	Y	7,877
5	1.02	212.3	216.5	11.2	8.32	28.5	Y	6,590
6	1.04	226.1	235.1	11.3	8.38	29.0	Y	6,339
7	1.09	224.3	244.5	10.5	8.43	31.3	Y	6,532
8	1.18	218.3	257.6	9.6	8.44	33.8	Y	6,603
9	1.03	188.8	194.5	10.0	8.45	32.3	Y	7,267
10	0.93	172.7	160.6	10.1	8.40	31.2	Y	7,813
11	0.93	159.4	148.2	10.9	8.35	29.1	Y	7,123
12	0.96	148.8	142.8	11.6	8.34	27.7	Y	6,950
13	1.15	142.7	164.1	12.2	8.37	27.5	Y	7,452
14	1.07	138.2	147.9	12.8	8.38	26.5	Y	7,385
15	0.98	123.1	120.6	12.8	8.42	26.6	Y	7,124
16	1.00	120.8	120.8	12.7	8.43	26.9	Y	7,018
17	1.04	95.7	99.5	12.9	8.47	27.1	Y	8,465
18	1.07	105.9	113.3	11.6	8.49	29.7	Y	7,061
19	1.09	93.1	101.5	11.2	8.50	30.6	Y	7,366
20	1.19	136.3	162.2	10.4	8.46	32.2	Y	7,288
21	1.15	159.3	183.2	10.1	8.42	32.3	Y	7,093
22	1.04	185.5	192.9	10.6	8.43	31.0	Y	7,440
23	1.02	171.7	175.1	11.5	8.45	29.2	Y	7,430
24	1.04	178.4	185.5	10.9	8.49	31.0	Y	7,209
25	1.00	193.7	193.7	10.7	8.42	30.4	Y	6,868
26	0.94	187.1	175.9	11.2	8.42	29.2	Y	6,975
27	0.89	178.0	158.4	12.5	8.44	27.0	Y	7,670
28	0.96	176.7	169.6	11.7	8.40	28.2	Y	8,111
29	1.04	189.5	197.1	12.2	8.42	27.7	Y	7,106
30	1.07	143.2	153.2	13.0	8.43	26.6	Y	7,777
31	1.04	127.2	132.3	13.7	8.41	25.2	Y	7,539

Signature: SCOTT LAROCHE

Date: 6/10/21

Print Name: SCOTT LAROCHE

Cert #: N/A

(1) If Cl2 at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.
 (2) Prior to 11/2014, Peak Instantaneous Demand Flow is used.

Department of Human Services - Drinking Water Section

Membrane Integrity Report Form

Public Water System Name: Albany

PWS ID#: 41 00012 B

Month/Year:

5/ 2021

Albany/Millersburg Water Plant

Date	Membrane 1	Membrane 2	Membrane 3	Membrane 4
05/01/21	Pass	Pass	Pass	Pass
05/02/21	Pass	Pass	Pass	Pass
05/03/21	Pass	Pass	Pass	Pass
05/04/21	Pass	Pass	Pass	Pass
05/05/21	Pass	Pass	Pass	Pass
05/06/21	Pass	Pass	Pass	Pass
05/07/21	Pass	Pass	Pass	Pass
05/08/21	Pass	Pass	Pass	Pass
05/09/21	Pass	Pass	Pass	Pass
05/10/21	Pass	Pass	Pass	Pass
05/11/21	Pass	Pass	Pass	Pass
05/12/21	Pass	Pass	Pass	Pass
05/13/21	Pass	Pass	Pass	Pass
05/14/21	Pass	Pass	Pass	Pass
05/15/21	Pass	Pass	Pass	Pass
05/16/21	Pass	Pass	Pass	Pass
05/17/21	Pass	Pass	Pass	Pass
05/18/21	Pass	Pass	Pass	Pass
05/19/21	Pass	Pass	Pass	Pass
05/20/21	Pass	Pass	Pass	Pass
05/21/21	Pass	Pass	Pass	Pass
05/22/21	Pass	Pass	Pass	Pass
05/23/21	Pass	Pass	Pass	Pass
05/24/21	Pass	Pass	Pass	Pass
05/25/21	Pass	Pass	Pass	Pass
05/26/21	Pass	Pass	Pass	Pass
05/27/21	Pass	Pass	Pass	Pass
05/28/21	Pass	Pass	Pass	Pass
05/29/21	Pass	Pass	Pass	Pass
05/30/21	Pass	Pass	Pass	Pass
05/31/21	Pass	Pass	Pass	Pass

Signature: 

Date: 6/10/21

Print Name: Scott LaRape, Water Superintendent

Cert. #: N/A