

OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Linn
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

System Name: ALBANY, CITY OF ID #: OR4100012 WTP:-WTP-B

Month/Year: 6/2021

DAY	12 AM	4 AM	8 AM	NOON	4 PM	8 PM	Highest Reading of the Day (1)
	[NTU]	[NTU]	[NTU]	[NTU]	[NTU]	[NTU]	[NTU]
1	0.01	0.01	0.01	0.01	0.01	0.01	0.01
2	0.01	0.01	0.01	0.01	0.01	0.01	0.01
3	0.01	0.01	0.01	0.01	0.01	0.01	0.01
4	0.01	0.01	0.01	0.01	0.01	0.01	0.01
5	0.01	0.01	0.01	0.01	0.01	0.01	0.01
6	0.01	0.01	0.01	0.01	0.01	0.01	0.01
7	0.01	0.01	0.01	0.01	0.01	0.01	0.01
8	0.01	0.01	0.01	0.01	0.01	0.01	0.01
9	0.01	0.01	0.01	0.01	0.01	0.01	0.01
10	0.01	0.01	0.01	0.01	0.01	0.01	0.01
11	0.01	0.01	0.01	0.01	0.01	0.01	0.01
12	0.01	0.01	0.01	0.01	0.01	0.01	0.01
13	0.01	0.01	0.01	0.01	0.01	0.01	0.01
14	0.01	0.01	0.01	0.01	0.01	0.01	0.01
15	0.01	0.01	0.01	0.01	0.01	0.02	0.02
16	0.01	0.01	0.01	0.01	0.01	0.01	0.01
17	0.01	0.01	0.01	0.01	0.01	0.01	0.01
18	0.01	0.01	0.01	0.01	0.01	0.01	0.01
19	0.01	0.01	0.01	0.01	0.01	0.01	0.01
20	0.01	0.02	0.01	0.01	0.01	0.01	0.02
21	0.01	0.01	0.01	0.01	0.01	0.01	0.01
22	0.01	0.01	0.06	0.01	0.01	0.01	0.06
23	0.01	0.01	0.01	0.01	0.01	0.01	0.01
24	0.01	0.01	0.01	0.01	0.01	0.01	0.01
25	0.01	0.01	0.01	0.01	0.01	0.01	0.01
26	0.01	0.01	0.01	0.01	0.01	0.01	0.01
27	0.01	0.01	0.01	0.01	0.01	0.01	0.01
28	0.01	Plant Off	0.01	0.01	0.01	0.01	0.01
29	0.01	0.01	0.01	0.01	0.01	0.01	0.01
30	0.01	0.01	0.01	0.01	0.01	0.01	0.01

Membrane Filtration		Monthly Summary (Answer Yes or No)	
95% of turbidity readings <= 1 NTU? (2)	Yes/No <input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday?	All CL2 residuals at entry point >= 0.2 mg/l?
All daily turbidity readings <= 5 NTU?	Yes/No <input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No
Notes:	PRINTED NAME: <i>Chuck Leffler</i>		
	SIGNATURE: <i>[Signature]</i>		DATE: 7-7-21
	PHONE #: 541-990-1907		CERT #: T-7158 FE


(1) Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. (2) Filtered systems only.

OHA - Drinking Water Program - Surface Water Quality Data Form

System Name: ALBANY, CITY OF ID #: OR4100012 WTP:-WTP-B Month/Year: 6/2021

Date / Time	Minimum CL2 Residual @ 1st User (C) (1)	Contact Time (T)	Actual CT	Temp.	pH	Reqd. CT	CT Met? (1)	Peak Hourly Demand Flow (2)
	[ppm or mg/L]	[minutes]	C x T	[°C]		Use tables	Yes / No	[GPM]
1	0.95	114.2	108.5	14.1	8.39	24.0	Y	7,966
2	0.95	151.4	143.8	15.0	8.23	21.4	Y	8,077
3	0.96	170.0	163.2	15.0	8.29	21.9	Y	8,767
4	0.99	173.2	171.5	14.6	8.10	21.0	Y	8,139
5	1.04	187.3	194.8	13.9	8.08	21.9	Y	7,682
6	1.03	203.5	209.6	11.9	8.23	26.3	Y	7,131
7	1.03	203.9	210.0	11.5	8.34	28.2	Y	7,111
8	1.05	172.0	180.6	11.6	8.35	28.0	Y	7,489
9	1.10	175.1	192.6	11.6	8.38	28.6	Y	7,797
10	1.10	187.4	206.1	12.5	8.36	26.8	Y	6,957
11	1.09	230.4	251.1	12.0	8.40	27.9	Y	6,473
12	1.11	228.2	253.3	11.5	8.38	28.9	Y	6,538
13	1.06	180.6	191.4	13.7	8.39	25.0	Y	7,228
14	1.02	223.9	228.4	12.7	8.26	25.3	Y	6,244
15	0.92	201.5	185.4	12.7	8.31	25.5	Y	6,464
16	0.85	216.8	184.3	12.4	8.30	25.5	Y	6,707
17	0.78	200.0	156.0	13.3	8.32	24.1	Y	6,741
18	0.80	170.2	136.2	14.2	8.29	22.6	Y	7,967
19	0.74	238.7	176.6	14.2	8.30	22.5	Y	6,631
20	0.70	156.4	109.5	14.9	8.26	21.0	Y	8,425
21	0.76	155.0	117.8	15.9	8.27	20.0	Y	8,932
22	0.78	169.3	132.1	15.8	8.19	19.6	Y	8,518
23	0.76	184.1	139.9	15.3	8.22	20.3	Y	8,217
24	0.74	163.8	121.2	15.1	8.25	20.9	Y	8,955
25	0.82	150.3	123.2	16.0	8.26	19.8	Y	9,205
26	0.97	174.6	169.4	16.7	8.24	19.2	Y	8,985
27	0.96	146.9	141.0	17.6	8.19	17.8	Y	9,920
28	0.84	141.0	118.4	18.1	8.29	17.5	Y	9,318
29	0.79	158.1	124.9	17.1	8.33	18.9	Y	8,559
30	0.81	161.4	130.7	16.3	8.36	20.2	Y	8,879

Signature: _____



Date: _____

7-7-21

Print Name: _____

Chuck Leffler

Cert #: _____

T-7158 FE

(1) If Cl2 at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.
 (2) Prior to 11/2014, Peak Instantaneous Demand Flow is used.

Department of Human Services - Drinking Water Section

Membrane Integrity Report Form

Public Water System Name: Albany

PWS ID#: 41 00012 B

Month/Year:

6/ 2021

Albany/Millersburg Water Plant

Date	Membrane 1	Membrane 2	Membrane 3	Membrane 4
06/01/21	Pass	Pass	Pass	Pass
06/02/21	Pass	Pass	Pass	Pass
06/03/21	Pass	Pass	Pass	Pass
06/04/21	Pass	Pass	Pass	Pass
06/05/21	Pass	Pass	Pass	Pass
06/06/21	Pass	Pass	Pass	Pass
06/07/21	Pass	Pass	Pass	Pass
06/08/21	Pass	Pass	Pass	Pass
06/09/21	Pass	Pass	Pass	Pass
06/10/21	Pass	Pass	Fail	Pass
06/11/21	Pass	Pass	Pass	Pass
06/12/21	Pass	Pass	Pass	Pass
06/13/21	Pass	Pass	Pass	Pass
06/14/21	Pass	Pass	Pass	Pass
06/15/21	Pass	Pass	Pass	Pass
06/16/21	Pass	Pass	Pass	Pass
06/17/21	Pass	Pass	Pass	Pass
06/18/21	Pass	Pass	Pass	Pass
06/19/21	Pass	Pass	Pass	Pass
06/20/21	Pass	Pass	Pass	Pass
06/21/21	Pass	Pass	Pass	Pass
06/22/21	Pass	Pass	Pass	Pass
06/23/21	Pass	Pass	Pass	Pass
06/24/21	Pass	Pass	Pass	Pass
06/25/21	Pass	Pass	Pass	Pass
06/26/21	Pass	Pass	Pass	Pass
06/27/21	Pass	Pass	Pass	Pass
06/28/21	Pass	Pass	Pass	Pass
06/29/21	Pass	Pass	Pass	Pass
06/30/21	Pass	Pass	Pass	Pass

Signature: _____



Date: _____

7-7-21

Print Name: _____

Chuck Leffler

Cert. #: _____

T-7158 FE