

**OHA - Drinking Water Program - Turbidity Monitoring Report Form    County: Linn**  
**Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems**

**System Name: ALBANY, CITY OF    ID #: OR4100012    WTP:-WTP-B**

**Month/Year: 7/2021**

DAY	12 AM	4 AM	8 AM	NOON	4 PM	8 PM	Highest Reading of the Day (1)
	[NTU]	[NTU]	[NTU]	[NTU]	[NTU]	[NTU]	[NTU]
1	0.01	0.01	0.01	0.01	0.01	0.01	0.01
2	0.01	0.01	0.01	0.01	0.01	0.01	0.01
3	0.01	0.01	0.01	0.01	0.01	0.01	0.01
4	0.01	0.01	0.01	0.01	0.01	0.01	0.01
5	0.01	0.01	0.01	0.01	0.01	0.01	0.01
6	0.01	0.01	0.01	0.01	0.01	0.01	0.01
7	0.01	0.01	0.01	0.01	0.01	0.01	0.01
8	0.01	0.01	0.01	0.01	0.01	0.01	0.01
9	0.01	0.01	0.01	0.01	0.01	0.01	0.01
10	0.01	0.01	0.01	0.01	0.01	0.01	0.01
11	0.01	0.01	0.01	0.01	0.01	0.01	0.01
12	0.01	0.01	0.01	0.01	0.01	0.01	0.01
13	0.01	0.01	0.01	0.01	0.01	0.01	0.01
14	0.01	0.01	0.01	0.01	0.01	0.01	0.01
15	0.01	0.01	0.01	0.01	0.01	0.01	0.01
16	0.01	0.01	0.01	0.01	0.01	0.01	0.01
17	0.01	0.01	0.01	0.01	0.01	0.01	0.01
18	0.01	Plant Off	0.01	0.01	0.01	0.01	0.01
19	0.01	0.01	0.01	0.01	0.01	0.01	0.01
20	0.01	0.01	0.01	0.01	0.01	0.01	0.01
21	0.01	0.01	0.01	0.01	0.01	0.01	0.01
22	0.01	0.01	0.01	0.01	0.01	0.01	0.01
23	0.01	0.01	0.01	0.01	0.01	0.01	0.01
24	0.01	0.01	0.01	0.01	0.01	0.01	0.01
25	0.01	0.01	0.01	0.01	0.01	0.01	0.01
26	0.01	0.01	0.01	0.01	0.01	0.01	0.01
27	0.01	0.01	0.01	0.01	0.01	0.01	0.01
28	0.01	0.01	0.01	0.01	0.01	0.01	0.01
29	0.01	0.01	0.01	0.01	0.01	0.01	0.01
30	0.01	0.01	0.01	0.01	0.01	0.01	0.01
31	0.01	0.01	0.01	0.01	0.01	0.01	0.01

<b>Membrane Filtration</b>		<b>Monthly Summary (Answer Yes or No)</b>	
95% of turbidity readings <= 1 NTU? (2)	<input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday?	All CL2 residuals at entry point >= 0.2 mg/l?
All daily turbidity readings <= 5 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No
<b>Notes:</b>	PRINTED NAME: <i>Chuck Leffler</i>		DATE: <i>8-9-21</i>
	SIGNATURE: <i>[Signature]</i>		CERT #: <i>T-718 FE</i>
	PHONE #: <i>541-990-1907</i>		

(1) Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. (2) Filtered systems only.



## OHA - Drinking Water Program - Surface Water Quality Data Form

**System Name: ALBANY, CITY OF ID #: OR4100012 WTP:-WTP-B**      **Month/Year: 7/2021**

Date / Time	Minimum CL2 Residual @ 1st User (C) (1)	Contact Time (T)	Actual CT	Temp.	pH	Reqd. CT	CT Met? (1)	Peak Hourly Demand Flow (2)
	[ppm or mg/L]	[minutes]	C x T	[°C]		Use tables	Yes / No	[GPM]
1	0.93	169.7	157.8	15.0	8.37	22.4	Y	8,665
2	1.04	171.6	178.5	14.5	8.35	23.2	Y	9,008
3	0.98	161.7	158.5	15.8	8.35	21.1	Y	7,778
4	1.00	166.7	166.7	15.9	8.31	20.7	Y	8,313
5	1.02	168.3	171.7	15.7	8.30	21.0	Y	8,344
6	0.93	156.4	145.5	15.6	8.32	21.1	Y	9,135
7	0.89	163.7	145.7	15.6	8.31	21.0	Y	8,482
8	0.91	146.2	133.0	14.8	8.39	22.8	Y	9,042
9	1.05	141.1	148.2	14.0	8.43	24.7	Y	9,478
10	1.08	149.5	161.5	15.5	8.43	22.6	Y	9,007
11	1.00	165.5	165.5	15.6	8.38	21.7	Y	8,175
12	0.93	143.0	133.0	15.6	8.37	21.5	Y	8,742
13	0.93	165.2	153.6	15.2	8.39	22.2	Y	8,437
14	1.09	140.1	152.7	15.2	8.41	22.8	Y	9,572
15	1.15	148.4	170.7	14.9	8.42	23.6	Y	8,915
16	1.07	163.4	174.8	14.0	8.43	24.8	Y	9,019
17	1.00	160.9	160.9	14.5	8.44	23.9	Y	8,465
18	0.97	160.7	155.9	14.7	8.38	23.0	Y	8,480
19	0.98	155.7	152.6	15.0	8.44	23.2	Y	9,023
20	0.97	147.3	142.9	15.0	8.46	23.3	Y	9,023
21	0.95	163.3	155.1	14.9	8.48	23.6	Y	8,632
22	0.92	163.2	150.1	13.9	8.51	25.2	Y	8,632
23	0.96	170.6	163.8	14.1	8.49	25.0	Y	8,852
24	0.94	166.2	156.2	14.8	8.52	24.0	Y	8,852
25	0.92	146.9	135.1	15.5	8.48	22.5	Y	8,505
26	1.12	153.0	171.4	15.8	8.50	22.8	Y	8,994
27	1.16	156.6	181.7	15.8	8.53	23.2	Y	9,560
28	1.02	150.7	153.7	15.1	8.54	23.9	Y	8,755
29	0.99	134.7	133.4	15.4	8.51	23.1	Y	10,438
30	0.94	124.9	117.4	15.7	8.53	22.8	Y	9,442
31	0.95	133.0	126.4	14.5	8.63	25.5	Y	8,626

Signature: \_\_\_\_\_



Date: \_\_\_\_\_

8-9-21

Print Name: \_\_\_\_\_

Chuck Leffler

Cert #: \_\_\_\_\_

T-7158 FE

(1) If Cl2 at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.  
 (2) Prior to 11/2014, Peak Instantaneous Demand Flow is used.

# Department of Human Services - Drinking Water Section

## Membrane Integrity Report Form

Public Water System Name: Albany

PWS ID#: 41 00012 B

Month/Year:

7/ 2021

Albany/Millersburg Water Plant

Date	Membrane 1	Membrane 2	Membrane 3	Membrane 4
07/01/21	Pass	Pass	Pass	Pass
07/02/21	Pass	Pass	Pass	Pass
07/03/21	Pass	Pass	Pass	Pass
07/04/21	Pass	Pass	Pass	Pass
07/05/21	Pass	Pass	Pass	Pass
07/06/21	Pass	Pass	Pass	Pass
07/07/21	Pass	Pass	Pass	Pass
07/08/21	Pass	Pass	Pass	Pass
07/09/21	Pass	Pass	Pass	Pass
07/10/21	Pass	Pass	Pass	Pass
07/11/21	Pass	Pass	Pass	Pass
07/12/21	Pass	Pass	Pass	Pass
07/13/21	Pass	Pass	Pass	Pass
07/14/21	Pass	Pass	Pass	Pass
07/15/21	Pass	Pass	Pass	Pass
07/16/21	Pass	Pass	Pass	Pass
07/17/21	Pass	Pass	Pass	Pass
07/18/21	Pass	Pass	Pass	Pass
07/19/21	Pass	Pass	Pass	Pass
07/20/21	Pass	Pass	Pass	Pass
07/21/21	Pass	Pass	Pass	Pass
07/22/21	Pass	Pass	Pass	Pass
07/23/21	Pass	Pass	Pass	Pass
07/24/21	Pass	Pass	Pass	Pass
07/25/21	Pass	Pass	Pass	Pass
07/26/21	Pass	Pass	Pass	Pass
07/27/21	Pass	Pass	Pass	Pass
07/28/21	Pass	Pass	Pass	Pass
07/29/21	Pass	Pass	Pass	Pass
07/30/21	Pass	Pass	Pass	Pass
07/31/21	Pass	Pass	Pass	Pass

Signature:



Print Name:

Chuck Leffler

Date:

8-9-21

Cert. #:

T-7158 FE