

OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Linn
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

System Name: ALBANY, CITY OF ID #: OR4100012 WTP:-WTP-B

Month/Year: 8/2021

DAY	12 AM	4 AM	8 AM	NOON	4 PM	8 PM	Highest Reading of the Day (1)
	[NTU]	[NTU]	[NTU]	[NTU]	[NTU]	[NTU]	[NTU]
1	0.01	0.01	0.01	0.01	0.01	0.01	0.01
2	0.01	0.01	0.01	0.01	0.01	0.01	0.01
3	0.01	0.01	0.01	0.01	0.01	0.01	0.01
4	0.01	0.01	0.01	0.01	0.01	0.01	0.01
5	0.01	0.01	0.01	0.01	0.01	0.01	0.01
6	0.01	0.01	0.01	0.01	0.01	0.01	0.01
7	0.01	0.01	0.01	0.01	0.01	0.01	0.01
8	0.01	0.01	0.01	0.01	0.01	0.01	0.01
9	0.01	0.01	0.01	0.01	0.01	0.01	0.01
10	0.01	0.01	0.01	0.01	0.01	0.01	0.01
11	0.01	0.01	0.01	0.01	0.01	0.01	0.01
12	0.01	0.01	0.01	0.01	0.01	0.01	0.01
13	0.01	0.01	0.01	0.01	0.01	0.01	0.01
14	0.01	0.01	0.01	0.01	0.01	0.01	0.01
15	0.01	0.01	0.01	0.01	0.01	0.01	0.01
16	0.01	0.01	0.01	0.01	0.01	0.01	0.01
17	0.01	0.01	0.01	0.01	0.01	0.01	0.01
18	0.01	0.01	0.01	0.01	0.01	0.01	0.01
19	0.01	0.01	0.01	0.01	0.01	0.01	0.01
20	0.01	0.01	0.01	0.01	0.01	0.01	0.01
21	0.01	0.01	0.01	0.01	0.01	0.01	0.01
22	0.01	0.01	0.01	0.01	0.01	0.01	0.01
23	0.01	0.01	0.01	0.01	0.01	0.01	0.01
24	0.01	0.01	0.01	0.01	0.01	0.01	0.01
25	0.01	0.01	0.01	0.01	0.01	0.01	0.01
26	0.01	0.01	0.01	0.01	0.02	0.01	0.02
27	0.01	0.01	0.01	0.01	0.01	0.01	0.01
28	0.01	0.01	0.01	0.01	0.01	0.01	0.01
29	Plant Off	0.01	0.01	0.01	0.01	0.01	0.01
30	0.01	0.01	0.01	0.01	0.01	0.01	0.01
31	0.01	0.01	0.01	0.01	0.01	0.01	0.01

Membrane Filtration	Monthly Summary (Answer Yes or No)	
95% of turbidity readings <= 1 NTU? (2) <input checked="" type="checkbox"/> Yes / No	CT's met everyday? <input checked="" type="checkbox"/> Yes / No	All CL2 residuals at entry point >= 0.2 mg/l? <input checked="" type="checkbox"/> Yes / No
All daily turbidity readings <= 5 NTU? <input checked="" type="checkbox"/> Yes / No		
Notes:	PRINTED NAME: <i>Chuck Leffler</i>	DATE: 9-3-21
	SIGNATURE: <i>[Signature]</i>	CERT #: T-1158 FE
	PHONE #: 541-990-1907	

(1) Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. (2) Filtered systems only.

OHA - Drinking Water Program - Surface Water Quality Data Form

System Name: ALBANY, CITY OF ID #: OR4100012 WTP:-WTP-B Month/Year: 8/2021

Date / Time	Minimum CL2 Residual @ 1st User (C) (1)	Contact Time (T)	Actual CT	Temp.	pH	Reqd. CT	CT Met? (1)	Peak Hourly Demand Flow (2)
	[ppm or mg/L]	[minutes]	C x T	[°C]		Use tables	Yes / No	[GPM]
1	0.80	82.6	66.1	13.7	8.59	26.1	Y	8,626
2	0.76	159.3	121.1	15.2	8.66	24.0	Y	7,995
3	0.98	160.7	157.5	15.7	8.59	23.4	Y	8,766
4	0.96	148.2	142.3	15.3	8.57	23.7	Y	9,578
5	0.96	164.9	158.3	15.6	8.57	23.2	Y	9,578
6	0.98	125.5	123.0	14.9	8.61	24.8	Y	9,151
7	0.98	175.2	171.7	15.2	8.56	23.9	Y	9,151
8	0.95	176.3	167.5	15.2	8.33	21.8	Y	8,557
9	0.91	158.7	144.4	14.5	8.40	23.4	Y	9,199
10	0.91	166.2	151.2	15.0	8.43	22.9	Y	9,199
11	1.05	149.2	156.7	15.8	8.42	21.9	Y	9,114
12	1.03	163.0	167.9	16.2	8.41	21.2	Y	9,114
13	0.93	153.4	142.7	15.8	8.36	21.1	Y	9,161
14	0.95	172.1	163.5	15.1	8.42	22.8	Y	9,161
15	0.82	161.5	132.4	15.4	8.43	22.0	Y	8,749
16	0.97	162.5	157.6	15.2	8.41	22.6	Y	8,883
17	1.02	189.7	193.5	15.0	8.34	22.5	Y	8,883
18	1.06	169.7	179.9	13.0	8.39	26.1	Y	8,690
19	1.07	179.4	192.0	13.8	8.35	24.6	Y	8,690
20	1.05	173.1	181.8	14.3	8.28	23.0	Y	8,326
21	1.04	209.6	218.0	13.9	8.28	23.6	Y	8,326
22	1.03	189.8	195.5	13.2	8.30	24.8	Y	7,898
23	1.08	188.0	203.0	12.2	8.35	27.1	Y	7,909
24	1.07	181.3	194.0	12.6	8.34	26.5	Y	8,044
25	0.98	178.0	174.4	13.1	8.35	25.4	Y	8,044
26	0.98	181.7	178.1	13.7	8.37	24.5	Y	8,219
27	1.04	178.6	185.7	14.1	8.32	23.7	Y	8,219
28	1.02	169.8	173.2	13.3	8.29	24.6	Y	8,447
29	1.04	161.1	167.5	13.6	8.32	24.5	Y	8,447
30	1.04	181.4	188.7	13.7	8.34	24.5	Y	7,973
31	0.98	192.6	188.7	13.3	8.32	24.8	Y	7,973

Signature: _____

[Handwritten Signature]

Date: _____

9-3-21

Print Name: _____

Chuck Leffler

Cert #: _____

T-7158 FE

(1) If Cl2 at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.
 (2) Prior to 11/2014, Peak Instantaneous Demand Flow is used.

Department of Human Services - Drinking Water Section

Membrane Integrity Report Form

Public Water System Name: Albany

PWS ID#: 41 00012 B

Month/Year:

8/ 2021

Albany/Millersburg Water Plant

Date	Membrane 1	Membrane 2	Membrane 3	Membrane 4
08/01/21	Pass	Pass	Pass	Pass
08/02/21	Pass	Pass	Pass	Pass
08/03/21	Pass	Pass	Pass	Pass
08/04/21	Pass	Pass	Pass	Pass
08/05/21	Pass	Pass	Pass	Pass
08/06/21	Pass	Pass	Pass	Pass
08/07/21	Pass	Pass	Pass	Pass
08/08/21	Pass	Pass	Pass	Pass
08/09/21	Pass	Pass	Pass	Pass
08/10/21	Pass	Pass	Pass	Pass
08/11/21	Pass	Pass	Pass	Pass
08/12/21	Pass	Pass	Pass	Pass
08/13/21	Pass	Pass	Pass	Pass
08/14/21	Pass	Pass	Pass	Pass
08/15/21	Pass	Pass	Pass	Pass
08/16/21	Pass	Pass	Pass	Pass
08/17/21	Pass	Pass	Pass	Pass
08/18/21	Pass	Pass	Pass	Pass
08/19/21	Pass	Pass	Pass	Pass
08/20/21	Pass	Pass	Pass	Pass
08/21/21	Pass	Pass	Pass	Pass
08/22/21	Pass	Pass	Pass	Pass
08/23/21	Pass	Pass	Pass	Pass
08/24/21	Pass	Pass	Pass	Pass
08/25/21	Pass	Pass	Pass	Pass
08/26/21	Pass	Pass	Pass	Pass
08/27/21	Pass	Pass	Pass	Pass
08/28/21	Pass	Pass	Pass	Pass
08/29/21	Pass	Pass	Pass	Pass
08/30/21	Pass	Pass	Pass	Pass
08/31/21	Pass	Pass	Pass	Pass

Signature:



Print Name:

Chuck Loeffler

Date:

9-3-21

Cert. #:

T-7158 FE