

OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Linn
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

System Name: ALBANY, CITY OF ID #: OR4100012 WTP-:WTP-B

Month/Year: 9/2021

DAY	12 AM	4 AM	8 AM	NOON	4 PM	8 PM	Highest Reading of the Day (1)
	[NTU]	[NTU]	[NTU]	[NTU]	[NTU]	[NTU]	[NTU]
1	0.01	0.01	0.01	0.01	0.01	0.01	0.01
2	0.01	0.01	0.01	0.01	0.01	0.01	0.01
3	0.01	0.01	0.01	0.01	0.01	0.01	0.01
4	0.01	0.01	0.01	0.01	0.01	0.01	0.01
5	0.01	0.01	0.01	0.01	0.01	0.01	0.01
6	0.01	0.01	0.01	0.01	0.01	0.01	0.01
7	0.01	0.01	0.01	0.01	0.01	0.01	0.01
8	0.01	0.01	0.01	0.01	0.01	0.01	0.01
9	0.01	0.01	0.01	0.01	0.01	0.01	0.01
10	0.01	0.01	0.01	0.01	0.01	0.01	0.01
11	0.01	0.01	0.01	0.01	0.01	0.01	0.01
12	0.01	0.01	0.01	0.01	0.01	0.01	0.01
13	0.01	0.01	0.01	0.01	0.01	0.01	0.01
14	0.02	0.01	0.01	0.01	0.01	0.01	0.02
15	0.01	0.02	0.01	0.01	0.01	0.01	0.02
16	0.01	0.01	0.01	0.01	0.01	0.01	0.01
17	0.01	0.01	0.01	0.01	0.01	0.01	0.01
18	0.01	0.01	0.01	0.01	0.01	0.01	0.01
19	0.01	0.01	0.01	0.01	0.01	0.01	0.01
20	0.01	0.01	0.01	0.01	0.01	0.01	0.01
21	0.01	0.01	0.01	0.01	0.02	0.01	0.02
22	0.01	0.01	0.01	0.01	0.01	0.01	0.01
23	0.01	0.01	0.01	0.01	0.01	0.01	0.01
24	0.01	0.01	0.01	0.01	0.01	0.01	0.01
25	0.02	0.02	0.01	0.01	0.01	0.01	0.02
26	0.01	0.01	0.01	0.01	0.01	0.01	0.01
27	0.01	0.01	0.01	0.01	0.01	0.01	0.01
28	0.01	0.01	0.01	0.01	0.01	0.01	0.01
29	0.01	0.01	0.01	0.01	0.01	0.01	0.01
30	0.01	0.01	0.01	0.01	0.01	0.01	0.01


Membrane Filtration	Monthly Summary (Answer Yes or No)	
95% of turbidity readings <= 1 NTU? (2) <input checked="" type="radio"/> Yes / No	CT's met everyday? <input checked="" type="radio"/> Yes No	All CL2 residuals at entry point >= 0.2 mg/l? <input checked="" type="radio"/> Yes No
All daily turbidity readings <= 5 NTU? <input checked="" type="radio"/> Yes/ No		
Notes:	PRINTED NAME: <i>Scott LaRoque</i>	
	SIGNATURE: <i>SC LaRoque</i>	DATE: <i>10/18/21</i>
	PHONE #: <i>541 791 0175</i>	CERT #: <i>N/A</i>

(1) Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. (2) Filtered systems only.

OHA - Drinking Water Program - Surface Water Quality Data Form

System Name: ALBANY, CITY OF ID #: OR4100012 WTP:-WTP-B Month/Year: 9/2021

Date / Time	Minimum CL2 Residual @ 1st User (C) (1) [ppm or mg/L]	Contact Time (T) [minutes]	Actual CT C x T	Temp. [°C]	pH	Reqd. CT Use tables	CT Met? (1) Yes / No	Peak Hourly Demand Flow (2) [GPM]
1	0.93	169.4	157.5	12.5	8.28	25.5	Y	8,180
2	0.96	171.4	164.5	12.3	8.33	26.5	Y	8,180
3	0.98	176.9	173.4	12.2	8.41	27.4	Y	8,282
4	0.98	179.3	175.7	12.1	8.38	27.3	Y	8,282
5	0.95	185.6	176.3	12.9	8.35	25.6	Y	7,843
6	0.98	175.7	172.2	13.2	8.28	24.5	Y	7,843
7	0.98	189.4	185.6	13.0	8.30	25.0	Y	7,818
8	0.96	169.7	162.9	12.6	8.35	26.1	Y	8,503
9	0.95	177.3	168.4	13.1	8.34	25.3	Y	8,503
10	1.00	183.1	183.1	12.3	8.36	26.8	Y	8,226
11	1.04	189.3	196.9	11.3	8.33	28.4	Y	7,748
12	0.93	195.4	181.7	12.5	8.37	26.3	Y	7,697
13	0.93	170.9	158.9	12.1	8.35	26.8	Y	7,980
14	0.98	186.4	182.7	11.8	8.38	27.9	Y	7,980
15	0.95	182.5	173.4	12.6	8.33	26.0	Y	7,728
16	0.99	208.3	206.2	11.2	8.39	29.1	Y	7,728
17	1.01	201.7	203.7	10.9	8.45	30.4	Y	7,453
18	0.91	245.0	223.0	11.9	8.44	28.0	Y	5,170
19	0.93	196.5	182.7	11.7	8.30	27.0	Y	7,094
20	0.84	207.2	174.0	11.6	8.26	26.5	Y	5,906
21	0.86	201.2	173.0	11.8	8.28	26.4	Y	7,152
22	0.91	213.6	194.4	12.4	8.23	25.1	Y	6,507
23	1.06	233.2	247.2	12.2	8.27	26.2	Y	6,156
24	1.03	176.2	181.5	12.0	8.32	27.0	Y	7,363
25	1.06	188.2	199.5	12.4	8.29	26.1	Y	5,889
26	1.03	191.6	197.3	12.8	8.24	25.1	Y	6,314
27	1.04	208.2	216.5	11.8	8.34	27.7	Y	6,510
28	1.11	201.2	223.3	11.7	8.13	26.0	Y	6,089
29	0.91	208.7	189.9	11.6	8.20	26.2	Y	6,712
30	0.92	248.3	228.4	12.6	8.32	25.7	Y	5,459

Signature:  Date: 10/8/21
 Print Name: Scot LaRocque, Water Superintendent Cert #: N/A

(1) If Cl2 at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.
 (2) Prior to 11/2014, Peak Instantaneous Demand Flow is used.

Department of Human Services - Drinking Water Section

Membrane Integrity Report Form

Public Water System Name: Albany

PWS ID#: 41 00012 B

Month/Year:

9/ 2021

Albany/Millersburg Water Plant

Date	Membrane 1	Membrane 2	Membrane 3	Membrane 4
09/01/21	Pass	Pass	Pass	Pass
09/02/21	Pass	Pass	Pass	Pass
09/03/21	Pass	Pass	Pass	Pass
09/04/21	Pass	Pass	Pass	Pass
09/05/21	Pass	Pass	Pass	Pass
09/06/21	Pass	Pass	Pass	Pass
09/07/21	Pass	Pass	Pass	Pass
09/08/21	Pass	Pass	Pass	Pass
09/09/21	Pass	Pass	Pass	Pass
09/10/21	Pass	Pass	Pass	Pass
09/11/21	Pass	Pass	Pass	Pass
09/12/21	Pass	Pass	Pass	Pass
09/13/21	Pass	Pass	Pass	Pass
09/14/21	Pass	Pass	Pass	Pass
09/15/21	Pass	Pass	Pass	Pass
09/16/21	Pass	Pass	Pass	Pass
09/17/21	Pass	Pass	Pass	Pass
09/18/21	Pass	Pass	Pass	Pass
09/19/21	Pass	Pass	Pass	Pass
09/20/21	Pass	Pass	Pass	Pass
09/21/21	Pass	Pass	Pass	Pass
09/22/21	Pass	Pass	Pass	Pass
09/23/21	Pass	Pass	Pass	Pass
09/24/21	Pass	Pass	Pass	Pass
09/25/21	Pass	Pass	Pass	Pass
09/26/21	Pass	Pass	Pass	Pass
09/27/21	Pass	Pass	Pass	Pass
09/28/21	Pass	Pass	Pass	Pass
09/29/21	Pass	Pass	Pass	Pass
09/30/21	Pass	Pass	Pass	Pass

Signature: *SR JRV*

Date: 10/8/21

Print Name: Scott LaRoque, Water Superintendent Cert. #: N/A