

**OHA - Drinking Water Program - Turbidity Monitoring Report Form    County: Linn**  
**Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems**

System Name: ALBANY, CITY OF    ID #: OR4100012    WTP:-WTP-B

Month/Year: 10/2021

DAY	12 AM	4 AM	8 AM	NOON	4 PM	8 PM	Highest Reading of the Day (1)
	[NTU]	[NTU]	[NTU]	[NTU]	[NTU]	[NTU]	[NTU]
1	0.01	0.01	0.01	0.01	0.01	0.01	0.01
2	0.01	0.01	0.01	0.01	0.01	0.01	0.01
3	0.01	0.01	0.01	0.01	0.02	0.02	0.02
4	0.01	0.01	0.01	0.01	0.01	0.01	0.01
5	0.01	0.01	0.01	0.01	0.01	0.01	0.01
6	0.01	0.01	0.01	0.01	0.01	0.01	0.01
7	0.01	0.01	0.01	0.01	0.01	0.01	0.01
8	0.01	0.01	0.02	0.02	0.02	0.01	0.02
9	0.01	0.02	0.02	0.02	0.01	0.01	0.02
10	0.01	0.01	0.01	0.01	0.01	0.01	0.01
11	0.01	0.01	0.01	0.01	0.01	0.01	0.01
12	0.01	0.01	0.01	0.01	0.01	0.01	0.01
13	0.01	0.01	0.02	0.01	0.02	0.01	0.02
14	0.01	0.01	0.01	0.01	0.01	0.01	0.01
15	0.01	0.01	0.01	0.01	0.01	0.01	0.01
16	0.01	0.01	0.01	0.01	0.01	0.01	0.01
17	0.01	0.01	0.01	0.01	0.01	0.01	0.01
18	0.01	0.01	0.01	0.01	0.01	0.01	0.01
19	0.01	0.01	0.01	0.01	0.01	0.01	0.01
20	0.01	0.01	0.01	0.01	0.01	0.01	0.01
21	0.01	0.01	0.01	0.01	0.01	0.01	0.01
22	0.01	0.01	0.01	0.01	0.01	0.01	0.01
23	0.01	0.01	0.01	0.01	0.02	0.01	0.02
24	0.01	0.01	0.02	0.01	0.01	0.01	0.02
25	0.01	0.01	0.01	0.02	0.02	0.01	0.02
26	0.01	0.01	0.02	0.02	0.01	0.01	0.02
27	0.01	0.02	0.02	0.01	0.01	0.01	0.02
28	0.01	0.01	0.01	0.02	0.01	0.02	0.02
29	0.01	0.01	0.01	0.01	0.02	0.02	0.02
30	0.02	0.01	0.02	0.01	0.01	0.02	0.02
31	0.01	0.01	0.01	0.02	0.02	0.02	0.02

<b>Membrane Filtration</b>		<b>Monthly Summary (Answer Yes or No)</b>	
95% of turbidity readings <= 1 NTU? (2)	<input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday?	All CL2 residuals at entry point >= 0.2 mg/l?
All daily turbidity readings <= 5 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No
<b>Notes:</b>	<b>PRINTED NAME:</b> <i>Chuck Leffler</i>		<b>DATE:</b> 11-10-21
	<b>SIGNATURE:</b> <i>[Signature]</i>		
	<b>PHONE #:</b> 541-990-1907		<b>CERT #:</b> T-7158 FE


(1) Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. (2) Filtered systems only.



## OHA - Drinking Water Program - Surface Water Quality Data Form

System Name: ALBANY, CITY OF ID #: OR4100012 WTP--WTP-B Month/Year: 10/2021

Date / Time	Minimum CL2 Residual @ 1st User (C) (1)	Contact Time (T)	Actual CT	Temp.	pH	Reqd. CT	CT Met? (1)	Peak Hourly Demand Flow (2)
	[ppm or mg/L]	[minutes]	C x T	[°C]		Use tables	Yes / No	[GPM]
1	1.04	215.7	224.3	12.6	8.30	25.9	Y	6,652
2	1.06	254.4	269.7	12.0	8.33	27.2	Y	5,245
3	1.03	201.4	207.4	12.1	8.36	27.3	Y	7,071
4	1.04	217.4	226.1	12.1	8.33	26.9	Y	6,391
5	1.11	204.5	227.0	11.7	8.33	28.0	Y	6,594
6	1.09	130.6	142.4	11.1	8.24	28.0	Y	7,293
7	1.06	219.0	232.1	10.9	8.27	28.7	Y	6,049
8	1.09	219.2	238.9	10.2	8.30	30.6	Y	6,135
9	1.10	209.2	230.1	10.6	8.32	30.0	Y	5,424
10	1.03	270.4	278.5	11.6	8.38	28.4	Y	5,835
11	1.11	235.3	261.2	10.9	8.22	28.4	Y	6,176
12	1.09	235.1	256.3	9.9	8.29	31.1	Y	6,017
13	1.05	226.0	237.3	10.2	8.33	30.8	Y	5,896
14	1.01	251.6	254.1	10.7	8.33	29.6	Y	5,825
15	0.98	218.3	213.9	10.3	8.32	30.1	Y	5,351
16	0.98	225.3	220.8	10.4	8.37	30.4	Y	6,358
17	1.00	232.8	232.8	10.6	8.32	29.6	Y	6,058
18	1.00	247.6	247.6	10.7	8.29	29.0	Y	5,593
19	0.98	262.7	257.4	10.2	8.27	29.8	Y	5,612
20	1.10	256.6	282.3	10.5	8.30	29.9	Y	5,072
21	1.15	223.0	256.5	10.7	8.31	29.7	Y	5,688
22	1.13	244.8	276.6	11.1	8.26	28.4	Y	5,259
23	0.82	238.4	195.5	10.5	8.17	27.6	Y	6,129
24	0.78	232.2	181.1	10.2	8.12	27.6	Y	5,767
25	0.84	218.0	183.1	9.6	8.21	29.9	Y	5,971
26	0.94	229.4	215.6	9.5	8.24	30.7	Y	5,921
27	0.90	272.9	245.6	9.7	8.16	29.5	Y	5,163
28	0.87	280.0	243.6	10.0	8.16	28.7	Y	5,064
29	0.99	315.9	312.7	10.4	8.17	28.4	Y	4,728
30	1.01	293.3	296.2	9.4	8.17	30.5	Y	4,645
31	0.94	246.6	231.8	9.0	8.16	31.0	Y	6,222

Signature:   
 Print Name: Chuck Leffler

Date: 11-10-21  
 Cert #: T-7158 FE

(1) If Cl2 at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.  
 (2) Prior to 11/2014, Peak Instantaneous Demand Flow is used.



**Department of Human Services - Drinking Water Section**  
**Membrane Integrity Report Form**

Public Water System Name: Albany

PWS ID#: 41 00012 B


Month/Year:

10/ 2021

Albany/Millersburg Water Plant

Date	Membrane 1	Membrane 2	Membrane 3	Membrane 4
10/01/21	Pass	Pass	Pass	Pass
10/02/21	Pass	Pass	Pass	Pass
10/03/21	Pass	Pass	Pass	Pass
10/04/21	Pass	Pass	Pass	Pass
10/05/21	Pass	Pass	Pass	Pass
10/06/21	Pass	Pass	Pass	Pass
10/07/21	Pass	Pass	Pass	Pass
10/08/21	Pass	Pass	Pass	Pass
10/09/21	Pass	Pass	Pass	Pass
10/10/21	Pass	Pass	Pass	Pass
10/11/21	Pass	Pass	Pass	Pass
10/12/21	Pass	Pass	Pass	Pass
10/13/21	Pass	Pass	Pass	Pass
10/14/21	Pass	Pass	Pass	Pass
10/15/21	Pass	Pass	Pass	Pass
10/16/21	Pass	Pass	Pass	Pass
10/17/21	Pass	Pass	Pass	Pass
10/18/21	Pass	Pass	Pass	Pass
10/19/21	Pass	Pass	Pass	Pass
10/20/21	Pass	Pass	Pass	Pass
10/21/21	Pass	Pass	Pass	Pass
10/22/21	Pass	Pass	Pass	Pass
10/23/21	Pass	Pass	Pass	Pass
10/24/21	Pass	Pass	Pass	Pass
10/25/21	Pass	Pass	Pass	Pass
10/26/21	Pass	Pass	Pass	Pass
10/27/21	Pass	Pass	Pass	Pass
10/28/21	Pass	Pass	Pass	Pass
10/29/21	Pass	Pass	Pass	Pass
10/30/21	Pass	Pass	Pass	Pass
10/31/21	Pass	Pass	Pass	Pass

Signature: \_\_\_\_\_



Date: \_\_\_\_\_

11-10-21

Print Name: \_\_\_\_\_

Chuck Leffler

Cert. #: \_\_\_\_\_

T-718P FE