

**OHA - Drinking Water Program - Turbidity Monitoring Report Form    County: Linn**  
**Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems**

System Name: ALBANY, CITY OF    ID #: OR4100012    WTP:-WTP-B

Month/Year: 11/2021

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day (1) [NTU]
1	0.01	0.02	0.01	0.02	0.01	0.01	0.02
2	0.01	0.01	0.01	0.01	0.01	0.01	0.01
3	0.01	0.01	0.01	0.02	0.01	0.01	0.02
4	0.01	0.02	0.02	0.01	0.01	0.01	0.02
5	0.01	0.01	0.01	0.01	0.01	0.02	0.02
6	0.02	0.02	0.02	0.02	0.01	0.02	0.02
7	0.02	0.02	0.02	0.02	0.02	0.02	0.02
8	0.02	0.02	0.02	0.02	0.02	0.02	0.02
9	0.01	0.02	0.02	0.02	0.02	0.01	0.02
10	0.02	0.02	0.02	0.01	0.02	0.02	0.02
11	0.02	0.01	0.01	0.02	0.02	0.02	0.02
12	0.02	0.02	0.02	0.02	0.02	0.02	0.02
13	0.02	0.02	0.02	0.02	0.02	0.02	0.02
14	0.02	0.02	0.02	0.01	0.02	0.02	0.02
15	0.02	0.02	0.01	0.02	0.01	0.02	0.02
16	0.01	0.01	0.02	0.02	0.02	0.02	0.02
17	0.02	0.02	0.02	0.02	0.02	0.02	0.02
18	0.01	0.02	0.02	0.02	0.02	0.02	0.02
19	0.01	0.02	0.01	0.01	0.01	0.02	0.02
20	0.01	0.01	0.01	0.01	0.01	0.02	0.02
21	0.01	0.01	0.01	0.01	0.01	0.01	0.01
22	0.01	0.01	0.01	0.01	0.01	0.01	0.01
23	0.02	0.01	0.01	0.01	0.01	0.02	0.02
24	0.02	0.02	0.01	0.01	0.02	0.02	0.02
25	0.02	0.01	0.02	0.02	0.02	0.02	0.02
26	0.02	0.02	0.02	0.02	0.02	0.02	0.02
27	0.02	0.02	0.02	0.02	0.01	0.01	0.02
28	0.01	0.02	0.01	0.01	0.02	0.02	0.02
29	0.02	0.02	0.02	0.02	0.01	0.01	0.02
30	0.01	0.01	0.02	0.02	0.01	0.01	0.02

Membrane Filtration	Monthly Summary (Answer Yes or No)	
95% of turbidity readings <= 1 NTU? (2) <input checked="" type="checkbox"/> Yes / No	CT's met everyday? <input checked="" type="checkbox"/> Yes / No	All CL2 residuals at entry point >= 0.2 mg/l? <input checked="" type="checkbox"/> Yes / No
All daily turbidity readings <= 5 NTU? <input checked="" type="checkbox"/> Yes / No		
Notes:	PRINTED NAME: <i>Chuck Lettler</i>	
	SIGNATURE: <i>[Signature]</i>	DATE: 12-10-21
	PHONE #: 541-990-1907	CERT #: T-7158 FE

(1) Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. (2) Filtered systems only.

## OHA - Drinking Water Program - Surface Water Quality Data Form

**System Name: ALBANY, CITY OF ID #: OR4100012 WTP:-WTP-B**      **Month/Year: 11/2021**

Date / Time	Minimum CL2 Residual @ 1st User (C) (1)	Contact Time (T)	Actual CT	Temp.	pH	Reqd. CT	CT Met? (1)	Peak Hourly Demand Flow (2)
	[ppm or mg/L]	[minutes]	C x T	[°C]		Use tables	Yes / No	[GPM]
1	1.04	250.9	260.9	8.9	8.25	32.5	Y	5,805
2	1.15	233.7	268.8	9.0	8.24	32.6	Y	6,027
3	1.13	211.4	238.9	9.6	8.20	30.7	Y	6,612
4	1.15	288.0	331.2	10.2	8.23	30.0	Y	5,068
5	1.04	298.4	310.3	9.3	8.11	30.0	Y	5,001
6	0.97	283.5	275.0	8.5	8.23	32.9	Y	5,206
7	0.95	236.0	224.2	7.8	8.25	34.6	Y	6,323
8	1.04	212.6	221.1	7.4	8.25	35.9	Y	6,496
9	1.03	224.2	230.9	7.8	8.27	35.1	Y	6,059
10	0.98	220.8	216.4	7.9	8.22	34.2	Y	6,483
11	1.10	262.3	288.5	8.1	8.20	33.9	Y	5,638
12	0.73	149.2	108.9	9.3	8.06	28.4	Y	5,933
13	0.91	251.7	229.0	9.1	8.03	29.1	Y	5,849
14	0.87	213.7	185.9	9.5	8.11	29.2	Y	6,514
15	1.19	219.7	261.4	8.6	8.13	32.3	Y	5,834
16	1.12	199.6	223.6	7.8	8.19	34.6	Y	6,454
17	1.09	258.0	281.2	7.0	8.44	40.0	Y	5,193
18	1.05	255.2	268.0	7.1	8.50	40.4	Y	5,393
19	1.07	259.8	278.0	7.9	8.46	37.7	Y	5,431
20	1.23	274.5	337.6	7.3	8.45	40.0	Y	5,549
21	1.28	229.5	293.8	7.0	8.45	41.0	Y	6,109
22	1.22	221.4	270.1	7.0	8.43	40.5	Y	5,774
23	1.24	219.6	272.3	7.6	8.43	38.9	Y	6,140
24	1.36	214.0	291.0	7.1	8.43	41.0	Y	6,150
25	1.33	262.7	349.4	7.1	8.39	40.3	Y	5,438
26	1.31	252.0	330.1	7.5	8.37	38.7	Y	4,877
27	1.28	260.7	333.7	8.0	8.37	37.2	Y	5,158
28	1.14	209.2	238.5	8.4	8.31	35.0	Y	5,958
29	1.04	258.8	269.2	8.2	8.40	36.1	Y	5,366
30	1.04	213.3	221.8	8.0	8.38	36.2	Y	6,056

Signature: \_\_\_\_\_



Date: \_\_\_\_\_

12-10-21

Print Name: \_\_\_\_\_

Chuck Leffler

Cert #: \_\_\_\_\_

T-7158 FE

(1) If Cl2 at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.  
 (2) Prior to 11/2014, Peak Instantaneous Demand Flow is used.

# Department of Human Services - Drinking Water Section

## Membrane Integrity Report Form

Public Water System Name: Albany

PWS ID#: 41 00012 B


Month/Year:

11/ 2021

Albany/Millersburg Water Plant

Date	Membrane 1	Membrane 2	Membrane 3	Membrane 4
11/01/21	Pass	Pass	Pass	Pass
11/02/21	Pass	Pass	Pass	Pass
11/03/21	Pass	Pass	Pass	Pass
11/04/21	Pass	Pass	Pass	Pass
11/05/21	Pass	Pass	Pass	Pass
11/06/21	Pass	Pass	Pass	Pass
11/07/21	Pass	Pass	Pass	Pass
11/08/21	Pass	Pass	Pass	Pass
11/09/21	Pass	Pass	Pass	Pass
11/10/21	Pass	Pass	Pass	Pass
11/11/21	Pass	Pass	Pass	Pass
11/12/21	Pass	Pass	Pass	Pass
11/13/21	Pass	Pass	Pass	Pass
11/14/21	Pass	Pass	Pass	Pass
11/15/21	Pass	Pass	Pass	Pass
11/16/21	Pass	Pass	Pass	Pass
11/17/21	Pass	Pass	Pass	Pass
11/18/21	Pass	Pass	Pass	Pass
11/19/21	Pass	Pass	Pass	Pass
11/20/21	Pass	Pass	Pass	Pass
11/21/21	Pass	Pass	Pass	Pass
11/22/21	Pass	Pass	Pass	Pass
11/23/21	Pass	Pass	Pass	Pass
11/24/21	Pass	Pass	Pass	Pass
11/25/21	Pass	Pass	Pass	Pass
11/26/21	Pass	Pass	Pass	Pass
11/27/21	Pass	Pass	Pass	Pass
11/28/21	Pass	Pass	Pass	Pass
11/29/21	Pass	Pass	Pass	Pass
11/30/21	Pass	Pass	Pass	Pass

Signature: \_\_\_\_\_



Print Name: \_\_\_\_\_

Chuck Leffler

Date: \_\_\_\_\_

12-10-21

Cert. #: \_\_\_\_\_

T-7158 FE