

# OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Linn

## Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

**System Name: ALBANY, CITY OF ID #: OR4100012 WTP:-WTP-B**

**Month/Year: 12/2021**

DAY	12 AM	4 AM	8 AM	NOON	4 PM	8 PM	Highest Reading of the Day (1)
	[NTU]	[NTU]	[NTU]	[NTU]	[NTU]	[NTU]	[NTU]
1	0.02	0.02	0.02	Plant Off	0.02	0.02	0.02
2	0.02	0.01	0.02	0.02	0.02	0.02	0.02
3	0.02	0.01	0.02	0.02	0.02	0.02	0.02
4	0.02	0.02	0.02	0.02	0.02	0.01	0.02
5	0.01	0.01	0.02	0.01	0.02	0.01	0.02
6	0.01	0.01	0.02	0.01	0.01	0.02	0.02
7	0.01	0.02	0.02	0.02	0.02	0.01	0.02
8	0.01	0.01	0.02	0.02	0.02	0.02	0.02
9	0.02	0.02	0.02	0.02	0.01	0.02	0.02
10	0.02	0.02	0.02	0.02	0.01	0.02	0.02
11	0.02	0.02	0.02	0.02	0.01	0.01	0.02
12	0.01	0.02	0.02	0.02	0.02	0.02	0.02
13	0.02	0.02	0.02	0.02	0.02	0.02	0.02
14	0.02	0.02	0.02	0.01	0.02	0.01	0.02
15	0.02	0.02	0.02	0.02	0.01	0.02	0.02
16	0.02	0.02	0.02	0.02	0.02	0.01	0.02
17	0.02	0.02	0.02	0.02	0.02	0.02	0.02
18	0.02	0.02	0.01	0.01	0.01	0.01	0.02
19	0.01	0.01	0.01	0.02	0.02	0.02	0.02
20	0.02	0.02	0.02	0.02	0.02	0.02	0.02
21	0.02	0.02	0.02	0.01	0.02	0.02	0.02
22	0.02	0.02	0.01	0.02	0.02	0.02	0.02
23	0.02	0.02	0.02	0.02	0.02	0.02	0.02
24	0.02	0.02	0.01	0.01	0.02	0.02	0.02
25	0.02	0.02	0.02	0.02	0.02	0.02	0.02
26	0.02	0.02	0.02	0.02	0.02	0.02	0.02
27	0.02	0.02	0.02	0.02	0.02	0.02	0.02
28	0.02	0.02	0.02	0.02	0.02	0.02	0.02
29	0.02	0.02	0.02	0.02	0.02	0.02	0.02
30	0.02	0.02	0.02	0.02	0.02	0.02	0.02
31	0.02	0.02	0.02	0.02	0.02	0.02	0.02


Membrane Filtration	Monthly Summary (Answer Yes or No)	
95% of turbidity readings <= 1 NTU? (2)	<input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? <input checked="" type="radio"/> Yes / <input type="radio"/> No All CL2 residuals at entry point >= 0.2 mg/l? <input checked="" type="radio"/> Yes / <input type="radio"/> No
All daily turbidity readings <= 5 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	
Notes:	PRINTED NAME: <i>Chuck Leffler</i>	
	SIGNATURE: <i>[Signature]</i>	DATE: <i>1-6-22</i>
	PHONE #: <i>541-990-1907</i>	CERT #: <i>7-7158 FE</i>

(1) Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. (2) Filtered systems only.

## OHA - Drinking Water Program - Surface Water Quality Data Form

**System Name: ALBANY, CITY OF ID #: OR4100012 WTP:-WTP-B** **Month/Year: 12/2021**

Date / Time	Minimum CL2 Residual @ 1st User (C) (1)	Contact Time (T)	Actual CT	Temp.	pH	Reqd. CT	CT Met? (1)	Peak Hourly Demand Flow (2)
	[ppm or mg/L]	[minutes]	C x T	[°C]		Use tables	Yes / No	[GPM]
1	1.17	244.7	286.3	8.0	8.36	36.7	Y	5,028
2	1.20	233.5	280.2	8.0	8.32	36.1	Y	5,149
3	1.24	267.0	331.1	7.5	8.40	38.7	Y	4,852
4	1.28	250.0	320.0	7.4	8.43	39.6	Y	5,055
5	1.29	245.2	316.3	7.2	8.38	39.4	Y	5,790
6	1.26	232.9	293.5	7.0	8.45	41.0	Y	5,287
7	1.18	272.0	321.0	7.3	8.38	38.7	Y	4,682
8	1.04	285.9	297.3	7.5	8.26	36.0	Y	4,798
9	1.04	278.0	289.1	6.5	8.20	37.6	Y	4,985
10	1.17	256.2	299.8	6.4	8.24	39.2	Y	4,428
11	1.24	297.0	368.3	6.5	8.29	39.9	Y	4,022
12	1.16	264.8	307.2	6.3	8.34	40.9	Y	4,134
13	1.04	319.1	331.9	5.8	8.20	39.6	Y	3,812
14	1.22	306.9	374.4	5.4	8.10	40.2	Y	3,784
15	1.21	192.8	233.3	5.6	8.13	39.9	Y	5,004
16	1.29	250.7	323.4	5.9	8.21	40.5	Y	4,631
17	1.37	243.4	333.5	6.2	8.29	41.5	Y	5,282
18	1.31	213.0	279.0	6.1	8.26	41.0	Y	5,314
19	1.29	170.6	220.1	5.6	8.21	41.4	Y	6,450
20	1.09	187.5	204.4	5.7	8.15	39.5	Y	6,097
21	1.09	198.9	216.8	6.0	8.04	37.0	Y	5,752
22	1.07	227.7	243.6	6.1	8.05	36.8	Y	5,284
23	1.33	192.3	255.8	6.0	8.18	40.0	Y	6,780
24	1.34	231.6	310.3	5.5	8.27	43.1	Y	5,327
25	1.40	266.1	372.5	5.1	8.25	44.2	Y	4,836
26	1.35	202.2	273.0	4.4	8.22	45.5	Y	6,788
27	1.34	181.6	243.3	4.1	8.27	47.2	Y	6,126
28	1.33	216.7	288.2	4.2	8.26	46.8	Y	5,512
29	1.26	187.7	236.5	4.3	8.26	46.0	Y	6,580
30	1.26	206.6	260.3	4.3	8.28	46.5	Y	5,938
31	1.27	233.5	296.5	4.3	8.21	45.3	Y	5,378

Signature:   
 Print Name: Charles LeRoyer

Date: 1-6-22  
 Cert #: T-7158 FE

(1) If Cl2 at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.  
 (2) Prior to 11/2014, Peak Instantaneous Demand Flow is used.

# Department of Human Services - Drinking Water Section

## Membrane Integrity Report Form

Public Water System Name: Albany

PWS ID#: 41 00012 B

Month/Year:

12/ 2021

Albany/Millersburg Water Plant

Date	Membrane 1	Membrane 2	Membrane 3	Membrane 4
12/01/21	Pass	Pass	Pass	Pass
12/02/21	Pass	Pass	Pass	Pass
12/03/21	Pass	Pass	Pass	Pass
12/04/21	Pass	Pass	Pass	Pass
12/05/21	Pass	Pass	Pass	Pass
12/06/21	Pass	Pass	Pass	Pass
12/07/21	Pass	Pass	Pass	Pass
12/08/21	Pass	Pass	Pass	Pass
12/09/21	Pass	Pass	Pass	Pass
12/10/21	Pass	Pass	Pass	Pass
12/11/21	Pass	Pass	Pass	Pass
12/12/21	Pass	Pass	Pass	Pass
12/13/21	Pass	Pass	Pass	Pass
12/14/21	Pass	Pass	Pass	Pass
12/15/21	Pass	Pass	Pass	Pass
12/16/21	Pass	Pass	Pass	Pass
12/17/21	Pass	Pass	Pass	Pass
12/18/21	Pass	Pass	Pass	Pass
12/19/21	Pass	Pass	Pass	Pass
12/20/21	Pass	Pass	Pass	Pass
12/21/21	Pass	Pass	Pass	Pass
12/22/21	Pass	Pass	Pass	Pass
12/23/21	Pass	Pass	Pass	Pass
12/24/21	Pass	Pass	Pass	Pass
12/25/21	Pass	Pass	Pass	Pass
12/26/21	Pass	Pass	Pass	Pass
12/27/21	Pass	Pass	Pass	Pass
12/28/21	Pass	Pass	Pass	Pass
12/29/21	Pass	Pass	Pass	Pass
12/30/21	Pass	Pass	Pass	Pass
12/31/21	Pass	Pass	Pass	Pass

Signature: \_\_\_\_\_



Date: \_\_\_\_\_

1-6-22

Print Name: \_\_\_\_\_

Chuck Beffler

Cert. #: \_\_\_\_\_

T-7158 FE