

OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Linn
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

System Name: ALBANY, CITY OF ID #: OR4100012 WTP:-WTP-B

Month/Year: 3/2022

DAY	12 AM	4 AM	8 AM	NOON	4 PM	8 PM	Highest Reading of the Day (1)
	[NTU]	[NTU]	[NTU]	[NTU]	[NTU]	[NTU]	[NTU]
1	0.01	0.01	0.01	0.01	0.01	0.01	0.01
2	0.01	0.01	0.01	Plant Off	0.01	0.02	0.02
3	0.06	0.01	0.01	0.01	0.01	0.01	0.06
4	0.01	0.01	0.01	0.01	0.01	0.01	0.01
5	0.01	0.01	0.01	0.01	0.01	0.01	0.01
6	0.01	0.01	0.01	0.01	0.01	0.01	0.01
7	0.01	0.01	0.01	0.01	0.01	0.01	0.01
8	0.01	0.01	0.01	0.01	0.01	0.01	0.01
9	0.01	0.01	0.01	0.01	0.01	0.01	0.01
10	0.01	0.01	0.01	0.01	0.01	0.01	0.01
11	0.01	0.01	0.01	0.01	0.01	0.01	0.01
12	0.01	0.01	0.01	0.01	0.01	0.01	0.01
13	0.01	0.01	0.01	0.01	Plant Off	0.01	0.01
14	0.07	0.01	0.01	0.01	0.01	0.01	0.07
15	0.01	0.01	0.01	0.01	0.01	0.01	0.01
16	0.01	0.01	0.01	0.01	0.01	0.01	0.01
17	0.01	0.01	0.01	0.01	0.01	0.01	0.01
18	0.01	0.01	0.01	0.01	0.01	0.01	0.01
19	0.01	0.01	0.01	0.01	0.01	0.01	0.01
20	0.01	0.01	0.01	0.01	0.01	0.01	0.01
21	0.01	0.01	0.01	0.01	0.01	0.01	0.01
22	0.01	0.01	0.01	0.01	0.01	0.10	0.10
23	0.14	0.04	0.01	0.01	0.10	0.16	0.16
24	0.01	0.01	0.01	0.01	0.01	0.01	0.01
25	0.01	0.01	0.01	0.01	0.01	0.01	0.01
26	0.01	0.01	0.01	0.01	0.01	0.01	0.01
27	0.01	0.01	0.01	0.01	0.01	0.01	0.01
28	0.01	0.01	0.01	0.01	0.01	0.01	0.01
29	0.01	0.01	0.01	0.01	0.01	0.01	0.01
30	0.01	0.01	0.01	0.01	0.01	0.01	0.01
31	0.01	0.01	0.01	0.01	0.01	0.01	0.01

Membrane Filtration	Monthly Summary (Answer Yes or No)	
95% of turbidity readings <= 1 NTU? (2) <input checked="" type="radio"/> Yes / No	CT's met everyday? <input checked="" type="radio"/> Yes / No	All CL2 residuals at entry point >= 0.2 mg/l? <input checked="" type="radio"/> Yes / No
All daily turbidity readings <= 5 NTU? <input checked="" type="radio"/> Yes / No	Notes:	
PRINTED NAME: <i>Chuck Leffler</i>		DATE: <i>4-7-22</i>
SIGNATURE: <i>[Signature]</i>		CERT #: <i>7-715356</i>
PHONE #: <i>541-990-1907</i>		

(1) Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. (2) Filtered systems only.

OHA - Drinking Water Program - Surface Water Quality Data Form

System Name: ALBANY, CITY OF ID #: OR4100012 WTP:-WTP-B	Month/Year: 3/2022
---	--------------------

Date / Time	Minimum CL2 Residual @ 1st User (C) (1)	Contact Time (T)	Actual CT	Temp.	pH	Reqd. CT	CT Met? (1)	Peak Hourly Demand Flow (2)
	[ppm or mg/L]	[minutes]	C x T	[°C]		Use tables	Yes / No	[GPM]
1	OFFLINE	197.0		6.3	8.16	33.2		4,722
2	1.04	178.5	185.6	6.5	8.24	38.4	Y	4,758
3	0.91	223.2	203.1	6.1	8.20	38.2	Y	3,906
4	0.95	188.2	178.8	5.1	8.14	40.1	Y	4,651
5	1.24	239.7	297.2	4.9	8.32	45.2	Y	3,791
6	1.15	185.1	212.9	4.7	8.16	42.5	Y	5,160
7	1.13	200.7	226.8	4.6	8.13	42.4	Y	4,180
8	1.11	178.9	198.6	5.1	8.19	41.5	Y	5,127
9	1.07	169.3	181.2	5.3	8.28	42.4	Y	4,538
10	1.00	186.3	186.3	4.4	8.40	46.9	Y	4,087
11	1.02	201.5	205.5	4.2	8.36	46.6	Y	4,368
12	1.06	209.7	222.3	4.8	8.38	45.3	Y	4,496
13	OFFLINE	164.8		5.5	8.35	37.7		4,548
14	0.88	175.4	154.4	5.9	8.27	39.7	Y	4,548
15	0.63	209.4	131.9	6.5	8.35	37.9	Y	4,473
16	1.00	171.8	171.8	6.4	8.35	39.9	Y	4,454
17	1.07	195.7	209.4	6.0	8.47	43.3	Y	4,381
18	1.17	213.6	249.9	6.1	8.50	44.0	Y	4,144
19	1.12	228.3	255.7	6.6	8.51	42.4	Y	4,210
20	0.90	238.2	214.4	5.7	8.37	41.7	Y	3,820
21	1.12	75.1	84.1	5.7	8.31	42.0	Y	4,028
22	1.06	204.9	217.2	6.5	8.30	39.1	Y	4,166
23	0.93	213.6	198.6	8.0	8.41	36.1	Y	4,021
24	1.03	213.6	220.0	7.3	8.38	37.9	Y	4,771
25	1.05	215.6	226.4	7.5	8.46	38.8	Y	4,549
26	1.15	256.2	294.6	8.3	8.53	38.1	Y	4,019
27	1.10	254.6	280.1	9.0	8.49	35.5	Y	4,338
28	1.08	244.2	263.7	8.5	8.36	35.1	Y	4,669
29	1.15	276.1	317.5	8.1	8.34	36.0	Y	4,142
30	1.11	219.7	243.9	8.2	8.37	36.0	Y	4,639
31	1.06	259.6	275.2	7.4	8.48	39.2	Y	4,337

Signature: _____



Date: _____

4-7-22

Print Name: _____

Chuck Leffler

Cert #: _____

I-7158 FE

(1) If Cl2 at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.
 (2) Prior to 11/2014, Peak Instantaneous Demand Flow is used.

Department of Human Services - Drinking Water Section

Membrane Integrity Report Form

Public Water System Name: Albany

PWS ID#: 41 00012 B

Month/Year:

3/ 2022

Albany/Millersburg Water Plant

Date	Membrane 1	Membrane 2	Membrane 3	Membrane 4
03/01/22	Pass	Pass	Pass	Pass
03/02/22	Pass	Pass	Pass	Pass
03/03/22	Pass	Pass	Pass	Pass
03/04/22	Pass	Pass	Pass	Pass
03/05/22	Pass	Pass	Pass	Pass
03/06/22	Pass	Pass	Pass	Pass
03/07/22	Pass	Pass	Pass	Pass
03/08/22	Pass	Pass	Pass	Pass
03/09/22	Pass	Pass	Pass	Pass
03/10/22	Pass	Pass	Pass	Pass
03/11/22	Pass	Pass	Pass	Pass
03/12/22	Pass	Pass	Pass	Pass
03/13/22	Pass	Pass	Pass	Pass
03/14/22	Pass	Pass	Pass	Pass
03/15/22	Pass	Pass	Pass	Pass
03/16/22	Pass	Pass	Pass	Pass
03/17/22	Pass	Pass	Pass	Pass
03/18/22	Pass	Pass	Pass	Pass
03/19/22	Pass	Pass	Pass	Pass
03/20/22	Pass	Pass	Pass	Pass
03/21/22	Pass	Pass	Pass	Pass
03/22/22	Pass	Pass	Pass	Pass
03/23/22	Pass	Pass	Pass	Pass
03/24/22	Pass	Pass	Pass	Pass
03/25/22	Pass	Pass	Pass	Pass
03/26/22	Pass	Pass	Pass	Pass
03/27/22	Pass	Pass	Pass	Pass
03/28/22	Pass	Pass	Pass	Pass
03/29/22	Pass	Pass	Pass	Pass
03/30/22	Pass	Pass	Pass	Pass
03/31/22	Pass	Pass	Pass	Pass

Signature: 

Date: 4-7-22

Print Name: Chuck LePier

Cert. #: T-7158 FE