

OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Linn
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

System Name: ALBANY, CITY OF ID #: OR4100012 WTP:-WTP-B

Month/Year: 4/2022

DAY	12 AM	4 AM	8 AM	NOON	4 PM	8 PM	Highest Reading of the Day (1)
	[NTU]	[NTU]	[NTU]	[NTU]	[NTU]	[NTU]	[NTU]
1	0.01	0.01	0.01	0.01	0.01	0.01	0.01
2	0.01	0.01	0.01	0.01	0.01	0.01	0.01
3	0.01	0.01	0.01	0.01	0.01	0.01	0.01
4	0.01	0.01	0.01	0.01	Plant Off	0.08	0.08
5	0.01	0.01	0.01	0.01	0.01	0.01	0.01
6	0.01	0.01	0.01	0.01	0.01	0.01	0.01
7	0.01	0.01	0.01	0.01	0.01	0.01	0.01
8	0.01	0.01	0.01	0.01	0.01	0.01	0.01
9	0.01	0.01	0.01	0.01	0.01	0.01	0.01
10	0.01	0.01	0.01	0.01	0.01	0.01	0.01
11	0.01	0.01	0.01	0.01	0.01	0.01	0.01
12	0.01	0.01	0.01	0.01	0.01	0.01	0.01
13	0.01	0.01	0.01	0.01	0.01	0.01	0.01
14	0.01	0.01	0.01	0.01	0.01	0.01	0.01
15	0.01	0.01	0.01	0.01	0.01	0.01	0.01
16	0.01	0.01	0.01	0.01	0.01	0.01	0.01
17	0.01	0.01	0.01	0.01	0.01	0.01	0.01
18	0.01	0.01	0.01	0.01	0.01	0.01	0.01
19	0.01	0.01	0.01	0.01	0.01	0.01	0.01
20	0.01	0.01	0.01	0.01	0.01	0.01	0.01
21	0.01	0.01	0.01	0.01	0.01	0.01	0.01
22	0.01	0.01	0.01	0.01	0.01	0.01	0.01
23	0.01	0.01	0.01	0.01	0.01	0.01	0.01
24	0.01	0.01	0.01	0.01	0.01	0.01	0.01
25	0.01	0.01	0.01	0.01	0.01	0.01	0.01
26	0.01	0.01	0.01	0.01	0.01	0.01	0.01
27	0.01	0.01	0.01	0.01	0.01	0.01	0.01
28	0.01	0.01	0.01	0.01	0.01	0.01	0.01
29	0.01	0.01	0.01	0.01	0.01	0.01	0.01
30	0.01	0.01	0.01	0.01	0.01	0.01	0.01

Membrane Filtration	Monthly Summary (Answer Yes or No)	
95% of turbidity readings <= 1 NTU? (2) <input checked="" type="radio"/> Yes / No	CT's met everyday? <input checked="" type="radio"/> Yes / No	All CL2 residuals at entry point >= 0.2 mg/l? <input checked="" type="radio"/> Yes / No
All daily turbidity readings <= 5 NTU? <input checked="" type="radio"/> Yes / No		
Notes: 4/9/22 - Slight bump in turb, after plant startup after powder bump. AK;	PRINTED NAME: <u>Chuck Leffler</u>	DATE: <u>5-6-22</u>
	SIGNATURE: <u>[Signature]</u>	CERT #: <u>T-7158 FE</u>
	PHONE #: <u>541-990-1907</u>	

(1) Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. (2) Filtered systems only.

OHA - Drinking Water Program - Surface Water Quality Data Form

System Name: ALBANY, CITY OF ID #: OR4100012 WTP--WTP-B **Month/Year: 4/2022**

Date / Time	Minimum CL2 Residual @ 1st User (C) (1)	Contact Time (T)	Actual CT	Temp.	pH	Reqd. CT	CT Met? (1)	Peak Hourly Demand Flow (2)
	[ppm or mg/L]	[minutes]	C x T	[°C]		Use tables	Yes / No	[GPM]
1	1.04	245.2	255.0	7.4	8.46	39.0	Y	4,854
2	1.02	209.6	213.8	8.1	8.58	38.6	Y	5,105
3	1.04	183.6	190.9	8.1	8.38	36.2	Y	4,846
4	0.97	134.2	130.2	8.1	8.47	37.0	Y	4,670
5	0.71	202.0	143.4	6.5	8.38	38.6	Y	4,610
6	0.84	176.2	148.0	6.6	8.47	40.4	Y	5,135
7	1.09	205.2	223.7	7.5	8.52	39.7	Y	4,702
8	1.11	175.6	194.9	8.6	8.33	34.6	Y	4,351
9	1.09	187.7	204.6	7.6	8.27	36.1	Y	4,397
10	1.09	218.8	238.5	6.7	8.32	39.1	Y	4,471
11	0.98	197.8	193.8	6.2	8.32	39.8	Y	4,438
12	0.86	226.1	194.4	5.5	8.27	40.5	Y	4,473
13	0.48	202.3	97.1	5.3	8.22	38.6	Y	4,673
14	0.75	179.3	134.5	5.6	8.18	38.4	Y	5,191
15	1.14	196.1	223.6	5.3	8.42	44.9	Y	4,146
16	1.10	228.6	251.5	6.5	8.54	42.9	Y	4,521
17	1.13	225.8	255.2	5.5	8.37	43.4	Y	4,246
18	1.10	233.4	256.7	6.4	8.47	42.2	Y	4,491
19	1.09	238.0	259.4	6.0	8.19	39.0	Y	4,482
20	0.98	181.2	177.6	5.8	8.32	41.0	Y	4,560
21	1.00	230.9	230.9	6.1	8.17	38.1	Y	4,534
22	1.07	240.5	257.3	6.2	8.14	37.7	Y	4,253
23	1.03	227.7	234.5	6.6	8.34	39.2	Y	4,689
24	1.04	166.1	172.7	7.2	8.42	38.8	Y	5,859
25	1.04	196.2	204.0	7.6	8.32	36.4	Y	4,540
26	1.09	207.9	226.6	7.3	8.20	35.9	Y	4,689
27	1.10	191.2	210.3	7.0	8.32	38.3	Y	4,909
28	1.10	208.7	229.6	7.2	8.34	38.0	Y	3,924
29	1.08	233.1	251.7	7.4	8.36	37.6	Y	4,252
30	1.07	207.7	222.2	8.0	8.27	35.1	Y	4,540

Signature: _____

[Handwritten Signature]

Date: _____

5-6-22

Print Name: _____

Chuck Leffler

Cert #: _____

T-7158 FE

(1) If Cl2 at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.
 (2) Prior to 11/2014, Peak Instantaneous Demand Flow is used.

Department of Human Services - Drinking Water Section

Membrane Integrity Report Form

Public Water System Name: Albany

PWS ID#: 41 00012 B

Month/Year:

4/ 2022

Albany/Millersburg Water Plant

Date	Membrane 1	Membrane 2	Membrane 3	Membrane 4
04/01/22	Pass	Pass	Pass	Pass
04/02/22	Pass	Pass	Pass	Pass
04/03/22	Pass	Pass	Pass	Pass
04/04/22	Pass	Pass	Pass	Pass
04/05/22	Pass	Pass	Pass	Pass
04/06/22	Pass	Pass	Pass	Pass
04/07/22	Pass	Pass	Pass	Pass
04/08/22	Pass	Pass	Pass	Pass
04/09/22	Pass	Pass	Pass	Pass
04/10/22	Pass	Pass	Pass	Pass
04/11/22	Pass	Pass	Pass	Pass
04/12/22	Pass	Pass	Pass	Pass
04/13/22	Pass	Pass	Pass	Pass
04/14/22	Pass	Pass	Pass	Pass
04/15/22	Pass	Pass	Pass	Pass
04/16/22	Pass	Pass	Pass	Pass
04/17/22	Pass	Pass	Pass	Pass
04/18/22	Pass	Pass	Pass	Pass
04/19/22	Pass	Pass	Pass	Pass
04/20/22	Pass	Pass	Pass	Pass
04/21/22	Pass	Pass	Pass	Pass
04/22/22	Pass	Pass	Pass	Pass
04/23/22	Pass	Pass	Pass	Pass
04/24/22	Pass	Pass	Pass	Pass
04/25/22	Pass	Pass	Pass	Pass
04/26/22	Pass	Pass	Pass	Pass
04/27/22	Pass	Pass	Pass	Pass
04/28/22	Pass	Pass	Pass	Pass
04/29/22	Pass	Pass	Pass	Pass
04/30/22	Pass	Pass	Pass	Pass

Signature: _____



Date: _____

5-6-22

Print Name: _____

Chuck Leffler

Cert. #: _____

T-7158 FE