

OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Linn
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

System Name: ALBANY, CITY OF ID #: OR4100012 WTP:-WTP-B

Month/Year: 5/2022

DAY	12 AM	4 AM	8 AM	NOON	4 PM	8 PM	Highest Reading of the Day (1)
	[NTU]	[NTU]	[NTU]	[NTU]	[NTU]	[NTU]	[NTU]
1	0.01	0.01	0.01	0.01	0.01	0.01	0.01
2	0.01	0.01	0.01	0.01	0.01	0.01	0.01
3	0.01	0.01	0.01	0.01	0.01	0.01	0.01
4	0.01	0.01	0.01	0.01	0.01	0.02	0.02
5	0.01	0.01	0.01	0.01	0.01	0.01	0.01
6	0.01	0.01	0.01	0.01	0.01	0.01	0.01
7	0.01	0.01	0.01	0.01	0.01	0.01	0.01
8	0.01	0.01	0.01	0.01	0.01	0.01	0.01
9	0.01	0.01	0.01	0.01	0.01	0.01	0.01
10	0.01	0.01	0.01	0.01	0.01	0.01	0.01
11	0.01	0.01	0.01	0.01	0.01	0.01	0.01
12	0.01	0.01	0.01	0.01	0.01	0.01	0.01
13	0.01	0.01	0.01	0.01	0.01	0.01	0.01
14	0.01	0.01	0.01	0.01	0.01	0.01	0.01
15	0.01	0.01	0.01	0.01	0.01	0.01	0.01
16	0.01	0.01	0.01	0.01	0.01	0.01	0.01
17	0.01	0.01	0.01	0.01	0.01	0.01	0.01
18	0.01	0.01	0.01	0.01	0.01	0.01	0.01
19	0.01	0.01	0.01	0.01	0.01	0.01	0.01
20	0.01	0.01	0.01	0.01	0.01	0.01	0.01
21	0.01	0.01	0.01	0.01	0.01	0.01	0.01
22	0.01	0.01	0.01	0.01	0.01	0.01	0.01
23	0.01	0.01	0.01	0.01	0.01	0.01	0.01
24	0.01	0.01	0.01	0.01	0.01	0.01	0.01
25	0.01	0.01	0.01	0.01	0.01	0.01	0.01
26	0.01	0.01	0.01	0.01	0.01	0.02	0.02
27	0.01	0.01	0.01	0.01	0.01	0.01	0.01
28	0.01	0.01	0.01	0.01	0.01	0.01	0.01
29	0.01	0.01	0.01	0.01	0.01	0.01	0.01
30	0.01	0.01	0.01	0.01	0.01	0.01	0.01
31	0.01	0.01	0.01	0.01	0.01	0.01	0.01

Membrane Filtration		Monthly Summary (Answer Yes or No)	
95% of turbidity readings <= 1 NTU? (2)	<input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday?	All CL2 residuals at entry point >= 0.2 mg/l?
All daily turbidity readings <= 5 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No
Notes:		PRINTED NAME: <i>Chuck Leffler</i>	
		SIGNATURE: <i>[Signature]</i>	DATE: 6-3-22
		PHONE #: 541-990-1907	CERT #: T-7158 FE


(1) Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. (2) Filtered systems only.

OHA - Drinking Water Program - Surface Water Quality Data Form

System Name: ALBANY, CITY OF ID #: OR4100012 WTP:-WTP-B Month/Year: 5/2022

Date / Time	Minimum CL2 Residual @ 1st User (C) (1)	Contact Time (T)	Actual CT	Temp.	pH	Reqd. CT	CT Met? (1)	Peak Hourly Demand Flow (2)
	[ppm or mg/L]	[minutes]	C x T	[°C]		Use tables	Yes / No	[GPM]
1	0.94	199.9	187.9	7.0	8.19	35.9	Y	4,732
2	1.02	221.0	225.4	7.4	8.26	36.3	Y	4,291
3	0.96	260.0	249.6	6.8	8.19	36.5	Y	4,205
4	0.95	204.6	194.4	7.0	8.29	37.1	Y	5,135
5	1.03	216.6	223.1	7.9	8.35	36.1	Y	4,361
6	0.93	200.6	186.6	7.6	8.16	34.0	Y	4,993
7	1.09	231.1	251.9	7.1	8.12	35.3	Y	4,146
8	1.11	227.2	252.2	6.0	8.13	38.3	Y	4,289
9	1.20	207.6	249.1	5.7	8.10	39.1	Y	4,646
10	1.18	160.5	189.4	5.9	8.12	38.7	Y	5,890
11	1.24	205.8	255.2	5.9	8.21	40.2	Y	4,519
12	1.12	164.2	183.9	6.1	8.23	39.6	Y	4,772
13	0.90	189.0	170.1	5.9	8.16	38.1	Y	5,144
14	1.11	184.2	204.5	6.7	8.27	38.4	Y	5,012
15	0.98	175.2	171.7	6.9	8.31	37.8	Y	4,986
16	1.11	218.5	242.5	7.0	8.31	38.2	Y	4,044
17	1.06	225.0	238.5	7.0	8.24	37.1	Y	4,643
18	1.04	256.3	266.6	7.4	8.18	35.3	Y	4,109
19	1.09	231.8	252.7	7.6	8.18	35.0	Y	4,873
20	1.04	204.4	212.6	6.9	8.31	38.1	Y	5,126
21	1.00	219.2	219.2	7.6	8.31	36.1	Y	5,280
22	0.98	240.2	235.4	9.1	8.33	32.8	Y	4,999
23	0.99	287.5	284.6	10.2	8.26	29.6	Y	4,687
24	1.02	239.7	244.5	10.7	8.21	28.3	Y	5,260
25	1.01	192.6	194.5	10.7	8.27	29.0	Y	5,645
26	1.05	234.4	246.1	11.0	8.44	30.3	Y	4,976
27	1.08	279.9	302.3	9.6	8.35	32.4	Y	4,338
28	1.03	273.7	281.9	8.6	8.48	36.1	Y	4,477
29	1.01	269.2	271.9	8.3	8.50	37.0	Y	4,617
30	0.83	280.2	232.6	8.1	8.44	36.0	Y	4,770
31	0.87	226.8	197.3	8.4	8.50	36.2	Y	5,624

Signature: _____



Date: _____

6-3-22

Print Name: _____

Chuck Lettler

Cert #: _____

T-7158 FE

(1) If Cl2 at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.
 (2) Prior to 11/2014, Peak Instantaneous Demand Flow is used.

Department of Human Services - Drinking Water Section

Membrane Integrity Report Form

Public Water System Name: Albany

PWS ID#: 41 00012 B

Month/Year:

5/ 2022

Albany/Millersburg Water Plant

Date	Membrane 1	Membrane 2	Membrane 3	Membrane 4
05/01/22	Pass	Pass	Pass	Pass
05/02/22	Pass	Pass	Pass	Pass
05/03/22	Pass	Pass	Pass	Pass
05/04/22	Pass	Pass	Pass	Pass
05/05/22	Pass	Pass	Pass	Pass
05/06/22	Pass	Pass	Pass	Pass
05/07/22	Pass	Pass	Pass	Pass
05/08/22	Pass	Pass	Pass	Pass
05/09/22	Pass	Pass	Pass	Pass
05/10/22	Pass	Pass	Pass	Pass
05/11/22	Pass	Pass	Pass	Pass
05/12/22	Pass	Pass	Pass	Pass
05/13/22	Pass	Pass	Pass	Pass
05/14/22	Pass	Pass	Pass	Pass
05/15/22	Pass	Pass	Pass	Pass
05/16/22	Pass	Pass	Pass	Pass
05/17/22	Pass	Pass	Pass	Pass
05/18/22	Pass	Pass	Pass	Pass
05/19/22	Pass	Pass	Pass	Pass
05/20/22	Pass	Pass	Pass	Pass
05/21/22	Pass	Pass	Pass	Pass
05/22/22	Pass	Pass	Pass	Pass
05/23/22	Pass	Pass	Pass	Pass
05/24/22	Pass	Pass	Pass	Pass
05/25/22	Pass	Pass	Pass	Pass
05/26/22	Pass	Pass	Pass	Pass
05/27/22	Pass	Pass	Pass	Pass
05/28/22	Pass	Pass	Pass	Pass
05/29/22	Pass	Pass	Pass	Pass
05/30/22	Pass	Pass	Pass	Pass
05/31/22	Pass	Pass	Pass	Pass

Signature: _____



Date: _____

6-3-22

Print Name: _____

Chuck LeBlond

Cert. #: _____

T-7158 FE