

**OHA - Drinking Water Program - Turbidity Monitoring Report Form    County: Linn**  
**Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems**

System Name: ALBANY, CITY OF    ID #: OR4100012    WTP:-WTP-B

Month/Year: 6/2022

DAY	12 AM	4 AM	8 AM	NOON	4 PM	8 PM	Highest Reading of the Day (1)
	[NTU]	[NTU]	[NTU]	[NTU]	[NTU]	[NTU]	[NTU]
1	0.01	0.01	Plant Off	Plant Off	0.01	0.01	0.01
2	0.01	0.01	0.01	0.01	0.01	0.01	0.01
3	0.01	0.01	0.01	0.01	0.01	0.01	0.01
4	0.01	0.01	0.01	0.01	0.01	0.01	0.01
5	0.01	0.01	0.01	0.01	0.01	0.01	0.01
6	0.01	0.01	0.01	0.01	0.01	0.01	0.01
7	0.01	0.01	0.01	0.01	0.01	0.01	0.01
8	0.01	0.01	0.01	0.01	0.01	0.01	0.01
9	0.01	0.01	0.01	0.01	0.01	0.01	0.01
10	0.01	0.01	0.01	0.01	0.01	0.01	0.01
11	0.01	0.01	0.01	0.01	0.01	0.01	0.01
12	0.01	0.01	0.01	0.01	0.01	0.01	0.01
13	0.01	0.01	0.01	0.01	0.01	0.01	0.01
14	0.01	0.01	0.01	0.01	0.01	0.01	0.01
15	0.01	0.01	0.01	0.01	0.01	0.01	0.01
16	0.01	0.01	0.01	0.01	0.01	0.01	0.01
17	0.01	0.01	0.01	0.01	0.01	0.01	0.01
18	0.01	0.01	0.01	0.01	0.01	0.01	0.01
19	0.01	0.01	0.01	0.01	0.01	0.01	0.01
20	0.01	0.01	0.01	0.01	0.01	0.01	0.01
21	0.01	0.01	0.01	0.01	0.01	0.01	0.01
22	0.01	0.01	0.01	0.01	0.01	0.01	0.01
23	0.01	0.01	0.01	0.01	0.01	0.01	0.01
24	0.01	0.01	0.01	0.01	0.01	0.01	0.01
25	0.01	0.01	0.01	0.01	0.01	0.01	0.01
26	0.01	0.01	0.01	0.01	0.01	0.01	0.01
27	0.01	0.01	0.01	0.01	0.01	0.01	0.01
28	0.01	0.01	0.01	0.01	0.01	0.01	0.01
29	0.01	0.01	0.01	Plant Off	0.01	0.01	0.01
30	0.01	0.01	0.01	0.01	0.01	0.01	0.01

Membrane Filtration	Monthly Summary (Answer Yes or No)	
95% of turbidity readings <= 1 NTU? (2) <input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? <input checked="" type="radio"/> Yes / <input type="radio"/> No	All CL2 residuals at entry point >= 0.2 mg/l? <input checked="" type="radio"/> Yes / <input type="radio"/> No
All daily turbidity readings <= 5 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No	Notes:	
PRINTED NAME: <i>Chuck Leffler</i>		DATE: <i>7-7-22</i>
SIGNATURE: <i>[Signature]</i>		CERT #: <i>F7158FE</i>
PHONE #:		

(1) Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. (2) Filtered systems only.

## OHA - Drinking Water Program - Surface Water Quality Data Form

**System Name: ALBANY, CITY OF ID #: OR4100012 WTP:-WTP-B**      **Month/Year: 6/2022**

Date / Time	Minimum CL2 Residual @ 1st User (C) (1)	Contact Time (T)	Actual CT	Temp.	pH	Reqd. CT	CT Met? (1)	Peak Hourly Demand Flow (2)
	[ppm or mg/L]	[minutes]	C x T	[°C]		Use tables	Yes / No	[GPM]
1	1.01	208.7	210.8	9.6	8.50	33.9	Y	5,239
2	1.01	220.3	222.5	9.1	8.46	34.4	Y	5,416
3	1.01	256.5	259.1	9.3	8.37	32.8	Y	5,024
4	1.09	309.7	337.6	8.6	8.33	34.3	Y	4,486
5	1.02	277.5	283.1	9.2	8.28	32.1	Y	4,642
6	0.91	297.3	270.5	8.9	8.32	33.0	Y	5,010
7	0.93	234.4	218.0	8.3	8.30	34.1	Y	5,468
8	0.89	157.1	139.8	8.6	8.39	34.4	Y	5,842
9	0.96	177.0	169.9	8.9	8.40	33.9	Y	5,468
10	1.09	238.1	259.5	9.8	8.43	32.8	Y	4,381
11	0.73	301.4	220.0	9.5	8.39	31.7	Y	4,199
12	0.71	263.6	187.2	8.6	8.19	31.3	Y	4,887
13	1.17	298.1	348.8	8.1	8.33	36.0	Y	5,010
14	1.12	237.3	265.8	8.0	8.22	34.5	Y	5,472
15	1.10	225.5	248.1	8.0	8.22	34.6	Y	5,520
16	1.09	283.8	309.3	9.8	8.22	30.4	Y	4,623
17	0.98	258.4	253.2	11.7	10.87	70.4	Y	5,053
18	0.88	283.3	249.3	18.1	8.21	17.1	Y	4,902
19	0.85	252.0	214.2	8.8	8.34	33.2	Y	5,511
20	0.89	245.1	218.1	8.9	8.28	32.4	Y	5,175
21	1.00	209.2	209.2	9.7	8.26	30.9	Y	6,731
22	0.98	288.5	282.7	11.5	8.23	26.8	Y	5,303
23	0.92	218.0	200.6	12.0	8.14	25.1	Y	6,192
24	0.91	187.8	170.9	11.4	8.26	27.1	Y	6,713
25	0.99	194.3	192.4	12.3	8.46	27.7	Y	6,548
26	1.08	181.8	196.3	13.6	8.21	23.5	Y	6,672
27	1.02	163.5	166.8	14.3	8.19	22.2	Y	6,813
28	1.00	168.4	168.4	14.1	8.20	22.6	Y	6,537
29	0.97	179.9	174.5	13.3	8.30	24.4	Y	7,520
30	1.01	155.2	156.8	12.8	8.42	26.6	Y	7,667

Signature:   
 Print Name: Chuck Leffler

Date: 7-7-22  
 Cert #: T-71SP FE

(1) If Cl2 at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.  
 (2) Prior to 11/2014, Peak Instantaneous Demand Flow is used.

# Department of Human Services - Drinking Water Section

## Membrane Integrity Report Form

Public Water System Name: Albany

PWS ID#: 41 00012 B

Month/Year:

6/ 2022

Albany/Millersburg Water Plant

Date	Membrane 1	Membrane 2	Membrane 3	Membrane 4
06/01/22	Pass	Pass	Pass	Pass
06/02/22	Pass	Pass	Pass	Pass
06/03/22	Pass	Pass	Pass	Pass
06/04/22	Pass	Pass	Pass	Pass
06/05/22	Pass	Pass	Pass	Pass
06/06/22	Pass	Pass	Pass	Pass
06/07/22	Pass	Pass	Pass	Pass
06/08/22	Pass	Pass	Pass	Pass
06/09/22	Pass	Pass	Pass	Pass
06/10/22	Pass	Pass	Pass	Pass
06/11/22	Pass	Pass	Pass	Pass
06/12/22	Pass	Pass	Pass	Pass
06/13/22	Pass	Pass	Pass	Pass
06/14/22	Pass	Pass	Pass	Pass
06/15/22	Pass	Pass	Pass	Pass
06/16/22	Pass	Pass	Pass	Pass
06/17/22	Pass	Pass	Pass	Pass
06/18/22	Pass	Pass	Pass	Pass
06/19/22	Pass	Pass	Pass	Pass
06/20/22	Pass	Pass	Pass	Pass
06/21/22	Pass	Pass	Pass	Pass
06/22/22	Pass	Pass	Pass	Pass
06/23/22	Pass	Pass	Pass	Pass
06/24/22	Pass	Pass	Pass	Pass
06/25/22	Pass	Pass	Pass	Pass
06/26/22	Pass	Pass	Pass	Pass
06/27/22	Pass	Pass	Pass	Pass
06/28/22	Pass	Pass	Pass	Pass
06/29/22	Pass	Pass	Pass	Pass
06/30/22	Pass	Pass	Pass	Pass

Signature: \_\_\_\_\_



Date: \_\_\_\_\_

7-7-22

Print Name: \_\_\_\_\_

Chuck Leffler

Cert. #: \_\_\_\_\_

T-7158 FE