

**OHA - Drinking Water Program - Turbidity Monitoring Report Form    County: Linn**  
**Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems**

System Name: ALBANY, CITY OF    ID #: OR4100012    WTP:-WTP-B

Month/Year: 7/2022

DAY	12 AM	4 AM	8 AM	NOON	4 PM	8 PM	Highest Reading of the Day (1)
	[NTU]	[NTU]	[NTU]	[NTU]	[NTU]	[NTU]	[NTU]
1	0.01	0.01	0.01	0.01	0.01	0.04	0.04
2	0.01	0.01	0.01	0.01	0.01	0.01	0.01
3	0.01	0.01	0.01	0.01	0.01	0.01	0.01
4	0.01	0.01	0.01	0.01	0.01	0.01	0.01
5	0.01	0.01	0.01	0.01	0.01	0.01	0.01
6	0.01	0.01	0.01	0.01	0.01	0.01	0.01
7	0.01	0.01	0.01	0.01	0.01	0.01	0.01
8	0.01	0.01	0.01	0.01	0.01	0.01	0.01
9	0.01	0.01	0.01	0.01	0.01	0.01	0.01
10	0.01	0.01	0.01	0.01	0.01	0.01	0.01
11	0.01	0.01	0.01	0.01	0.01	0.01	0.01
12	0.01	0.01	0.01	0.01	0.01	0.01	0.01
13	0.01	0.01	0.01	0.01	0.01	0.01	0.01
14	0.01	0.01	0.01	0.01	0.01	0.01	0.01
15	0.01	0.01	0.01	0.01	0.01	0.01	0.01
16	0.01	0.01	0.01	0.01	0.01	0.01	0.01
17	0.01	0.01	0.01	0.01	0.01	0.01	0.01
18	0.01	0.01	0.01	0.01	0.01	0.01	0.01
19	0.01	0.01	0.01	0.01	0.01	0.03	0.03
20	0.01	0.01	0.01	0.01	0.01	0.01	0.01
21	0.01	0.01	0.01	0.01	0.01	0.01	0.01
22	0.01	0.01	0.01	0.01	0.01	0.01	0.01
23	0.01	0.01	0.01	0.01	0.01	0.01	0.01
24	0.01	0.01	0.01	0.01	0.01	0.01	0.01
25	0.01	0.01	0.01	0.01	0.01	Plant Off	0.01
26	0.01	0.01	0.01	0.01	0.01	0.02	0.02
27	0.01	0.01	0.01	0.01	0.01	0.01	0.01
28	0.01	0.01	0.01	0.01	0.01	0.01	0.01
29	0.01	0.01	0.01	0.01	0.01	0.01	0.01
30	0.01	0.01	0.01	0.01	0.01	0.01	0.01
31	Plant Off	0.02	0.01	0.01	0.01	0.01	0.02

Membrane Filtration	Monthly Summary (Answer Yes or No)	
95% of turbidity readings <= 1 NTU? (2) <input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? <input checked="" type="radio"/> Yes / <input type="radio"/> No	All CL2 residuals at entry point >= 0.2 mg/l? <input checked="" type="radio"/> Yes / <input type="radio"/> No
All daily turbidity readings <= 5 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No		
Notes:	PRINTED NAME: <i>Chuck Leffler</i>	
	SIGNATURE: <i>[Signature]</i>	DATE: <i>8-10-22</i>
	PHONE #: <i>541-990-1907</i>	CERT #: <i>T-7158 FE</i>

(1) Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. (2) Filtered systems only.

## OHA - Drinking Water Program - Surface Water Quality Data Form

**System Name: ALBANY, CITY OF ID #: OR4100012 WTP:-WTP-B**      **Month/Year: 7/2022**

Date / Time	Minimum CL2 Residual @ 1st User (C) (1) [ppm or mg/L]	Contact Time (T) [minutes]	Actual CT C x T	Temp. [°C]	pH	Reqd. CT Use tables	CT Met? (1) Yes / No	Peak Hourly Demand Flow (2) [GPM]
1	1.07	180.2	192.8	13.5	8.42	25.5	Y	7,201
2	0.98	194.7	190.8	13.4	8.41	25.5	Y	7,145
3	0.97	188.7	183.0	12.9	8.41	26.2	Y	7,381
4	0.98	197.6	193.6	12.7	8.51	27.7	Y	7,200
5	0.93	261.5	243.2	14.3	8.52	24.8	Y	5,544
6	1.04	248.7	258.6	14.1	8.37	24.1	Y	6,065
7	0.98	225.2	220.7	14.1	8.40	24.2	Y	6,116
8	0.88	176.6	155.4	13.8	8.49	25.3	Y	8,033
9	0.96	175.8	168.8	14.7	8.50	24.1	Y	7,884
10	0.90	187.0	168.3	14.8	8.45	23.4	Y	7,872
11	0.89	168.1	149.6	15.1	8.39	22.3	Y	8,489
12	0.90	184.3	165.9	15.8	8.33	20.8	Y	8,108
13	0.89	159.1	141.6	15.7	9.85	36.7	Y	9,127
14	1.00	155.5	155.5	15.3	8.34	21.9	Y	9,487
15	1.03	149.5	154.0	15.2	8.38	22.4	Y	9,495
16	1.00	163.5	163.5	15.6	8.38	21.8	Y	8,489
17	0.98	177.7	174.1	14.6	8.44	23.8	Y	7,558
18	1.02	197.9	201.9	14.6	8.44	23.9	Y	7,729
19	1.02	145.5	148.4	15.0	8.45	23.4	Y	9,093
20	1.00	144.0	144.0	15.8	8.44	22.0	Y	10,331
21	0.93	155.4	144.5	16.2	8.38	20.8	Y	9,003
22	0.95	144.1	136.9	15.8	8.41	21.7	Y	9,389
23	1.03	146.0	150.4	14.8	8.46	23.6	Y	9,276
24	1.00	152.2	152.2	14.4	8.48	24.5	Y	9,381
25	0.98	168.1	164.7	15.7	8.49	22.4	Y	8,903
26	1.05	151.8	159.4	16.4	8.41	21.0	Y	9,446
27	0.95	174.6	165.9	16.6	8.41	20.4	Y	8,655
28	0.85	147.1	125.0	16.5	8.39	20.2	Y	9,896
29	0.94	137.7	129.4	16.7	8.38	20.1	Y	9,715
30	0.97	132.5	128.5	17.3	8.38	19.4	Y	9,010
31	1.00	147.5	147.5	17.1	8.40	19.9	Y	8,211

Signature: \_\_\_\_\_



Date: \_\_\_\_\_

8-10-22

Print Name: \_\_\_\_\_

Chuck Leffler

Cert #: \_\_\_\_\_

T-7158 FE

(1) If Cl2 at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.  
 (2) Prior to 11/2014, Peak Instantaneous Demand Flow is used.

# Department of Human Services - Drinking Water Section

## Membrane Integrity Report Form

Public Water System Name: Albany

PWS ID#: 41 00012 B

Month/Year:

7/ 2022

Albany/Millersburg Water Plant

Date	Membrane 1	Membrane 2	Membrane 3	Membrane 4
07/01/22	Pass	Pass	Pass	Pass
07/02/22	Pass	Pass	Pass	Pass
07/03/22	Pass	Pass	Pass	Pass
07/04/22	Pass	Pass	Pass	Pass
07/05/22	Pass	Pass	Pass	Pass
07/06/22	Pass	Pass	Pass	Pass
07/07/22	Pass	Pass	Pass	Pass
07/08/22	Pass	Pass	Pass	Pass
07/09/22	Pass	Pass	Pass	Pass
07/10/22	Pass	Pass	Pass	Pass
07/11/22	Pass	Pass	Pass	Pass
07/12/22	Pass	Pass	Pass	Pass
07/13/22	Pass	Pass	Pass	Pass
07/14/22	Pass	Pass	Pass	Pass
07/15/22	Pass	Pass	Pass	Pass
07/16/22	Pass	Pass	Pass	Pass
07/17/22	Pass	Pass	Pass	Pass
07/18/22	Pass	Pass	Pass	Pass
07/19/22	Pass	Pass	Pass	Pass
07/20/22	Pass	Pass	Pass	Pass
07/21/22	Pass	Pass	Pass	Pass
07/22/22	Pass	Pass	Pass	Pass
07/23/22	Pass	Pass	Pass	Pass
07/24/22	Pass	Pass	Pass	Pass
07/25/22	Pass	Pass	Pass	Pass
07/26/22	Pass	Pass	Pass	Pass
07/27/22	Pass	Pass	Pass	Pass
07/28/22	Pass	Pass	Pass	Pass
07/29/22	Pass	Pass	Pass	Pass
07/30/22	Pass	Pass	Pass	Pass
07/31/22	Pass	Pass	Pass	Pass

Signature:



Date:

8-10-22

Print Name:

Chuck Leffler

Cert. #:

T-7158 FE