

OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Linn
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

System Name: ALBANY, CITY OF ID #: OR4100012 WTP:-WTP-B

Month/Year: 8/2022

DAY	12 AM	4 AM	8 AM	NOON	4 PM	8 PM	Highest Reading of the Day (1)
	[NTU]	[NTU]	[NTU]	[NTU]	[NTU]	[NTU]	[NTU]
1	0.01	0.01	0.01	0.01	0.01	0.01	0.01
2	0.01	0.01	0.01	0.01	0.01	0.01	0.01
3	0.01	0.01	0.01	0.01	0.01	0.01	0.01
4	0.01	0.01	0.01	0.01	0.01	0.01	0.01
5	0.01	0.01	0.01	0.01	0.01	0.01	0.01
6	0.01	0.01	0.01	0.01	0.01	0.01	0.01
7	0.01	0.01	0.01	0.01	0.01	0.01	0.01
8	0.01	0.01	0.01	0.01	0.01	0.01	0.01
9	0.01	0.01	0.01	0.01	0.01	0.01	0.01
10	0.01	0.01	Plant Off	0.01	0.01	0.01	0.01
11	0.01	0.01	0.01	0.01	0.01	0.01	0.01
12	Plant Off	Plant Off	0.13	0.01	0.01	0.01	0.13
13	0.01	0.01	0.01	0.01	0.01	0.01	0.01
14	0.01	0.01	0.01	0.01	0.01	0.01	0.01
15	0.01	0.01	0.01	0.01	0.01	0.01	0.01
16	0.01	0.01	0.01	0.01	0.01	0.01	0.01
17	0.01	0.01	0.01	0.01	0.01	0.01	0.01
18	0.01	0.01	0.01	0.01	0.01	0.01	0.01
19	0.01	0.01	0.01	0.01	0.01	0.01	0.01
20	0.01	0.01	0.01	0.01	0.01	0.01	0.01
21	0.01	0.01	0.01	0.01	0.01	0.01	0.01
22	0.01	0.01	0.01	0.01	0.01	0.01	0.01
23	0.01	0.01	0.01	0.01	0.01	0.01	0.01
24	0.01	0.01	0.01	0.01	0.01	0.01	0.01
25	0.01	0.01	0.01	0.01	0.01	0.01	0.01
26	0.01	0.01	0.01	0.01	0.01	0.01	0.01
27	0.01	0.01	0.01	0.01	0.01	0.01	0.01
28	0.01	0.01	0.01	0.01	0.01	0.01	0.01
29	0.01	0.01	0.01	0.01	0.01	0.01	0.01
30	0.01	0.01	0.01	0.01	0.01	0.01	0.01
31	0.01	0.01	0.01	0.01	0.01	0.01	0.01

Membrane Filtration	Monthly Summary (Answer Yes or No)	
95% of turbidity readings <= 1 NTU? (2) <input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? <input checked="" type="radio"/> Yes / <input type="radio"/> No	All CL2 residuals at entry point >= 0.2 mg/l? <input checked="" type="radio"/> Yes / <input type="radio"/> No
All daily turbidity readings <= 5 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No	Notes:	
PRINTED NAME: <i>Chuck Leffler</i>		DATE: 9-2-22
SIGNATURE: <i>[Signature]</i>		CERT #: T-1158 FE
PHONE #: 541-990-1907		

(1) Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. (2) Filtered systems only.

OHA - Drinking Water Program - Surface Water Quality Data Form

System Name: ALBANY, CITY OF ID #: OR4100012 WTP:-WTP-B **Month/Year: 8/2022**

Date / Time	Minimum CL2 Residual @ 1st User (C) (1)	Contact Time (T)	Actual CT	Temp.	pH	Reqd. CT	CT Met? (1)	Peak Hourly Demand Flow (2)
	[ppm or mg/L]	[minutes]	C x T	[°C]		Use tables	Yes / No	[GPM]
1	0.99	120.1	118.9	16.8	8.46	20.8	Y	9,547
2	0.98	161.5	158.3	16.2	8.46	21.5	Y	8,079
3	0.96	131.4	126.1	15.7	8.49	22.5	Y	9,573
4	1.11	155.8	172.9	15.0	8.48	23.7	Y	9,412
5	1.05	152.7	160.3	14.6	8.46	24.2	Y	9,085
6	1.00	155.8	155.8	14.7	8.49	24.1	Y	8,981
7	0.98	150.6	147.6	15.1	8.50	23.4	Y	8,961
8	1.00	160.5	160.5	15.3	8.50	23.2	Y	8,856
9	1.07	145.1	155.3	14.8	8.49	24.2	Y	8,904
10	1.05	117.1	123.0	15.3	8.61	24.4	Y	8,595
11	1.01	105.4	106.5	14.3	8.63	26.1	Y	8,168
12	0.95	60.9	57.9	14.7	8.63	25.2	Y	7,094
13	0.99	154.2	152.7	14.6	8.54	24.6	Y	8,124
14	0.97	145.9	141.5	14.5	8.41	23.6	Y	9,096
15	0.98	151.8	148.8	14.8	8.41	23.2	Y	9,245
16	0.96	150.6	144.6	15.2	8.34	22.0	Y	9,425
17	0.91	138.4	125.9	15.4	8.31	21.2	Y	9,036
18	0.87	171.1	148.9	15.7	8.34	20.9	Y	8,534
19	0.91	200.7	182.6	14.2	8.39	23.7	Y	7,274
20	0.93	175.0	162.8	15.0	8.40	22.7	Y	8,204
21	0.98	191.4	187.6	14.3	8.42	24.1	Y	7,870
22	1.02	163.3	166.6	14.8	8.39	23.1	Y	8,531
23	1.00	198.8	198.8	14.9	8.36	22.7	Y	7,851
24	0.95	168.7	160.3	15.2	8.34	21.9	Y	8,510
25	0.92	178.1	163.9	15.4	8.37	21.8	Y	7,970
26	0.94	173.5	163.1	15.3	8.36	21.9	Y	8,580
27	1.07	183.7	196.6	15.2	8.34	22.3	Y	7,589
28	1.06	174.7	185.2	13.4	8.38	25.3	Y	8,735
29	1.04	163.8	170.4	13.7	8.43	25.3	Y	8,868
30	1.05	169.2	177.7	14.2	8.44	24.5	Y	8,632
31	1.02	179.3	182.9	15.0	8.40	23.0	Y	8,029

Signature: _____



Date: _____

9-2-22

Print Name: _____

Chuck Leffler

Cert #: _____

T-71SR FE

(1) If Cl2 at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.
 (2) Prior to 11/2014, Peak Instantaneous Demand Flow is used.

Department of Human Services - Drinking Water Section

Membrane Integrity Report Form

Public Water System Name: Albany

PWS ID#: 41 00012 B

Month/Year:

8/ 2022

Albany/Millersburg Water Plant

Date	Membrane 1	Membrane 2	Membrane 3	Membrane 4
08/01/22	Pass	Pass	Pass	Pass
08/02/22	Pass	Pass	Pass	Pass
08/03/22	Pass	Pass	Pass	Pass
08/04/22	Pass	Pass	Pass	Pass
08/05/22	Pass	Pass	Pass	Pass
08/06/22	Pass	Pass	Pass	Pass
08/07/22	Pass	Pass	Pass	Pass
08/08/22	Pass	Pass	Pass	Pass
08/09/22	Pass	Pass	Pass	Pass
08/10/22	Pass	Pass	Pass	Pass
08/11/22	Pass	Pass	Pass	Pass
08/12/22	Pass	Pass	Pass	Pass
08/13/22	Pass	Pass	Pass	Pass
08/14/22	Pass	Pass	Pass	Pass
08/15/22	Pass	Pass	Pass	Pass
08/16/22	Pass	Pass	Pass	Pass
08/17/22	Pass	Pass	Pass	Pass
08/18/22	Pass	Pass	Pass	Pass
08/19/22	Pass	Pass	Pass	Pass
08/20/22	Pass	Pass	Pass	Pass
08/21/22	Pass	Pass	Pass	Pass
08/22/22	Pass	Pass	Pass	Pass
08/23/22	Pass	Pass	Pass	Pass
08/24/22	Pass	Pass	Pass	Pass
08/25/22	Pass	Pass	Pass	Pass
08/26/22	Pass	Pass	Pass	Pass
08/27/22	Pass	Pass	Pass	Pass
08/28/22	Pass	Pass	Pass	Pass
08/29/22	Pass	Pass	Pass	Pass
08/30/22	Pass	Pass	Pass	Pass
08/31/22	Pass	Pass	Pass	Pass

Signature: _____



Date: _____

9-2-22

Print Name: _____

Chuck Kestler

Cert. #: _____

T-7158 FE