

OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Linn
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

System Name: ALBANY, CITY OF ID #: OR4100012 WTP:-WTP-B

Month/Year: 9/2022

DAY	12 AM	4 AM	8 AM	NOON	4 PM	8 PM	Highest Reading of the Day (1)
	[NTU]	[NTU]	[NTU]	[NTU]	[NTU]	[NTU]	[NTU]
1	0.01	0.01	0.01	0.02	0.01	0.01	0.02
2	0.01	0.01	0.01	0.01	0.01	0.01	0.01
3	0.01	0.01	0.01	0.01	0.01	0.01	0.01
4	0.01	0.01	0.01	0.01	0.01	0.01	0.01
5	0.01	0.01	0.01	0.01	0.01	0.01	0.01
6	0.02	0.01	0.01	0.01	0.01	0.01	0.02
7	0.01	0.01	0.01	0.01	0.01	0.01	0.01
8	0.01	0.01	0.01	0.01	0.01	0.01	0.01
9	0.01	0.01	0.01	0.01	0.02	0.01	0.02
10	0.01	0.01	0.01	0.01	0.01	0.01	0.01
11	0.01	0.01	0.01	0.01	0.01	0.01	0.01
12	0.01	0.01	0.03	0.01	0.01	0.01	0.03
13	0.01	0.01	0.01	0.01	0.01	0.01	0.01
14	0.01	0.01	0.01	0.01	0.01	0.02	0.02
15	0.01	0.02	0.01	0.01	0.01	0.02	0.02
16	0.01	0.01	0.01	0.01	0.01	0.01	0.01
17	0.01	0.01	0.01	0.01	0.01	0.01	0.01
18	0.01	0.01	0.01	0.01	0.01	0.01	0.01
19	0.01	0.01	0.01	0.01	0.01	0.01	0.01
20	0.01	0.01	0.01	0.01	0.01	0.01	0.01
21	0.01	0.01	0.01	0.01	0.01	0.01	0.01
22	0.01	0.01	0.01	0.01	0.01	0.01	0.01
23	0.01	0.06	0.01	0.01	0.01	0.01	0.06
24	0.01	0.01	0.01	0.01	0.01	0.01	0.01
25	0.01	0.01	0.01	0.01	0.01	0.01	0.01
26	0.01	0.01	0.01	0.01	0.01	0.01	0.01
27	0.01	0.01	0.01	0.01	0.08	0.01	0.08
28	0.01	0.01	0.01	0.01	0.01	0.01	0.01
29	0.01	0.01	0.01	0.01	0.01	0.01	0.01
30	0.01	0.01	0.01	0.01	0.01	0.01	0.01


Membrane Filtration	Monthly Summary (Answer Yes or No)	
95% of turbidity readings <= 1 NTU? (2) <input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? <input checked="" type="radio"/> Yes / <input type="radio"/> No	All CL2 residuals at entry point >= 0.2 mg/l? <input checked="" type="radio"/> Yes / <input type="radio"/> No
All daily turbidity readings <= 5 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No		
Notes:	PRINTED NAME: <i>Chuck Leffler</i>	
	SIGNATURE: <i>[Signature]</i>	DATE: 10-5-22
	PHONE #: 541-990-1907	CERT #: T-7158 FE

(1) Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. (2) Filtered systems only.

OHA - Drinking Water Program - Surface Water Quality Data Form

System Name: ALBANY, CITY OF ID #: OR4100012 WTP:-WTP-B **Month/Year: 9/2022**

Date / Time	Minimum CL2 Residual @ 1st User (C) (1)	Contact Time (T)	Actual CT	Temp.	pH	Reqd. CT	CT Met? (1)	Peak Hourly Demand Flow (2)
	[ppm or mg/L]	[minutes]	C x T	[°C]		Use tables	Yes / No	[GPM]
1	0.97	178.5	173.1	14.3	8.39	23.8	Y	8,142
2	0.97	189.4	183.7	13.7	8.40	24.7	Y	7,322
3	1.05	184.9	194.1	14.5	8.40	23.8	Y	7,247
4	0.95	178.7	169.8	13.2	8.38	25.3	Y	8,090
5	0.93	161.3	150.0	14.3	8.47	24.3	Y	8,675
6	0.95	167.3	158.9	13.5	8.42	25.2	Y	8,138
7	0.98	165.0	161.7	13.5	10.92	62.9	Y	8,195
8	0.99	180.0	178.2	13.0	8.44	26.4	Y	7,665
9	0.98	175.4	171.9	12.8	8.48	27.1	Y	7,957
10	0.99	196.6	194.6	12.4	8.45	27.5	Y	7,267
11	1.00	185.6	185.6	12.4	8.47	27.8	Y	7,470
12	0.99	159.2	157.6	11.9	8.45	28.3	Y	8,463
13	0.91	187.7	170.8	11.5	8.43	28.7	Y	7,574
14	0.89	172.1	153.2	11.9	8.39	27.5	Y	8,223
15	0.93	160.4	149.2	12.1	8.31	26.5	Y	7,429
16	0.95	180.3	171.3	12.2	8.40	27.2	Y	7,885
17	0.95	243.0	230.9	11.6	8.48	29.2	Y	6,184
18	0.92	175.7	161.6	11.5	8.39	28.3	Y	7,761
19	0.93	181.4	168.7	11.6	8.41	28.3	Y	7,729
20	1.05	183.1	192.3	11.6	8.42	28.8	Y	7,487
21	1.00	157.8	157.8	11.9	8.45	28.3	Y	7,394
22	1.13	159.3	180.0	11.8	8.45	29.0	Y	7,933
23	1.13	159.7	180.5	10.9	8.38	30.2	Y	7,975
24	1.13	184.0	207.9	11.1	8.38	29.7	Y	7,439
25	1.08	199.6	215.6	11.4	8.38	29.0	Y	7,659
26	1.04	195.5	203.3	11.9	8.40	28.0	Y	7,632
27	1.00	167.9	167.9	12.2	8.38	27.2	Y	7,095
28	1.00	185.2	185.2	12.3	8.36	26.8	Y	6,433
29	1.06	199.6	211.6	12.3	8.45	27.8	Y	6,591
30	1.01	226.0	228.3	12.1	8.28	26.3	Y	6,558

Signature: 
 Print Name: Charles Jefferson

Date: 10-5-22
 Cert #: T-7158 FE

(1) If Cl2 at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.
 (2) Prior to 11/2014, Peak Instantaneous Demand Flow is used.

Department of Human Services - Drinking Water Section

Membrane Integrity Report Form

Public Water System Name: Albany

PWS ID#: 41 00012 B

Month/Year:

9/ 2022

Albany/Millersburg Water Plant

Date	Membrane 1	Membrane 2	Membrane 3	Membrane 4
09/01/22	Pass	Pass	Pass	Pass
09/02/22	Pass	Pass	Pass	Pass
09/03/22	Pass	Pass	Pass	Pass
09/04/22	Pass	Pass	Pass	Pass
09/05/22	Pass	Pass	Pass	Pass
09/06/22	Pass	Pass	Pass	Pass
09/07/22	Pass	Pass	Pass	Pass
09/08/22	Pass	Pass	Pass	Pass
09/09/22	Pass	Pass	Pass	Pass
09/10/22	Pass	Pass	Pass	Pass
09/11/22	Pass	Pass	Pass	Pass
09/12/22	Pass	Pass	Pass	Pass
09/13/22	Pass	Pass	Pass	Pass
09/14/22	Pass	Pass	Pass	Pass
09/15/22	Pass	Pass	Pass	Pass
09/16/22	Pass	Pass	Pass	Pass
09/17/22	Pass	Pass	Pass	Pass
09/18/22	Pass	Pass	Pass	Pass
09/19/22	Pass	Pass	Pass	Pass
09/20/22	Pass	Pass	Pass	Pass
09/21/22	Pass	Pass	Pass	Pass
09/22/22	Pass	Pass	Pass	Pass
09/23/22	Pass	Pass	Pass	Pass
09/24/22	Pass	Pass	Pass	Pass
09/25/22	Pass	Pass	Pass	Pass
09/26/22	Pass	Pass	Pass	Pass
09/27/22	Pass	Pass	Pass	Pass
09/28/22	Pass	Pass	Pass	Pass
09/29/22	Pass	Pass	Pass	Pass
09/30/22	Pass	Pass	Pass	Pass

Signature: _____



Date: _____

10-5-22

Print Name: _____

Chuck Leffler

Cert. #: _____

T-7158 FE