

**OHA - Drinking Water Program - Turbidity Monitoring Report Form    County: Linn**  
**Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems**

System Name: ALBANY, CITY OF    ID #: OR4100012    WTP:-WTP-B

Month/Year: 10/2022

DAY	12 AM	4 AM	8 AM	NOON	4 PM	8 PM	Highest Reading of the Day (1)
	[NTU]	[NTU]	[NTU]	[NTU]	[NTU]	[NTU]	[NTU]
1	0.01	0.01	0.01	0.01	0.01	0.01	0.01
2	0.01	0.01	0.01	0.01	0.01	0.01	0.01
3	0.01	0.01	0.01	0.01	0.01	0.03	0.03
4	0.01	0.01	0.01	0.01	0.01	0.01	0.01
5	0.01	0.01	0.01	0.01	0.01	0.01	0.01
6	Plant Off	Plant Off	0.01	0.01	0.01	0.01	0.01
7	0.01	0.01	0.01	0.01	0.01	0.01	0.01
8	Plant Off	0.01	0.01	0.01	0.01	0.01	0.01
9	0.01	0.01	0.01	0.01	0.01	0.01	0.01
10	0.01	0.01	0.01	0.01	0.01	0.01	0.01
11	0.01	0.01	0.01	0.01	0.01	0.01	0.01
12	0.01	0.01	0.01	0.01	0.01	0.01	0.01
13	0.01	0.01	0.01	0.01	0.01	0.01	0.01
14	0.01	0.01	0.01	0.01	0.01	0.01	0.01
15	0.01	0.01	0.01	0.01	0.01	0.01	0.01
16	0.01	0.01	0.01	0.01	0.01	0.01	0.01
17	0.01	0.01	0.01	0.01	0.01	0.01	0.01
18	0.01	0.01	0.01	0.01	0.02	0.01	0.02
19	0.01	0.01	0.01	0.01	0.01	0.01	0.01
20	0.01	0.01	0.01	0.01	0.01	0.01	0.01
21	0.01	0.01	0.01	0.01	0.01	0.01	0.01
22	0.01	0.01	0.01	0.01	0.01	0.01	0.01
23	0.01	0.01	0.01	0.01	0.01	0.01	0.01
24	0.01	0.01	0.01	0.01	0.01	0.01	0.01
25	0.01	0.01	0.01	0.01	0.01	0.01	0.01
26	0.01	0.01	0.01	0.01	0.01	0.05	0.05
27	0.01	0.01	0.01	0.01	0.01	0.01	0.01
28	0.01	0.01	0.01	Plant Off	0.01	0.05	0.05
29	0.02	0.01	0.01	0.01	0.01	0.10	0.10
30	0.07	0.01	0.01	0.01	0.01	0.01	0.07
31	0.01	0.01	0.01	0.01	0.01	0.01	0.01

Membrane Filtration	Monthly Summary (Answer Yes or No)	
95% of turbidity readings <= 1 NTU? (2)	Yes/No	CT's met everyday?
All daily turbidity readings <= 5 NTU?	Yes/No	All CL2 residuals at entry point >= 0.2 mg/l?
Notes:	PRINTED NAME:	DATE: 11-8-22
	SIGNATURE:	CERT #: F-7158 FE
	PHONE #: 541-990-1907	

(1) Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. (2) Filtered systems only.

## OHA - Drinking Water Program - Surface Water Quality Data Form

**System Name: ALBANY, CITY OF ID #: OR4100012 WTP:-WTP-B**      **Month/Year: 10/2022**

Date / Time	Minimum CL2 Residual @ 1st User (C) (1)	Contact Time (T)	Actual CT	Temp.	pH	Reqd. CT	CT Met? (1)	Peak Hourly Demand Flow (2)
	[ppm or mg/L]	[minutes]	C x T	[°C]		Use tables	Yes / No	[GPM]
1	0.95	237.0	225.2	11.6	8.34	27.6	Y	6,512
2	0.89	220.1	195.9	12.8	8.35	25.6	Y	6,479
3	0.95	215.1	204.3	12.9	8.34	25.5	Y	6,247
4	1.11	230.2	255.5	12.1	8.32	27.1	Y	6,408
5	1.11	229.1	254.3	11.8	8.33	27.8	Y	6,415
6	1.06	191.4	202.9	11.3	8.25	27.7	Y	5,811
7	1.09	244.9	266.9	11.4	8.30	28.1	Y	5,924
8	1.00	178.3	178.3	12.0	8.25	26.3	Y	6,817
9	1.05	252.4	265.0	11.8	8.32	27.3	Y	5,333
10	0.95	205.4	195.1	11.7	8.22	26.4	Y	5,767
11	0.95	227.8	216.4	11.8	8.24	26.3	Y	6,755
12	0.98	210.7	206.5	10.8	8.28	28.6	Y	6,844
13	1.02	216.1	220.4	10.8	8.40	30.2	Y	6,613
14	0.98	227.4	222.9	10.8	8.33	29.2	Y	6,274
15	0.96	199.4	191.4	10.7	8.35	29.6	Y	7,205
16	1.03	224.6	231.3	10.7	8.47	31.1	Y	6,258
17	1.11	212.3	235.7	11.0	8.38	29.8	Y	5,818
18	1.13	207.4	234.4	10.6	8.34	30.2	Y	7,283
19	1.04	225.5	234.5	10.3	8.35	30.7	Y	6,698
20	1.00	186.2	186.2	10.3	8.26	29.6	Y	7,727
21	1.17	230.6	269.8	10.0	8.45	32.9	Y	6,456
22	1.04	193.3	201.0	9.9	8.31	31.1	Y	7,559
23	1.01	184.0	185.8	9.3	8.40	33.3	Y	8,718
24	1.01	205.4	207.5	9.5	8.47	33.8	Y	7,324
25	1.12	198.6	222.4	9.5	8.31	32.3	Y	7,149
26	1.04	187.8	195.3	9.1	8.32	33.0	Y	7,653
27	0.98	236.6	231.9	8.7	8.34	33.8	Y	6,053
28	0.93	206.9	192.4	9.4	8.53	34.3	Y	5,997
29	1.25	240.4	300.5	10.1	8.27	31.0	Y	6,599
30	1.28	211.5	270.7	10.7	8.34	30.6	Y	7,040
31	1.15	178.9	205.7	10.5	8.39	31.1	Y	7,709

Signature: \_\_\_\_\_



Date: \_\_\_\_\_

11-8-22

Print Name: \_\_\_\_\_

Chuck Leffer

Cert #: \_\_\_\_\_

T-7158 FE

(1) If Cl2 at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.  
 (2) Prior to 11/2014, Peak Instantaneous Demand Flow is used.

# Department of Human Services - Drinking Water Section

## Membrane Integrity Report Form

Public Water System Name: Albany

PWS ID#: 41 00012 B


Month/Year:

10/ 2022

Albany/Millersburg Water Plant

Date	Membrane 1	Membrane 2	Membrane 3	Membrane 4
10/01/22	Pass	Pass	Pass	Pass
10/02/22	Pass	Pass	Pass	Pass
10/03/22	Pass	Pass	Pass	Pass
10/04/22	Pass	Pass	Pass	Pass
10/05/22	Pass	Pass	Pass	Pass
10/06/22	Pass	Pass	Pass	Pass
10/07/22	Pass	Pass	Pass	Pass
10/08/22	Pass	Pass	Pass	Pass
10/09/22	Pass	Pass	Pass	Pass
10/10/22	Pass	Pass	Pass	Pass
10/11/22	Pass	Pass	Pass	Pass
10/12/22	Pass	Pass	Pass	Pass
10/13/22	Pass	Pass	Pass	Pass
10/14/22	Pass	Pass	Pass	Pass
10/15/22	Pass	Pass	Pass	Pass
10/16/22	Pass	Pass	Pass	Pass
10/17/22	Pass	Pass	Pass	Pass
10/18/22	Pass	Pass	Pass	Pass
10/19/22	Pass	Pass	Pass	Pass
10/20/22	Pass	Pass	Pass	Pass
10/21/22	Pass	Pass	Pass	Pass
10/22/22	Pass	Pass	Pass	Pass
10/23/22	Pass	Pass	Pass	Pass
10/24/22	Pass	Pass	Pass	Pass
10/25/22	Pass	Pass	Pass	Pass
10/26/22	Pass	Pass	Pass	Pass
10/27/22	Pass	Pass	Pass	Pass
10/28/22	Pass	Pass	Pass	Pass
10/29/22	Pass	Pass	Pass	Pass
10/30/22	Pass	Pass	Pass	Pass
10/31/22	Pass	Pass	Pass	Pass

Signature: \_\_\_\_\_



Date: \_\_\_\_\_

11-8-22

Print Name: \_\_\_\_\_

Chuck Lettner

Cert. #: \_\_\_\_\_

T-7158 FE