

OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Linn
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

System Name: ALBANY, CITY OF ID #: OR4100012 WTP:-WTP-B

Month/Year: 11/2022

DAY	12 AM	4 AM	8 AM	NOON	4 PM	8 PM	Highest Reading of the Day (1)
	[NTU]	[NTU]	[NTU]	[NTU]	[NTU]	[NTU]	[NTU]
1	0.01	0.01	0.01	0.01	0.01	0.01	0.01
2	0.01	0.01	0.01	0.01	0.01	0.01	0.01
3	0.01	0.01	0.01	0.01	0.01	0.01	0.01
4	0.01	0.01	0.01	0.01	0.01	0.01	0.01
5	0.01	0.01	0.01	0.01	0.01	0.06	0.06
6	0.01	0.01	0.01	0.01	0.01	0.01	0.01
7	0.01	0.01	0.01	0.01	0.01	0.01	0.01
8	0.01	0.01	0.01	0.01	0.01	0.01	0.01
9	0.01	0.01	0.01	0.01	0.01	0.01	0.01
10	0.01	0.01	0.01	0.01	0.01	0.01	0.01
11	0.01	0.01	0.01	0.01	0.01	0.01	0.01
12	0.01	0.01	0.01	0.01	0.01	0.01	0.01
13	0.01	0.01	Plant Off	0.01	0.01	0.01	0.01
14	0.01	0.01	0.01	0.01	0.01	0.01	0.01
15	0.01	0.01	0.01	0.01	0.01	0.01	0.01
16	0.01	0.01	0.01	0.01	0.01	0.01	0.01
17	0.01	0.01	0.01	0.01	0.01	0.04	0.04
18	0.01	0.01	0.01	0.01	0.01	0.01	0.01
19	0.01	0.01	0.01	0.01	0.01	0.01	0.01
20	0.01	0.01	0.01	0.01	0.01	0.01	0.01
21	0.01	0.01	0.01	0.01	0.01	0.01	0.01
22	0.01	0.01	0.01	0.01	0.01	0.01	0.01
23	0.01	0.01	0.01	0.01	0.01	0.01	0.01
24	0.01	0.01	0.01	0.01	0.01	0.01	0.01
25	0.01	0.01	0.01	0.01	0.01	0.01	0.01
26	0.01	0.01	0.01	0.01	0.01	0.01	0.01
27	0.01	0.01	0.01	0.01	0.01	0.01	0.01
28	0.01	0.01	0.01	0.01	0.01	0.01	0.01
29	0.01	0.01	0.01	0.01	0.01	0.01	0.01
30	0.01	0.01	Plant Off	0.01	0.01	0.01	0.01

Membrane Filtration		Monthly Summary (Answer Yes or No)	
95% of turbidity readings <= 1 NTU? (2)	<input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday?	All CL2 residuals at entry point >= 0.2 mg/l?
All daily turbidity readings <= 5 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No
Notes:	PRINTED NAME: <i>Chad Leffler</i>		
	SIGNATURE: <i>[Signature]</i>		DATE: 12-8-22
	PHONE #: 541-990-1907		CERT #: T-7158 FE

(1) Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. (2) Filtered systems only.

OHA - Drinking Water Program - Surface Water Quality Data Form

System Name: ALBANY, CITY OF ID #: OR4100012 WTP:-WTP-B **Month/Year: 11/2022**

Date / Time	Minimum CL2 Residual @ 1st User (C) (1)	Contact Time (T)	Actual CT	Temp.	pH	Reqd. CT	CT Met? (1)	Peak Hourly Demand Flow (2)
	[ppm or mg/L]	[minutes]	C x T	[°C]		Use tables	Yes / No	[GPM]
1	1.11	192.3	213.5	12.1	8.17	25.6	Y	8,615
2	1.06	205.7	218.0	11.1	8.47	30.5	Y	6,622
3	1.06	241.1	255.6	10.5	8.32	30.0	Y	6,332
4	1.05	243.4	255.6	10.5	8.47	31.7	Y	4,789
5	0.89	169.9	151.2	10.7	8.43	30.2	Y	5,788
6	0.78	136.9	106.8	9.1	8.28	31.3	Y	6,030
7	1.04	137.4	142.9	8.7	8.06	30.9	Y	6,166
8	1.00	131.8	131.8	8.7	8.21	32.5	Y	5,975
9	0.99	162.1	160.5	8.4	8.05	31.2	Y	5,287
10	1.09	118.9	129.6	8.2	8.22	33.9	Y	7,005
11	1.13	188.7	213.2	8.4	8.14	32.9	Y	5,007
12	1.15	159.0	182.9	8.9	8.15	31.7	Y	6,220
13	1.18	114.4	135.0	8.3	8.19	33.7	Y	7,734
14	0.99	123.3	122.1	8.1	8.15	33.0	Y	6,722
15	1.00	134.2	134.2	7.4	8.18	35.0	Y	6,869
16	0.93	173.3	161.2	7.0	8.30	37.2	Y	6,092
17	0.92	124.6	114.6	7.2	8.36	37.5	Y	6,366
18	1.14	130.2	148.4	7.2	8.43	39.4	Y	6,522
19	1.10	134.8	148.3	7.1	8.50	40.6	Y	6,608
20	1.09	128.8	140.4	7.2	8.53	40.9	Y	7,443
21	1.18	124.5	146.9	8.0	8.46	38.0	Y	6,590
22	1.16	157.9	183.2	8.7	8.64	38.8	Y	5,847
23	1.09	180.1	196.3	9.0	8.35	33.6	Y	5,945
24	1.02	172.3	175.7	9.3	8.41	33.5	Y	6,322
25	1.00	151.9	151.9	8.9	8.35	33.7	Y	6,312
26	1.02	160.1	163.3	9.0	8.28	32.5	Y	6,254
27	1.00	138.3	138.3	9.2	8.35	33.0	Y	6,998
28	0.95	136.1	129.3	9.0	8.38	33.6	Y	5,697
29	0.91	133.2	121.2	8.5	8.32	33.7	Y	6,556
30	1.02	118.4	120.8	8.5	8.32	34.1	Y	6,143

Signature: _____



Date: _____

12-8-22

Print Name: _____

Chris Laffner

Cert #: _____

T-7158 FE

(1) If Cl2 at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.
 (2) Prior to 11/2014, Peak Instantaneous Demand Flow is used.

Department of Human Services - Drinking Water Section

Membrane Integrity Report Form

Public Water System Name: Albany

PWS ID#: 41 00012 B

Month/Year:

11/ 2022

Albany/Millersburg Water Plant

Date	Membrane 1	Membrane 2	Membrane 3	Membrane 4
11/01/22	Pass	Pass	Pass	Pass
11/02/22	Pass	Pass	Pass	Pass
11/03/22	Pass	Pass	Pass	Pass
11/04/22	Pass	Pass	Pass	Pass
11/05/22	Pass	Pass	Pass	Pass
11/06/22	Pass	Pass	Pass	Pass
11/07/22	Pass	Pass	Pass	Pass
11/08/22	Pass	Pass	Pass	Pass
11/09/22	Pass	Pass	Pass	Pass
11/10/22	Pass	Pass	Pass	Pass
11/11/22	Pass	Pass	Pass	Pass
11/12/22	Pass	Pass	Pass	Pass
11/13/22	Pass	Pass	Pass	Pass
11/14/22	Pass	Pass	Pass	Pass
11/15/22	Pass	Pass	Pass	Pass
11/16/22	Pass	Pass	Pass	Pass
11/17/22	Pass	Pass	Pass	Pass
11/18/22	Pass	Pass	Pass	Pass
11/19/22	Pass	Pass	Pass	Pass
11/20/22	Pass	Pass	Pass	Pass
11/21/22	Pass	Pass	Pass	Pass
11/22/22	Pass	Pass	Pass	Pass
11/23/22	Pass	Pass	Pass	Pass
11/24/22	Pass	Pass	Pass	Pass
11/25/22	Pass	Pass	Pass	Pass
11/26/22	Pass	Pass	Pass	Pass
11/27/22	Pass	Pass	Pass	Pass
11/28/22	Pass	Pass	Pass	Pass
11/29/22	Pass	Pass	Pass	Pass
11/30/22	Pass	Pass	Pass	Pass

Signature: _____



Print Name: _____

Chris Leffler

Date: _____

12-8-22

Cert. #: _____

T-7158 FE