

**OHA - Drinking Water Program - Turbidity Monitoring Report Form    County: Linn**  
**Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems**

System Name: ALBANY, CITY OF    ID #: OR4100012    WTP:-WTP-B

Month/Year: 12/2022

DAY	12 AM	4 AM	8 AM	NOON	4 PM	8 PM	Highest Reading of the Day (1)
	[NTU]	[NTU]	[NTU]	[NTU]	[NTU]	[NTU]	[NTU]
1	0.01	0.01	0.01	0.01	0.01	0.01	0.01
2	0.01	0.01	0.01	0.01	0.01	0.01	0.01
3	0.01	0.01	0.01	0.01	0.01	0.01	0.01
4	0.01	0.01	0.01	0.01	0.01	0.01	0.01
5	0.01	0.01	0.01	0.01	0.01	0.01	0.01
6	0.01	0.01	0.01	0.01	0.01	0.01	0.01
7	0.01	0.01	0.01	0.01	0.01	0.01	0.01
8	0.01	0.01	0.01	0.01	0.01	0.01	0.01
9	0.01	0.01	0.01	0.01	0.01	0.01	0.01
10	0.01	0.01	0.01	0.01	0.01	0.01	0.01
11	0.01	0.01	0.01	0.01	0.01	0.01	0.01
12	0.01	0.01	0.01	0.01	0.01	0.01	0.01
13	0.01	0.01	0.01	0.01	0.01	0.01	0.01
14	0.01	0.01	0.01	0.01	0.01	0.01	0.01
15	0.01	0.01	0.01	0.01	0.01	0.02	0.02
16	0.01	0.01	0.01	0.01	0.01	0.01	0.01
17	0.01	0.01	0.01	0.01	0.01	0.01	0.01
18	0.01	0.01	0.01	0.01	0.01	0.01	0.01
19	0.01	0.01	0.01	0.01	0.01	0.01	0.01
20	0.01	0.01	0.01	0.01	0.01	0.01	0.01
21	0.01	0.01	0.01	0.01	0.01	0.01	0.01
22	0.01	0.01	0.01	0.01	0.01	0.01	0.01
23	0.01	0.01	0.01	0.01	0.01	0.01	0.01
24	0.01	0.01	0.01	0.01	0.01	0.01	0.01
25	0.01	0.01	0.01	0.01	0.01	0.01	0.01
26	0.01	0.01	0.01	0.01	0.01	0.01	0.01
27	0.01	0.01	Plant Off	0.01	Plant Off	0.01	0.01
28	0.01	0.01	0.01	0.01	0.01	0.01	0.01
29	0.01	0.01	0.01	0.01	0.01	0.01	0.01
30	0.01	0.01	0.01	0.02	0.01	0.01	0.02
31	0.01	0.01	0.01	0.01	0.01	0.01	0.01

Membrane Filtration	Monthly Summary (Answer Yes or No)	
95% of turbidity readings <= 1 NTU? (2) <input checked="" type="checkbox"/> Yes / No	CT's met everyday? <input checked="" type="checkbox"/> Yes / No	All CL2 residuals at entry point >= 0.2 mg/l? <input checked="" type="checkbox"/> Yes / No
All daily turbidity readings <= 5 NTU? <input checked="" type="checkbox"/> Yes / No		
Notes:	PRINTED NAME: <i>Chuck Leffer</i>	DATE: 1-5-23
	SIGNATURE: <i>[Signature]</i>	CERT #: T-7158 FE
	PHONE #: 541-990-1907	

(1) Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. (2) Filtered systems only.




## OHA - Drinking Water Program - Surface Water Quality Data Form

**System Name: ALBANY, CITY OF ID #: OR4100012 WTP:-WTP-B**      **Month/Year: 12/2022**

Date / Time	Minimum CL2 Residual @ 1st User (C) (1) [ppm or mg/L]	Contact Time (T) [minutes]	Actual CT C x T	Temp. [°C]	pH	Reqd. CT Use tables	CT Met? (1) Yes / No	Peak Hourly Demand Flow (2) [GPM]
1	0.37	143.2	53.0	8.2	8.33	32.4	Y	6,790
2	OFFLINE	152.9		7.9	8.22	30.4		5,949
3	1.17	148.5	173.7	7.8	8.26	35.7	Y	5,823
4	1.12	136.5	152.9	7.3	8.11	34.8	Y	7,495
5	1.13	129.1	145.9	7.2	8.12	35.3	Y	7,099
6	OFFLINE	141.5		7.1	8.07	30.4		7,239
7	OFFLINE	136.4		7.4	8.13	30.6		6,689
8	0.62	127.1	78.8	7.3	8.09	32.6	Y	6,005
9	0.47	133.2	62.6	7.0	8.12	33.0	Y	6,381
10	OFFLINE	144.1		7.1	8.25	32.6		6,681
11	OFFLINE	147.5		7.7	8.40	33.0		7,066
12	1.20	140.2	168.2	7.4	8.35	38.2	Y	6,998
13	1.11	134.1	148.9	6.8	8.44	40.6	Y	6,671
14	1.24	127.2	157.7	6.2	8.34	41.3	Y	6,345
15	1.13	115.4	130.4	6.1	8.33	40.9	Y	7,934
16	1.17	141.3	165.3	5.4	8.33	43.2	Y	6,207
17	1.00	120.6	120.6	4.8	8.30	43.7	Y	6,440
18	1.07	152.8	163.5	5.1	8.22	41.9	Y	5,805
19	1.35	121.7	164.3	5.9	8.22	40.9	Y	7,094
20	1.00	167.2	167.2	6.5	8.17	37.1	Y	7,195
21	0.72	176.7	127.2	6.5	8.34	38.1	Y	5,794
22	0.75	156.6	117.5	5.1	8.65	47.3	Y	6,733
23	1.23	142.3	175.0	4.7	8.58	50.1	Y	7,298
24	1.17	134.6	157.5	5.0	8.48	47.0	Y	7,348
25	0.98	203.1	199.0	6.8	8.38	39.2	Y	4,724
26	1.00	114.7	114.7	7.8	8.40	37.0	Y	6,619
27	0.86	132.8	114.2	8.0	8.36	35.3	Y	4,716
28	0.89	205.3	182.7	7.7	8.14	33.3	Y	7,436
29	1.02	224.0	228.5	7.5	8.07	33.4	Y	6,981
30	1.06	196.6	208.4	7.8	8.10	33.3	Y	7,612
31	1.14	187.3	213.5	7.7	8.15	34.5	Y	7,386

Signature: \_\_\_\_\_



Date: \_\_\_\_\_

12-23

Print Name: \_\_\_\_\_

Chuck Leffer

Cert #: \_\_\_\_\_

T-7158 FE

(1) If Cl<sub>2</sub> at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.  
 (2) Prior to 11/2014, Peak Instantaneous Demand Flow is used.

# Department of Human Services - Drinking Water Section

## Membrane Integrity Report Form

Public Water System Name: Albany

PWS ID#: 41 00012 B


Month/Year:

12/ 2022

Albany/Millersburg Water Plant

Date	Membrane 1	Membrane 2	Membrane 3	Membrane 4
12/01/22	Pass	Pass	Pass	Pass
12/02/22	Pass	Pass	Pass	Pass
12/03/22	Pass	Pass	Pass	Pass
12/04/22	Pass	Pass	Pass	Pass
12/05/22	Pass	Pass	Pass	Pass
12/06/22	Pass	Pass	Pass	Pass
12/07/22	Pass	Pass	Pass	Pass
12/08/22	Pass	Pass	Pass	Pass
12/09/22	Pass	Pass	Pass	Pass
12/10/22	Pass	Pass	Pass	Pass
12/11/22	Pass	Pass	Pass	Pass
12/12/22	Pass	Pass	Pass	Pass
12/13/22	Pass	Pass	Pass	Pass
12/14/22	Pass	Pass	Pass	Pass
12/15/22	Pass	Pass	Pass	Pass
12/16/22	Pass	Pass	Pass	Pass
12/17/22	Pass	Pass	Pass	Pass
12/18/22	Pass	Pass	Pass	Pass
12/19/22	Pass	Pass	Pass	Pass
12/20/22	Pass	Pass	Pass	Pass
12/21/22	Pass	Pass	Pass	Pass
12/22/22	Pass	Pass	Pass	Pass
12/23/22	Pass	Pass	Pass	Pass
12/24/22	Pass	Pass	Pass	Pass
12/25/22	Pass	Pass	Pass	Pass
12/26/22	Pass	Pass	Pass	Pass
12/27/22	Pass	Pass	Pass	Pass
12/28/22	Pass	Pass	Pass	Pass
12/29/22	Pass	Pass	Pass	Pass
12/30/22	Pass	Pass	Pass	Pass
12/31/22	Pass	Pass	Pass	Pass

Signature:



Date:

1-5-23

Print Name:

Chad LeFler

Cert. #:

T-7158FE