


OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Linn
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

System Name: ALBANY, CITY OF ID #: OR4100012 WTP:-WTP-B

Month/Year: 1/2023

DAY	12 AM	4 AM	8 AM	NOON	4 PM	8 PM	Highest Reading of the Day (1)
	[NTU]	[NTU]	[NTU]	[NTU]	[NTU]	[NTU]	[NTU]
1	0.01	0.01	0.01	0.01	0.01	0.01	0.01
2	0.01	0.01	0.01	0.01	0.01	0.01	0.01
3	0.01	0.01	0.01	0.01	0.01	0.01	0.01
4	0.01	0.01	0.01	0.01	0.01	0.01	0.01
5	0.01	0.01	0.01	0.01	0.01	0.01	0.01
6	0.01	0.01	0.01	0.01	0.01	0.01	0.01
7	0.01	0.01	0.01	0.01	0.01	0.01	0.01
8	0.01	0.01	0.01	0.01	0.01	0.01	0.01
9	0.01	0.01	0.01	0.01	0.01	0.01	0.01
10	0.01	0.01	0.01	0.01	0.01	0.01	0.01
11	0.01	0.01	Plant Off	Plant Off	Plant Off	0.02	0.02
12	0.02	0.01	0.01	0.01	0.01	0.01	0.02
13	0.01	0.01	0.01	0.01	0.01	0.01	0.01
14	0.01	0.01	0.01	0.01	0.01	0.01	0.01
15	0.01	0.01	0.01	0.01	0.01	0.01	0.01
16	0.01	0.01	0.01	0.01	0.01	0.03	0.03
17	0.01	0.01	0.01	0.01	0.01	0.01	0.01
18	0.01	0.01	0.01	0.01	0.01	0.01	0.01
19	0.01	0.01	0.01	0.01	0.01	0.01	0.01
20	0.01	0.01	0.01	0.01	0.01	0.01	0.01
21	0.01	0.01	0.01	0.01	0.01	0.01	0.01
22	0.01	0.01	0.01	0.01	0.01	0.01	0.01
23	0.01	0.01	0.01	0.01	0.01	0.01	0.01
24	0.01	0.01	0.01	0.01	0.01	0.01	0.01
25	0.01	0.01	0.01	0.01	0.01	0.01	0.01
26	0.01	0.01	0.01	0.01	0.01	0.01	0.01
27	0.01	0.01	0.01	0.01	0.01	0.01	0.01
28	0.01	0.01	0.01	0.01	0.01	0.01	0.01
29	0.01	0.01	0.01	0.01	0.01	0.01	0.01
30	0.01	0.01	0.01	Plant Off	0.01	0.01	0.01
31	0.01	0.01	0.01	0.01	0.01	0.01	0.01

Membrane Filtration	Monthly Summary (Answer Yes or No)	
95% of turbidity readings <= 1 NTU? (2) <input checked="" type="radio"/> Yes <input type="radio"/> No	CT's met everyday? <input checked="" type="radio"/> Yes <input type="radio"/> No	All CL2 residuals at entry point >= 0.2 mg/l? <input checked="" type="radio"/> Yes <input type="radio"/> No
All daily turbidity readings <= 5 NTU? <input checked="" type="radio"/> Yes <input type="radio"/> No		
Notes:	PRINTED NAME: Scott LaRoque	
	SIGNATURE: 	DATE: 2/7/23
	PHONE #: 541-791-0175	CERT #: N/A

(1) Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. (2) Filtered systems only.

OHA - Drinking Water Program - Surface Water Quality Data Form

System Name: ALBANY, CITY OF ID #: OR4100012 WTP:-WTP-B	Month/Year: 1/2023
---	--------------------

Date / Time	Minimum CL2 Residual @ 1st User (C) (1)	Contact Time (T)	Actual CT	Temp.	pH	Reqd. CT	CT Met? (1)	Peak Hourly Demand Flow (2)
	[ppm or mg/L]	[minutes]	C x T	[°C]		Use tables	Yes / No	[GPM]
1	1.16	175.7	203.8	7.6	8.19	35.3	Y	7,054
2	1.17	141.0	165.0	7.2	8.24	37.1	Y	7,549
3	1.10	136.9	150.6	7.1	8.32	38.2	Y	7,325
4	1.06	121.5	128.8	7.0	8.32	38.1	Y	6,766
5	1.11	186.7	207.2	7.1	8.31	38.0	Y	6,571
6	1.13	204.9	231.5	7.4	8.27	36.6	Y	6,799
7	1.06	214.4	227.3	7.6	8.35	37.0	Y	6,528
8	1.09	159.3	173.6	7.7	8.33	36.6	Y	7,636
9	0.78	176.6	137.7	7.5	8.35	36.1	Y	7,659
10	1.03	180.1	185.5	6.9	8.41	39.5	Y	7,965
11	1.15	157.0	180.6	7.2	8.61	42.5	Y	7,112
12	1.11	218.9	243.0	7.5	8.29	36.8	Y	6,593
13	1.05	243.6	255.8	8.2	8.23	34.0	Y	5,722
14	1.00	247.9	247.9	8.2	8.24	33.9	Y	5,939
15	1.04	218.4	227.1	8.1	8.30	35.1	Y	6,576
16	1.10	196.5	216.2	7.4	8.43	38.7	Y	7,297
17	1.15	193.1	222.1	7.4	8.45	39.4	Y	6,586
18	1.15	214.1	246.2	7.5	8.43	38.6	Y	6,330
19	1.02	202.3	206.3	7.0	8.20	36.2	Y	6,031
20	0.96	230.9	221.7	6.4	8.05	35.5	Y	5,952
21	1.11	240.4	266.8	6.1	8.03	36.6	Y	5,910
22	1.11	197.1	218.8	5.7	8.12	39.0	Y	6,849
23	1.04	192.4	200.1	6.1	8.19	38.6	Y	7,145
24	1.02	186.7	190.4	5.8	8.25	40.1	Y	7,965
25	1.04	181.5	188.8	5.9	8.23	39.8	Y	7,521
26	0.80	206.5	165.2	6.3	8.20	37.1	Y	6,453
27	1.07	205.0	219.4	6.5	8.21	37.8	Y	6,136
28	1.05	205.6	215.9	6.7	8.23	37.5	Y	6,368
29	0.99	175.4	173.6	5.3	8.34	42.7	Y	7,600
30	1.02	175.6	179.1	3.9	8.49	50.1	Y	6,500
31	1.04	200.7	208.7	3.4	8.31	48.7	Y	6,342

Signature: 

Date: 2/7/23

Print Name: Scott LaRogue
Water Superintendent

Cert #: N/A

(1) If Cl2 at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.
 (2) Prior to 11/2014, Peak Instantaneous Demand Flow is used.

Department of Human Services - Drinking Water Section

Membrane Integrity Report Form

Public Water System Name: Albany

PWS ID#: 41 00012 B


Month/Year:

1/ 2023

Albany/Millersburg Water Plant

Date	Membrane 1	Membrane 2	Membrane 3	Membrane 4
01/01/23	Pass	Pass	Pass	Pass
01/02/23	Pass	Pass	Pass	Pass
01/03/23	Pass	Pass	Pass	Pass
01/04/23	Pass	Pass	Pass	Pass
01/05/23	Pass	Pass	Pass	Pass
01/06/23	Pass	Pass	Pass	Pass
01/07/23	Pass	Pass	Pass	Pass
01/08/23	Pass	Pass	Pass	Pass
01/09/23	Pass	Pass	Pass	Pass
01/10/23	Pass	Pass	Pass	Pass
01/11/23	Pass	Pass	Pass	Pass
01/12/23	Pass	Pass	Pass	Pass
01/13/23	Pass	Pass	Pass	Pass
01/14/23	Pass	Pass	Pass	Pass
01/15/23	Pass	Pass	Pass	Pass
01/16/23	Pass	Pass	Pass	Pass
01/17/23	Pass	Pass	Pass	Pass
01/18/23	Pass	Pass	Pass	Pass
01/19/23	Pass	Pass	Pass	Pass
01/20/23	Pass	Pass	Pass	Pass
01/21/23	Pass	Pass	Pass	Pass
01/22/23	Pass	Pass	Pass	Pass
01/23/23	Pass	Pass	Pass	Pass
01/24/23	Pass	Pass	Pass	Pass
01/25/23	Pass	Pass	Pass	Pass
01/26/23	Pass	Pass	Pass	Pass
01/27/23	Pass	Pass	Pass	Pass
01/28/23	Pass	Pass	Pass	Pass
01/29/23	Pass	Pass	Pass	Pass
01/30/23	Pass	Pass	Pass	Pass
01/31/23	Pass	Pass	Pass	Pass

Signature:



Date:

2/7/23

Print Name:

Scott LaRaque

Cert. #:

N/A

WT_AM_MonthlyMembrane Water Superintendent

Reported On 2/6/2023 at 08:25